
Foundation for Cross-Connection Control and Hydraulic Research

List of Approved Backflow Prevention Assemblies

01 October 2026



USC University of Southern California

The List of Approved Backflow Prevention Assemblies is published by
the Foundation for Cross-Connection Control and Hydraulic Research
a Division of the Viterbi School of Engineering

2026 © University of Southern California
All Rights Reserved

Table of Contents

Legend 4

Notices 5

Orientation of Assemblies 6

Shutoff Valve Designation 7

Detector Assembly Meters 11

Special Notices 12

Atmospheric Vacuum Breaker (AVB) 13

Double Check Valve Assembly (DC) 14

Double Check-Detector Assembly (DCDA) 236

Double Check-Detector Assembly-Type II (DCDA-II) 370

Pressure Vacuum Breaker Assembly (PVB) 391

Reduced Pressure Principle Assembly (RP) 407


Reduced Pressure Principle-Detector Assembly (RPDA) 625

Reduced Pressure Principle-Detector Assembly-Type II (RPDA-II) 673

Spill-Resistant Pressure Vacuum Breaker Assembly (SVB) 685

Manufacturers of Approved Backflow Prevention Assemblies 689

Legend



2026 © University of Southern California

Notices

REGARDING RENEWALS:
The original Certificate of Approval–identified by the Edition of the Manual and the approval date shown in this list is valid as of the date of this list, only if the original or renewal date shown hereon is within three (3) years of the date of this list. The responsibility to request a renewal of an Approval is that of each manufacturer. The USC Foundation retains the right of determining the extent of re-evaluation required before renewal is granted. Certificates of Approval are not recalled for the purpose of updating the effective date. This revision of date is only published via the current List of Approved Backflow Prevention Assemblies.


REGARDING INSTALLATION:
Unless otherwise specified by the manufacturer all assemblies are to be installed on cold potable water applications - below 1100F. Also, all of the assemblies listed are Approved for the INDICATED ORIENTATION(S) ONLY. Rotation of assemblies on either axis will invalidate the USC Foundation's Approval. Use of spare parts other than those of the original manufacturer invalidates the Approval. Rotation of shutoff valves of one bolt hole only is permitted only for the 2 1/2" and larger flanged assemblies.

REGARDING LEAD CONTENT:
In order to determine if backflow preventers comply with lead-free requirements of several states and the Safe Drinking Water Act, USC Foundation Approved assemblies which comply with the ≤ 0.25% lead requirement are indicated by a Y in the column ≤ 0.25%Pb.

REGARDING LIST UPDATES:
The List of Approved Assemblies is printed annually in the first quarter of the year. Update notices are printed and sent to USC Foundation Members quarterly. The most recent changes to the List may be found on the USC Foundation's website. The web version of the List is updated each time a change is made.

REGARDING SUSPENSIONS:
As part of an assembly's ongoing approval process, manufacturers are required to submit selected assemblies for review and re-evaluation. When a manufacturer fails to provide a required assembly, the assembly's approval is suspended. Once the assembly satisfactorily completes the renewal review and re-evaluation, the suspension will be removed.

Orientation of Assemblies



2026 © University of Southern California

Shutoff Valve Designation

Each backflow prevention assembly has been evaluated with a specific set of shutoff valves as an integral part of the assembly. The specific shutoff valves are coded by a parenthetic code with each assembly. This coding of shutoff valves is defined below. Other shutoff valves having similar performance characteristics which permit the assembly to comply with the standards are also shown immediately after the original shutoff valves. The use of any shutoff valve, other than those listed for that specific assembly invalidates the Approval. Assemblies listed with a Y in the "spare parts only" column may not include the shutoff valve designation.

(aa)	American Figure 1-QT
(bb)	American Figure 17-NRS RW
(cc)	American Figure 370OSY RW
(dd)	Apollo Series 7B-QT
(ee)	AVK Series 25-NRS
(ff)	AVK Series 25-OSY (Nibco F607RW OSY)
(gg)	Clow R/W Model 2640 (FxF) - NRS
	(formerly Clow R/W F6102-NRS)
(hh)	Clow R/W Model 2640 (FxF) - OSY
	(formerly Clow R/W F6136-OSY)
(ii)	Fortune Series 620/623 (C84400 Bronze) (Formerly Figure 601)
	Private labeled as: Ames, Buckner, Febco, Flomatic, Hersey and Wilkins
(jj)	Kennedy Ken Seal I-NRS
(kk)	Kennedy Ken Seal-OSY
(ll)	Kennedy Model KS-FW Figure 8561 (FxF) - NRS (2 1/2" - 12")
	Kennedy Model KS-RW Figure 7561 (FxF) - NRS (4" - 10")
	(formerly Kennedy Ken Seal II-NRS)
(mm)	Kennedy Model KS-FW Figure 8068 (FxF) - OSY (2 1/2" - 12")
	Kennedy Model KS-RW Figure 7068 (FxF) - OSY (4" - 10")
	(formerly Kennedy Ken Seal II-OSY)
(nn)	Lee Brass-QT
(oo)	Watts Model 405 (2-1/2" - 10" NRS-RW FxF)
(pp)	Watts Model 408 (2-1/2" - 10" OSY-RW FxF)
(qq)	Mueller R/W HP NRS
(rr)	Mueller R/W HP OSY
(ss)	Toro.Orion Integral Ball Valve-QT
(tt)	American Flow Control (Waterous) Series 500-NRS
(uu)	American Flow Control (Waterous) Series 500-OSY
(vv)	Watts Model FBV & FBV-E (1/4" - 2" Ball Valve QT)
	Ames Model FBV & FBV-E (1/4" - 2" Ball Valve QT)
(ww)	Watts Moel G4000-FDA (2-1/2" -10" Ball Valve FxF)
(xx)	Watts Model 6080 & 6080-E (1/4" - 2" Ball Valve QT)
(yy)	Matco-Norca 10RW (NRS)
(zz)	Matco-Norca 105U (OSY)
(aaa)	American Flow Control Series 2500-NRS
(bbb)	American Flow Control Series 2500-OSY
(ccc)	M&H Model 4067-02 (NRS)
(ddd)	M&H Model 4068-02(OSY)
(eee)	Stockham Model G-610 (OSY)

Shutoff Valve Designation

(fff)	Febco Series 620 QT
(ggg)	Fortune Figure 620U-QT
(hhh)	Watts Model S-FBV & S-FBV-E (1/4” - 1” Ball Valve QT)
(iii)	Mueller Model A2360-NRS
(int)	Shutoff Valve is integral part of assembly
(jjj)	Febco Series 621-QT
(kkk)	Febco Series 620U-QT
(lll)	Mueller Model R2360-OSY
(mmm)	Conbraco Series IBVE-125-QT
(nnn)	Kennedy Model KS-FW Figure 8701 (FxF) - NRS (3” - 10”) Post Indicator/Tapping
	Kennedy Model KS-RW Figure 7701 (FxF) - NRS (4” - 10”) Post Indicator/Tapping
	(formerly Kennedy Ken Seal II Post Indicator/Tapping)
(ooo)	Ningbo Ball Valves (Febco 622F & 622FT, Watts Series 855-QT & Wilkins Series 850-QT)(1/4” - 2” Ball Valve QT)
(ppp)	Clow R/W Model 2639 (GxF) - NRS (2 1/2” - 3”)
	Clow R/W Model 2638 (GxF) - NRS (4” - 10”)
	(formerly Clow Series F6105-NRS)
(qqq)	Clow R/W Model 2639 (GxF) - OSY (2 1/2” - 3”)
	Clow R/W Model 2638 (GxF) - OSY (4” - 10”)
	(formerly Clow Series F6138-OSY)
(rrr)	Apollo Series 7B-308-01 (& 7B-308-31)
(sss)	Clow R/W Model 2639 (GxG) - NRS (2 1/2” - 3”)
	Clow R/W Model 2638 (GxFG) - NRS (4” - 10”)
	(formerly Clow Series F6104-NRS)
(ttt)	Clow R/W Model 2639 (GxG) - OSY (2 1/2” - 3”)
	Clow R/W Model 2638 (GxFG) - OSY (4” - 10”)
	(formerly Clow Series F6137-OSY)
(uuu)	Apollo Series 7H-QT
(vvv)	Clow R/W Model 2640 (FxF) - OSY Post Indicator/Tapping Valve
	(formerly Clow R/W F6136-OSY Post Indicator/Tapping Valve)
(www)	Clow R/W Model 2639 (GxF) - OSY (2 1/2” - 3”) Post Indicator/Tapping Valve
	Clow R/W Model 2640 (GxF) - OSY (4” - 10”) Post Indicator/Tapping Valve
	(formerly Clow R/W F6138-OSY Post Indicator/Tapping Valve)
(xxx)	Ningbo Union Ball Valves (Febco 622UF & 622UFT & Wilkins 850U-QT)(1/2” - 2” Ball Valve QT)
(yyy)	Victaulic Series 702 (Butterfly valves)
(zzz)	Kennedy Model KS-RW Figure 7092ABF (FxG) - OSY
	(formerly Kennedy Series 7092ABF-OSY)
(aaaa)	Union Model GV12 (flange by groove)-OSY
(bbbb)	Enbee Model GV12 (flange by groove)-OSY
(cccc)	Kennedy Model KS-RW Figure 7092 (FxG) - OSY
	(formerly Kennedy Series 7092 (GxF) - OSY)
(dddd)	Kennedy Model KS-RW Figure 7592 (FxG) - NRS
	(formerly Kennedy Series 7592ABF - NRS)
(eeee)	Kennedy Model KS-RW Figure 7592PABF (FxG) - NRS Post Indicator/Tapping Valve
	(formerly Kennedy Series 7592PABF-Post Indicator/Tapping Valve)
(ffff)	Watts Model 409 (2-1/2” - 10” OSY-RW FxF)

2026 © University of Southern California

Shutoff Valve Designation

(gggg)	Watts Model 409 (2-1/2” - 10” OSY-RW FxG)
(hhhh)	Watts Model LF-FBV & LF-FBV-E (1/4” - 2” Ball Valve QT)
	Ames Model LF-FBV & LF-FBV-E (1/4” - 2” Ball Valve QT)
	Febco Model LF-FBV & LF-FBV-E (1/4” - 2” Ball Valve QT)
(iiii)	Wilkins Series 850XL (850TXL) - QT
(jjjj)	WATTS Model 409 (2” OSY-RW NPTxNPT)
(kkkk)	Kennedy Model KS-RW Figure 7093 (GxG) - OSY
(llll)	Kennedy Model KS-RW Figure 7593 (GxG) - NRS
(mmmm)	Kennedy Model KS-RW Figure 7093ABF (GxG) - OSY
(nnnn)	Kennedy Model KS-RW Figure 7593ABF (GxG) - NRS
(oooo)	Kennedy Model KS-RW Figure 7593PABF (GxG) - NRS Post Indicator
(pppp)	Watts Model L-FBV & L-FBV-E (1/4” - 2” Ball Valve QT)
	Ames Model L-FBV & L-FBV-E (1/4” - 2” Ball Valve QT)
	Febco Model L-FBV & L-FBV-E (1/4” - 2” Ball Valve QT)
(qqqq)	Kennedy Figure G300E - Butterfly Valve (2 1/2”-6”)
(rrrr)	Kennedy Figure 02G - Butterfly Valve (8”)
(ssss)	Wilkins Model 48-509 (GXF) - NRS (2-1/2” - 12”) [Effective 12/06/16. Formerly Model 48]
(tttt)	Wilkins Model 48-509 (FXF) - NRS (2-1/2” - 12”) [Effective 12/06/16. Formerly Model 48]
(uuuu)	Wilkins Model 48-509 (GXG) - NRS (2-1/2” - 10”) Post Indicator/Tapping Valve [Effective 12/06/16. Formerly Model 48]
(vvvv)	Wilkins Model 48-509 (GXF) - NRS (2-1/2” - 12”) Post Indicator/Tapping Valve [Effective 12/06/16. Formerly Model 48]
(wwww)	Wilkins Model 48-509 (FXF) - NRS (2-1/2” - 12”) Post Indicator/Tapping Valve [Effective 12/06/16. Formerly Model 48]
(xxxx)	Wilkins Model 48-509 (GXG) - OSY (2-1/2” - 10”) [Effective 12/06/16. Formerly Model 48]
(yyyy)	Wilkins Model 48-509 (GXF) - OSY (2-1/2” - 12”) [Effective 12/06/16. Formerly Model 48]
(zzzz)	Wilkins Model 48-509 (FXF) - OSY (2-1/2” - 12”) [Effective 12/06/16. Formerly Model 48]
(aaaaa)	Wilkins Model 48-509 (GXG) - NRS (2-1/2” - 10”) [Effective 12/06/16. Formerly Model 48]
(bbbbb)	Milwaukee BB-SC100 - Butterfly Valve
(ccccc)	Milwaukee BB-SCS02 - Butterfly Valve (with gearbox)
(ddddd)	Flomatic Model NRS
(eeeee)	Watts Model FBV-FP & FBV-E-FP (3/4” - 2” Ball Valve w/Gearbox)
	Ames Model LFAFBV-FP & LFAFBV-E-FP (3/4” - 2” Ball Valve w/Gearbox)
(fffff)	Watts Model L-FBV-QT (2-1/2” - 4” Ball Valve NPTxG)
(ggggg)	Wilkins Model 850MSS
(hhhhh)	Fortune Series 620/623 (c89520 unleaded bronze)
(iiiii)	Apollo Series 77B-100 and 77C-100 - QT
(jjjjj)	Apollo Series 77BLF-100 and 77CLF-100 - QT
(kkkkk)	Wilkins Model 49 (GXF) - (2 1/2” - 10”)
(lllll)	Wilkins Model 49 (GXG) - (2 1/2” - 10”)
(mmmmm)	Wilkins 850UXL (850TUXL) -QT
(nnnnn)	Watts Model 405 (2 1/2” - 10” NRS-RW FxG)
(ooooo)	ARI HC260 and HC262 Ball Valves - QT
(ppppp)	Febco Model LF622UF & LF622UFT (1/2” - 2” Ball Valve QT)
(qqqqq)	Febco Model LF622F & LF622FT (1/2” - 2” Ball Valve QT)

Shutoff Valve Designation

(rrrrr)	Watts Model LFFBV-FRG & LFFBV-E-FRG (1/2” - 2” Ball Valve QT)
(sssss)	Apollo Series 91B and 91C-QT (1/2 - 2”)
(ttttt)	Apollo Series 91BLF and 91CLF-QT (1/2 - 2”)
(uuuuu)	Apollo Model 77B-LFU and 77C-LFU Union Ball Valves - QT (1/2”)
(vvvvv)	Apollo Series 91BLF-U and 91CLF-U-QT (3/4”-2”)
(wwwww)	Apollo Series 91B-U and 91C-U-QT (3/4”-2”)
(xxxxx)	Apollo Model GV (FXG) - NRS (2-1/2” - 12”)
(yyyyy)	Apollo Model GV (GXG) - NRS (2-1/2” - 12”)
(zzzzz)	Apollo Model GV (FXG) - OSY (2-1/2” - 12”)
(aaaaaa)	Apollo Model GV (GXG) - OSY (2-1/2” - 12”)
(bbbbbb)	Apollo Model GV (FXF) - NRS (2-1/2” - 12”)
(cccccc)	Apollo Model GV (FXF) - OSY (2-1/2” - 12”)
(dddddd)	Apollo Model 77S-XT (1 1/2”-2” Ball Valve w/Gearbox)
(eeeeee)	Apollo Model 77S-LFXT (1 1/2”-2” Ball Valve w/Gearbox)
(ffffff)	ARI Model PLS-VA Ball Valves -QT (3/4”-2”)
(ggggggg)	Wilkins Model 48 (GXF) - NRS (2-1/2” - 12”)
(hhhhhh)	Wilkins Model 48 (FXF) - NRS (2-1/2” - 12”)
(iiiiii)	Wilkins Model 48 (GXG) - NRS (2-1/2” - 10”) Post Indicator/Tapping Valve
(jjjjjj)	Wilkins Model 48 (GXF) - NRS (2-1/2” - 12”) Post Indicator/Tapping Valve
(kkkkkk)	Wilkins Model 48 (FXF) - NRS (2-1/2” - 12”) Post Indicator/Tapping Valve
(llllll)	Wilkins Model 48 (GXG) - OSY (2-1/2” - 10”)
(mmmmmm)	Wilkins Model 48 (GXF) - OSY (2-1/2” - 12”)
(nnnnnn)	Wilkins Model 48 (FXF) - OSY (2-1/2” - 12”)
(oooooo)	Wilkins Model 48 (GXG) - NRS (2-1/2” - 10”)
(pppppp)	Lansdale Model LPBLFB2 - Butterfly Valve (2”)
(qqqqqq)	AVK Series 25-21 (GXF) - NRS
(rrrrrr)	AVK Series 25-11 (GXG) - NRS
(ssssss)	AVK Series 25-26 (GXF) -OSY
(tttttt)	AVK Series 25-16 (GxG) - OSY
(uuuuuu)	Ames Model LFAFBV-FP-GV-T & LFAFBV-E-FP-GV-T (1” - 2” Thread x Groove Ball Valve w/Gearbox)
(vvvvvv)	BEECO Mod GV (GXF) - NRS (2 1/2”- 10”)
(wwwwww)	BEECO Mod GV (GXF) - OSY (2 1/2”- 10”)
(xxxxxx)	Apollo Mod BFV (GXG) - (2 1/2”-10”) - Butterfly Valves
(yyyyyy)	BEECO Mod BV Series (1/2”-2” Ball Valve QT)
(zzzzzz)	AVK Series 25-41 (FXF) - NRS
(aaaaaaa)	AVK Series 25-46 (FXF) - OSY
(bbbbbbb)	Controls Model 11BVLF and 11BVTLF Ball Valves (3/4”)
(ccccccc)	Controls Model 11BVULF and 11BVUTLF Ball Valves (3/4”)

2026 © University of Southern California

Detector Assembly Meters

The Detector Assemblies contained herein have been evaluated with a specific meter as the detector element of the assembly. That specific meter is coded by a parenthetic letter shown in the “meters” column. The coding of meters is shown in this Section. Other meters having similar performance characteristics to permit the assembly to meet the Standard are shown immediately after the original evaluation meter. The use of any other meter or modified bypass piping invalidates the Approval.

Some of the detector assemblies use a line-size assembly, which is not a standard stock Approved assembly. Increased loads are required in these line-size units to allow the assembly to accurately record low flow rates in the bypass meter. Therefore, various off-the-shelf components can not be assembled and expected to perform satisfactorily. The bypass backflow preventer Approved with the detector assembly is listed under the bypass column. This is only for verification purposes. Should replacement parts or a complete bypass be needed, the model number of the complete detector assembly should be used in ordering these components.

A	Hersey Model F-F 5/8” x 3/4”
B	Carlon 5/8” x 3/4”
C	Dandé Model D-3 5/8” x 3/4”
D	Gamon-Calmet 5/8”
E	Hays Acumeter 5/8” x 3/4”
F	Arad 5/8” x 3/4” (Master Meter)
G	Schlumberger 5/8” x 3/4” Model MBRF
H	Rockwell (Sensus) SR-II 5/8” x 3/4”
I	Hersey Model 430 - 5/8”
J	Elster AMCO Model C700 5/8”x3/4” (Formerly Kent, ABB)
K	Precision 5/8”
L	Neptune Trident 8 5/8”
M	Neptune T-10 5/8” (Lead free compliant version identified with NSF61 mark on meter)
N	Badger Model 25 3/4”
O	Badger 5/8” x 3/4” Model 25 (Lead free compliant version identified with NSF61 mark on meter)
P	Hersey Model 430 Series II 5/8”
Q	Hersey Model MVR-30 3/4”
R	Neptune T-10 1”
S	Neptune T-10 1 1/2”
T	Zenner Model PMN 5/8” x 3/4”
U	Badger Model 35 3/4” (Lead free compliant version identified with NSF61 mark on meter)

Special Notices

The USC Foundation publishes Special Notices from time to time. These notices contain information that requires special attention. The Foundation makes Special Notices, in their first year of publication, an exclusive benefit for Foundation members. Members receive all Special Notices via mail immediately upon release. Please visit fccchr.usc.edu/list to view the Special Notices archive.

Notice 96-001
This notice lists Ames assemblies which have been reported with low check valve readings. Corrections to the problem are discussed.

Notice 97-001
This notice discusses changes in the retaining cup in the relief valve stem of the 8" and 10" Wilkins 975 reduced pressure principle assemblies.

Notice 97-002
This notice identifies Ames 2000SS, 3000SS, and 4000SS series assemblies that were discovered to have unapproved components.

Notice 97-003
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 98-001
This notice advises members of certain action in the Federal Register regarding cross-connection control programs.

Notice 98-002
This notice advises members of Wilkins 950 series and 975 series modifications.

Notice 99-001
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 99-002
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 99-003
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 01-001
This notice discuss silicon parts in certain Febco relief valves.

Notice 01-002/Revised Notice 01-002-R1
This notice discusses some check valves not approved in certain Ames and Watts assemblies.

Notice 01-003
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 02-001
This notice explains there are some specific Febco assemblies with unapproved check valve retainers.

Notice 03-001
This notice explains there are improper markings of model designations on some Wilkins assemblies.

Notice 03-002
This notice explains the possibility of the interference of the check valves on some Ames and Watts assemblies.

Notice 04-001
This notice identifies some Febco 825YA assemblies sold with a dimensional variation.

Notice 05-001
This notice identifies some Ames and Watts assemblies sold with unapproved disc material.

Notice 06-001
This notice identifies unapproved guides found in certain Febco assemblies.

Notice 06-002
This notice identifies a change in the design of the Flomatic PVBs.

Notice 06-003
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 07-001
This notice discusses out of tolerance springs on Conbraco assemblies.

Notice 09-001
This notice highlights unapproved third party components that are being distributed.

Notice 13-001
This notice discusses modifications to guiding surfaces of the check valves on Wilkins assemblies.

Notice 14-001
This notice lists assemblies which were NOT Approved by the Foundation, although advertisements may have implied otherwise.

Notice 14-002
This notice clarifies the method in which the model designation is indicated on the Wilkins 3/4" 950XLD and 975XLD assemblies.

Notice 15-001
This notice has been prepared to review Special Notice 14-002 and clarify the USC Approval Status of Wilkins Reduced Pressure Principle Detector Assemblies (RPDAs).

Notice 19-001
This notice brings to attention that certain Ames and Watts double check detector assemblies (DCDA) may have been produced with the bypass assembly containing the incorrect model designation.

2026 © University of Southern California

Type: AVB
Size: 3/4
Manual: 8
Approved: 01-Nov-1991
Manufacturer: Ames
Orientation: VUH
0.25% Pb: No
Renewed: 01-Nov-2024
Model: A100
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 1
Manual: 8
Approved: 01-Nov-1991
Manufacturer: Ames
Orientation: VUH
0.25% Pb: No
Renewed: 01-Nov-2024
Model: A100
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1991
Manufacturer: Ames
Orientation: VUH
0.25% Pb: No
Renewed: 27-Sep-2024
Model: A100
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 2
Manual: 8
Approved: 21-Aug-1991
Manufacturer: Ames
Orientation: VUH
0.25% Pb: No
Renewed: 21-Aug-2024
Model: A100
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 1 1/4
Manual: 8
Approved: 12-Aug-1991
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 12-Aug-2024
Model: 288AM3
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1991
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 27-Sep-2024
Model: 288AM3
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 2
Manual: 8
Approved: 21-Aug-1991
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 21-Aug-2024
Model: 288AM3
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Size: 2 1/2
Manual: 8
Approved: 10-Sep-1991
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 10-Sep-2024
Model: 288AM3
Meters:
Spare Parts Only: Yes
Bypass:

Type: AVB
Manufacturer: Watts
Model: 288AM3
Size: 3
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1991
Renewed: 16-Sep-2024
Bypass:

Type: AVB
Manufacturer: Watts
Model: 288AM5
Size: 3/4
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Nov-1991
Renewed: 01-Nov-2024
Bypass:

Type: AVB
Manufacturer: Watts
Model: 288AM5
Size: 1
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Nov-1991
Renewed: 01-Nov-2024
Bypass:

Type: DC
Manufacturer: Ames
Model: 2000-DC
Size: 10
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1987
Renewed: 04-Aug-2026
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DC

Type: DC
Manufacturer: Ames
Model: 2000-DCA
Size: 4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DCA

Type: DC
Manufacturer: Ames
Model: 2000-DCA
Size: 6
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DCA

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: 2000-DCA
Size: 8
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DCA

Type: DC
Manufacturer: Ames
Model: 2000-G-DC
Size: 10
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1987
Renewed: 04-Aug-2026
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DC

Type: DC
Manufacturer: Ames
Model: 2000-G-DCA
Size: 4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DCA

Type: DC
Manufacturer: Ames
Model: 2000-G-DCA
Size: 6
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DCA

Type: DC
Manufacturer: Ames
Model: 2000-G-DCA
Size: 8
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model DCA

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Dec-1983
Renewed: 06-Dec-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Upgraded to 9th Ed.

Type: DC
Size: 1/2
Manual: 9
Approved: 16-Jun-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previous 8th Ed. Approval

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 16-Jun-2024

Model: 2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 16-Jun-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 16-Jun-2024

Model: 2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 05-Apr-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 05-Apr-2026

Model: 2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 27-Aug-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 27-Aug-2026

Model: 2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 26-Feb-1991
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Upgraded to 9th Ed.

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 26-Feb-2024

Model: 2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previous 8th Ed. Approval

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 18-May-2025

Model: 2000B
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-May-1998
Renewed: 18-May-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Oct-1996
Renewed: 01-Oct-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 1 1/4
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Oct-1996
Renewed: 01-Oct-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1994
Renewed: 24-May-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 1 1/2
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Mar-1996
Renewed: 11-Mar-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Jun-1992
Renewed: 30-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B
Size: 2
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000B-FP
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: DC
Manufacturer: Ames
Model: 2000B-FP
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: Model Designation changed to 2000BM1-FP

Type: DC
Manufacturer: Ames
Model: 2000B-FP
Size: 1 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: Model Designation changed to 2000BM2-FP

Type: DC
Manufacturer: Ames
Model: 2000B-FP
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: Model Designation changed to 2000BM2-FP

Type: DC
Manufacturer: Ames
Model: 2000B-FP
Size: 2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: Model Designation changed to 2000BM1-FP

Type: DC
Manufacturer: Ames
Model: 2000BM1-FP
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Model 2000B-FP. Model Change effective beginning with serial #: 028561

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: 2000BM1-FP
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Aug-2017
Renewed: 21-Aug-2026
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: DC
Manufacturer: Ames
Model: 2000BM1-FP
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Model 2000B-FP. Model Change effective beginning with serial #: 039123

Type: DC
Manufacturer: Ames
Model: 2000BM1-FP
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Aug-2017
Renewed: 21-Aug-2026
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: DC
Manufacturer: Ames
Model: 2000BM2-FP
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Model 2000B-FP. Model Change effective beginning with serial #: 017727

Type: DC
Manufacturer: Ames
Model: 2000BM2-FP
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Aug-2017
Renewed: 21-Aug-2026
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: DC
Manufacturer: Ames
Model: 2000BM2-FP
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Model 2000B-FP. Model Change effective beginning with serial #: 034639

Type: DC
Manufacturer: Ames
Model: 2000BM2-FP
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Aug-2017
Renewed: 21-Aug-2026
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: DC
Manufacturer: Ames
Model: 2000BM3
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000BM3
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 2000BM3-FP
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 15-Jan-1982
Renewed: 15-Jan-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 4
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-1996
Renewed: 11-Mar-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 6
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-May-1982
Renewed: 18-May-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 6
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 8
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jul-1981
Renewed: 06-Jul-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 8
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 10
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Mar-1983
Renewed: 16-Mar-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000CIV
Size: 10
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: DC
Manufacturer: Ames
Model: 2000SE
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass:
Shutoffs: (mm),ee,ff,gg,hh,ll,mm,oo,pp,tt,uu,ccc,ddd,ffff,gggg

---

Type: DC
Manufacturer: Ames
Model: 2000SE
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Nov-1993
Renewed: 22-Nov-2023
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg

Type: DC
Manufacturer: Ames
Model: 2000SE
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jul-1995
Renewed: 14-Jul-2025
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Oct-1995
Renewed: 13-Oct-2025
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Oct-1995
Renewed: 13-Oct-2025
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Sep-1996
Renewed: 16-Sep-2026
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Sep-1996
Renewed: 16-Sep-2026
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Feb-2001
Renewed: 16-Feb-2025
Bypass:
Shutoffs: pp,

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Feb-2001
Renewed: 16-Feb-2025
Bypass:
Shutoffs: (ll),mm,oo,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 12
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: pp,

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 12
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 12
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: pp,

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: 2000SS
Size: 12
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (ll),mm,oo

Type: DC
Manufacturer: Ames
Model: 2000SS-M
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Ames
Model: 2000SS-M
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Ames
Model: 200B
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 200B
Size: 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 200B
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: 200B
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Size: 3/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B-A
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: 200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jul-2025

Model: 200B-AR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jul-2025

Model: 200B-AR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2 1/2
Manual: 9
Approved: 20-Jul-2004
Shutoffs: (ppp),qqq,nnnnn

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 20-Jul-2025

Model: Colt 200
Meters:
Spare Parts Only: No
Bypass:

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Jul-2004 **Renewed:** 20-Jul-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Colt 200
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 21-Apr-2006 **Renewed:** 21-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 11-Aug-2004 **Renewed:** 11-Aug-2025 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 11-Aug-2004 **Renewed:** 11-Aug-2025 **Bypass:**
Shutoffs: (yyy),zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 10-Feb-2006 **Renewed:** 10-Feb-2024 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 10-Feb-2006 **Renewed:** 10-Feb-2024 **Bypass:**
Shutoffs: (yyy),zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,ggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

2026 © University of Southern California

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 10 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC **Manufacturer:** Ames **Model:** Colt 200
Size: 10 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Dec-2014 **Renewed:** 05-Dec-2023 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,ggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),fff,qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200a
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Colt 200N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Jan-2013
Renewed: 03-Jan-2025
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Jan-2013
Renewed: 03-Jan-2025
Bypass:
Shutoffs: yyy, zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Colt 200N
Size: 10
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (ppp),qqq

Type: DC **Manufacturer:** Ames **Model:** Colt 200N
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 01-Sep-2009 **Renewed:** 01-Sep-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200Na
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200Na
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200Na
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** Colt 200Na
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Ames **Model:** DC
Size: 4 **Orientation:** H **Meters:**
Manual: 6 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 14-Jun-1985 **Renewed:** 14-Jun-2024 **Bypass:**
Shutoffs: oo,pp,ffff,gggg

Type: DC **Manufacturer:** Ames **Model:** DC
Size: 6 **Orientation:** H **Meters:**
Manual: 6 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 14-Jun-1985 **Renewed:** 14-Jun-2024 **Bypass:**
Shutoffs: oo,pp,ffff,gggg

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: DC
Size: 8
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1987
Renewed: 04-Aug-2026
Bypass:
Shutoffs: oo,pp,ffff,gggg

Type: DC
Manufacturer: Ames
Model: DC
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-DC

Type: DC
Manufacturer: Ames
Model: DC
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-G-DC

Type: DC
Manufacturer: Ames
Model: DCA
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-DCA

Type: DC
Manufacturer: Ames
Model: DCA
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-G-DCA

Type: DC
Manufacturer: Ames
Model: DCA
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-DCA

Type: DC
Manufacturer: Ames
Model: DCA
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-G-DCA

Type: DC
Manufacturer: Ames
Model: DCA
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-DCA

Type: DC
Manufacturer: Ames
Model: DCA
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 2000-G-DCA

Type: DC
Manufacturer: Ames
Model: Deringer 20
Size: 2 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Ames
Model: Deringer 20
Size: 2 1/2
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Ames
Model: Deringer 20
Size: 3
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Ames
Model: Deringer 20
Size: 3
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Ames
Model: Deringer 20
Size: 4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (int)

2026 © University of Southern California

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF2000B
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF2000BM1
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF2000BM1
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF2000BM1
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 2
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Sep-2025

Model: LF2000BM1
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM1-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM1-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM1-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM1-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 25-Sep-2013
Shutoffs: (hhhh)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025

Model: LF2000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 25-Sep-2013
Shutoffs: (hhhh)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Sep-2025

Model: LF2000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 25-Sep-2013
Shutoffs: (hhhh)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025

Model: LF2000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 25-Sep-2013
Shutoffs: (hhhh)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Sep-2025

Model: LF2000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: LF2000BM2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025

Model: LF2000BM3
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 3/4
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF2000BM3
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 03-Jul-2025
Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VD
0.25% Pb: Yes
Renewed: 03-Jul-2025
Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 03-Jul-2025
Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 03-Jul-2025
Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VD
0.25% Pb: Yes
Renewed: 03-Jul-2025
Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 03-Jul-2025
Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: LF200B
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: LF200B
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: LF200B
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: LF200B
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: LF200B
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: LF200B R10
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Manufacturer: Ames
Model: LF200B R10
Size: 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: DC
Size: 1/2
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B R10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B-A
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 2
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF200B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LFU200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LFU200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LFU200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LFU200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LFU200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LFU200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Manufacturer: Ames
Model: LFU200B
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: LFU200B
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: LFU200B
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: LFU200B
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: LFU200B
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: LFU200B
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: (ppp),qqq,nnnnn

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: yyy,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: yyy,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: yyy,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jul-2004
Renewed: 20-Jul-2025
Bypass:
Shutoffs: yyy,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Aug-2004
Renewed: 11-Aug-2025
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Aug-2004
Renewed: 11-Aug-2025
Bypass:
Shutoffs: (yyy),zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Feb-2006
Renewed: 10-Feb-2024
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

2026 © University of Southern California

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 10-Feb-2006 **Renewed:** 10-Feb-2024 **Bypass:**
Shutoffs: (yyy),zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: (yyy),zzz,dddd,eeee,gggg,ssssss,qqqqqq

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: (yyy),zzz,dddd,eeee,gggg,ssssss,qqqqqq

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Oct-2008 **Renewed:** 20-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC **Manufacturer:** Ames **Model:** Maxim 200
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Oct-2008 **Renewed:** 20-Oct-2023 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,ssssss,qqqqqq

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Oct-2008
Renewed: 20-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Ames
Model: Maxim 200
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2008
Renewed: 20-Oct-2023
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,ssssss,qqqqqq

Type: DC
Manufacturer: Ames
Model: Maxim 200a
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200a
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200a
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200a
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC
Manufacturer: Ames
Model: Maxim 200a
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 03-Jul-2003
Renewed: 03-Jul-2024
Bypass:
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

2026 © University of Southern California

Type: DC **Manufacturer:** Ames **Model:** Maxim 200a
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jan-2013 **Renewed:** 03-Jan-2025 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 03-Jan-2013 **Renewed:** 03-Jan-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 01-Sep-2009 **Renewed:** 01-Sep-2024 **Bypass:**
Shutoffs: (ppp),qqq,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200N
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 01-Sep-2009 **Renewed:** 01-Sep-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: DC **Manufacturer:** Ames **Model:** Maxim 200Na
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200Na
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

Type: DC **Manufacturer:** Ames **Model:** Maxim 200Na
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,nnnnn

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200B
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200BR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 21-Apr-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 21-Apr-2024

Model: U200BR10
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Ames
Model: U200BR10
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: U200BR10
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: U200BR10
Size: 3/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Ames
Model: U200BR10
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Apollo/Conbraco
Model: 1/2DC
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC4S

Type: DC
Manufacturer: Apollo/Conbraco
Model: 1/2DC
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC4S

Type: DC
Manufacturer: Apollo/Conbraco
Model: 10DC
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC4S

Type: DC
Manufacturer: Apollo/Conbraco
Model: 10DC
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC4S

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DC
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DC
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DC-7
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DC-7
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DC8
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DC8
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCU
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCU
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DC
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DC
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DC7
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DC7
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DC8
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DC8
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DCU
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 3DCU
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-100-02
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: tt,bb,ee,ll

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-100-03
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: uu,cc,mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-100-05
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Dec-1998
Renewed: 08-Dec-2025
Bypass:
Shutoffs: mmm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-103-02
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-May-1995
Renewed: 01-May-2025
Bypass:
Shutoffs: dd

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-104-02
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Mar-1989
Renewed: 17-Mar-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-104-99T
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-104-A2
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jun-1993
Renewed: 21-Jun-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-104-A2T
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 25-Mar-1992
Renewed: 25-Mar-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-104-T2
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-104-TC2
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-105-02
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Mar-1989
Renewed: 17-Mar-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-105-99T
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-105-A2
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jun-1993
Renewed: 21-Jun-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-105-A2T
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 25-Mar-1992
Renewed: 25-Mar-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-105-T2
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-105-TC2
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-106-02
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Apr-1992
Renewed: 06-Apr-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-106-99T
Size: 1 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-106-A2
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jun-1993
Renewed: 21-Jun-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-106-A2T
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-1993
Renewed: 22-May-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-106-T2
Size: 1 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-107-02
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Mar-1989
Renewed: 17-Mar-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-107-99T
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-107-A2
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-1993
Renewed: 22-May-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-107-A2T
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-1993
Renewed: 22-May-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-107-T2
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-108-02
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Mar-1989
Renewed: 17-Mar-2025
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-108-99T
Size: 2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-108-A2
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-1993
Renewed: 22-May-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-108-A2T
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-1993
Renewed: 22-May-2026
Bypass:
Shutoffs: dd

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-108-T2
Size: 2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC40

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-109-02
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: tt,bb,ee,ll

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-109-03
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: uu,cc,mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-109-05
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Dec-1998
Renewed: 08-Dec-2025
Bypass:
Shutoffs: mmm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-10A-02
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: tt,bb,ee,ll

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-10A-03
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: uu,cc,mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-10A-05
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Dec-1998
Renewed: 08-Dec-2025
Bypass:
Shutoffs: mmm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-10A-06
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass:
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 40-10C-02
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: tt,bb,ee,ll

Type: DC
Size: 6
Manual: 8
Approved: 08-Apr-1991
Shutoffs: uu,cc,mm

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 08-Apr-2024

Model: 40-10C-03
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 6
Manual: 8
Approved: 08-Dec-1998
Shutoffs: mmm

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 08-Dec-2025

Model: 40-10C-05
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 6
Manual: 8
Approved: 01-Feb-2000
Shutoffs: mm[#1SOV], nnn[#2SOV]

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 01-Feb-2024

Model: 40-10C-06
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 8
Manual: 8
Approved: 22-Oct-1991
Shutoffs: tt,bb,ee,ll

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 22-Oct-2024

Model: 40-10E-02
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 8
Manual: 8
Approved: 22-Oct-1991
Shutoffs: uu,cc,mm

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 22-Oct-2024

Model: 40-10E-03
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 8
Manual: 8
Approved: 01-Feb-2000
Shutoffs: mm[#1SOV], nnn[#2SOV]

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 01-Feb-2024

Model: 40-10E-06
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 10
Manual: 8
Approved: 13-Apr-1993
Shutoffs: tt,bb,ee,ll

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 13-Apr-2026

Model: 40-10G-02
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 10
Manual: 8
Approved: 13-Apr-1993
Shutoffs: uu,cc,mm

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 13-Apr-2026

Model: 40-10G-03
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 10
Manual: 8
Approved: 01-Feb-2000
Shutoffs: mm[#1SOV], nnn[#2SOV]

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 01-Feb-2024

Model: 40-10G-06
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2 1/2
Manual: 9
Approved: 11-Mar-2012
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2 1/2
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2 1/2
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100U
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100U
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 11-Mar-2009
Shutoffs: (yyy), cccc, dddd

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 11-Mar-2024

Model: 4D-100U
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (ll),mm

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 16-Oct-2024

Model: 4DC
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (ll),mm

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 16-Oct-2024

Model: 4DC
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 23-Oct-2001
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 23-Oct-2025

Model: 4DC7
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4DC7
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4DC8
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4DC8
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4DCU
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4S103
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to W432100

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4S103
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to W432100

Type: DC
Manufacturer: Apollo/Conbraco
Model: 4SG-100
Size: 2 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

Type: DC | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-100
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DC4SG

2026 © University of Southern California

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100
Size: 8 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SG

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100
Size: 8 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SG

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100U
Size: 2 1/2 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SGN

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100U
Size: 3 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SGN

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100U
Size: 4 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SGN

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100U
Size: 6 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SGN

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** 4SG-100U
Size: 8 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to DC4SGN

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DC
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DC
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DC7
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DC7
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Oct-2001
Renewed: 23-Oct-2025
Bypass:
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DC8
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DC8
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 6DCU
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass:
Shutoffs: (ll),mm

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: 8DC
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass:
Shutoffs: (mm),ll

Type: DC
Manufacturer: Apollo/Conbraco
Model: 8DC
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass:
Shutoffs: (mm),ll

Type: DC
Manufacturer: Apollo/Conbraco
Model: 8DC8
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: 8DC8
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC40
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Jun-1996
Renewed: 27-Jun-2026
Bypass:
Shutoffs: (dd)
Notes: formerly 40-104-99T, 40-104-T2, 40-104-TC2

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC40
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Jun-1996
Renewed: 27-Jun-2026
Bypass:
Shutoffs: (dd)
Notes: formerly 40-105-99T, 40-105-T2, 40-105-TC2

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC40
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1996
Renewed: 09-Oct-2023
Bypass:
Shutoffs: (dd)
Notes: formerly 40-106-99T, 40-106-T2

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC40
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1996
Renewed: 09-Oct-2023
Bypass:
Shutoffs: (dd)
Notes: formerly 40-107-99T, 40-107-T2

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC40
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1996
Renewed: 09-Oct-2023
Bypass:
Shutoffs: (dd)
Notes: formerly 40-108-99T, 40-108-T2

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Apr-2011
Renewed: 27-Apr-2026
Bypass:
Shutoffs: (iiiii),sssss

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Apr-2011
Renewed: 27-Apr-2026
Bypass:
Shutoffs: (iiiii),sssss

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Apr-2011
Renewed: 27-Apr-2026
Bypass:
Shutoffs: (iiiii),sssss

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Apr-2011
Renewed: 06-Apr-2026
Bypass:
Shutoffs: (iiiii),sssss

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Sep-2011
Renewed: 27-Sep-2026
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Apr-2011
Renewed: 06-Apr-2026
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Feb-2012
Renewed: 07-Feb-2024
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Feb-2012
Renewed: 07-Feb-2024
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Feb-2012
Renewed: 07-Feb-2024
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Feb-2012
Renewed: 07-Feb-2024
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Feb-2012
Renewed: 07-Feb-2024
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4A
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Mar-2012
Renewed: 27-Mar-2024
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4AY
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2019
Renewed: 16-Jan-2025
Bypass:
Shutoffs: (sssss)
Notes: body axis oriented with test cocks pointing up and nameplate on the top surface

---

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4AY
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Oct-2018
Renewed: 24-Oct-2024
Bypass:
Shutoffs: (sssss)

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4AY
Size: 1
Orientation: H
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2019
Renewed: 16-Jan-2025
Bypass:
Shutoffs: (sssss)
Notes: body axis oriented with test cocks pointing up and nameplate on the top surface

---

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4AY
Size: 1
Orientation: VU
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Oct-2018
Renewed: 24-Oct-2024
Bypass:
Shutoffs: (sssss)

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4S
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Sep-2000
Renewed: 18-Sep-2024
Bypass:
Shutoffs: (dd)
Notes: formerly 1/2DC

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4S
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Sep-2000
Renewed: 18-Sep-2024
Bypass:
Shutoffs: (dd)
Notes: formerly 1/2DC

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4S
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass:
Shutoffs: (mm),ll, xxxxx, zzzzz, bbbbbb, cccccc
Notes: formerly 10DC

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4S
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass:
Shutoffs: (mm),ll, xxxxx, zzzzz, bbbbbb, cccccc
Notes: formerly 10DC

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SG
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SG
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Type: DC
Size: 3
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SG
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SG
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SG
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SG
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SG
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt, xxxxxx
Notes: formerly 4SG-100

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SG
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SG
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Sep-2007
Renewed: 25-Sep-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx
Notes: formerly 4SG-100

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SG
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Sep-2007
Renewed: 25-Sep-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx
Notes: formerly 4SG-100

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SGN
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG-100U

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SGN
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG-100U

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SGN
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG-100U

Type: DC
Manufacturer: Apollo/Conbraco
Model: DC4SGN
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 25-Sep-2007
Renewed: 25-Sep-2025
Bypass:
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG-100U

Type: DC
Size: 8
Manual: 9
Approved: 25-Sep-2007
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG-100U

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 25-Sep-2025

Model: DC4SGN
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 10
Approved: 27-Apr-2011
Shutoffs: (jjjjj),ttttt, uuuuu

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 27-Apr-2026

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 10
Approved: 27-Apr-2011
Shutoffs: (jjjjj),ttttt, uuuuu

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: Yes
Renewed: 27-Apr-2026

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 27-Apr-2011
Shutoffs: (jjjjj),ttttt

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 27-Apr-2026

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 06-Apr-2011
Shutoffs: (jjjjj),ttttt

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Apr-2026

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 27-Sep-2011
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 27-Sep-2026

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 06-Apr-2011
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Apr-2026

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 07-Feb-2012
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 07-Feb-2024

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 07-Feb-2012
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Feb-2024

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 07-Feb-2012
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 07-Feb-2024

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 07-Feb-2012
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Feb-2024

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 07-Feb-2012
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 07-Feb-2024

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 27-Mar-2012
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: Yes
Renewed: 27-Mar-2024

Model: DCLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2013 **Renewed:** 05-Nov-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2013 **Renewed:** 05-Nov-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2013 **Renewed:** 05-Nov-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 3 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2013 **Renewed:** 05-Nov-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 4 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

2026 © University of Southern California

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 6 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2014 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 8 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2014 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (zzzzz), yyy,zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4A
Size: 12 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 10-Jun-2014 **Renewed:** 10-Jun-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 08-Apr-2014 **Renewed:** 08-Apr-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-Nov-2013 **Renewed:** 22-Nov-2025 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-Apr-2014 **Renewed:** 15-Apr-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (zzzzz), yyy,zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AN
Size: 12 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 09-Nov-2015 **Renewed:** 09-Nov-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

2026 © University of Southern California

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 09-Nov-2015 **Renewed:** 09-Nov-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 09-Nov-2015 **Renewed:** 09-Nov-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 3 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 09-Nov-2015 **Renewed:** 09-Nov-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 21-Sep-2015 **Renewed:** 21-Sep-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 4 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 21-Sep-2015 **Renewed:** 21-Sep-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 21-Sep-2015 **Renewed:** 21-Sep-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 6 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 21-Sep-2015 **Renewed:** 21-Sep-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 21-Dec-2015 **Renewed:** 21-Dec-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 8 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 21-Dec-2015 **Renewed:** 21-Dec-2024 **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4AR
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** Yes
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 65 3/4" and max. 100 5/8"

2026 © University of Southern California

Type: DC
Manufacturer: Apollo/Conbraco
Model: DCLF4AY
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Jan-2019
Renewed: 16-Jan-2025
Bypass:
Shutoffs: (ttttt)
Notes: body axis oriented with test cocks pointing up and nameplate on the top surface

---

Type: DC
Manufacturer: Apollo/Conbraco
Model: DCLF4AY
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 24-Oct-2018
Renewed: 24-Oct-2024
Bypass:
Shutoffs: (ttttt)

Type: DC
Manufacturer: Apollo/Conbraco
Model: DCLF4AY
Size: 1
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Jan-2019
Renewed: 16-Jan-2025
Bypass:
Shutoffs: (ttttt)
Notes: body axis oriented with test cocks pointing up and nameplate on the top surface

---

Type: DC
Manufacturer: Apollo/Conbraco
Model: DCLF4AY
Size: 1
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 24-Oct-2018
Renewed: 24-Oct-2024
Bypass:
Shutoffs: (ttttt)

Type: DC
Manufacturer: Apollo/Conbraco
Model: DCLF4SG
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 23-Jan-2015
Renewed: 23-Jan-2024
Bypass:
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC
Manufacturer: Apollo/Conbraco
Model: DCLF4SG
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 23-Jan-2015
Renewed: 23-Jan-2024
Bypass:
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4SG
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2015 **Renewed:** 23-Jan-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4SG
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2015 **Renewed:** 23-Jan-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4SG
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2015 **Renewed:** 23-Jan-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4SG
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2015 **Renewed:** 23-Jan-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4SG
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2015 **Renewed:** 23-Jan-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DC **Manufacturer:** Apollo/Conbraco **Model:** DCLF4SG
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2015 **Renewed:** 23-Jan-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

2026 © University of Southern California

Type: DC
Size: 1/2
Manual: 9
Approved: 18-Oct-2007
Shutoffs: (dd)
Notes: formerly 4S103

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 18-Oct-2025

Model: W432100
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 18-Oct-2007
Shutoffs: (dd)
Notes: formerly 4S103

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 18-Oct-2025

Model: W432100
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (ooooo), ii, ooo,ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: No
Renewed: 03-Jan-2025

Model: DC 500
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 18-Feb-2014
Shutoffs: (ooooo),ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2026

Model: DC 500
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (ii),ooo, ooooo, ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: No
Renewed: 02-Mar-2025

Model: DC 500
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 18-Feb-2014
Shutoffs: (ooooo), ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2026

Model: DC 500
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: ARI
Model: DC 500
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Mar-2007
Renewed: 02-Mar-2025
Bypass:
Shutoffs: (ii),ooo, ooooo, ffffff

Type: DC
Manufacturer: ARI
Model: DC 500
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: DC
Manufacturer: ARI
Model: DC 500
Size: 1 1/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: DC
Manufacturer: ARI
Model: DC 500
Size: 1 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: DC
Manufacturer: ARI
Model: DC 500
Size: 2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: DC
Manufacturer: ARI
Model: DC 501
Size: 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2018
Renewed: 06-Sep-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: ARI
Model: DC 501
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2017
Renewed: 20-Mar-2026
Bypass:
Shutoffs: (int)

2026 © University of Southern California

Type: DC
Size: 1
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024

Model: DC 501
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: DC 501
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: DC 501
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: DC 501
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 21-Dec-2024

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 21-Dec-2024

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 21-Dec-2024

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 21-Dec-2024

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 30-Sep-2015
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 30-Sep-2024

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 30-Sep-2015
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 30-Sep-2024

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 30-Oct-2025

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 30-Oct-2025

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 23-Dec-2025

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 23-Dec-2025

Model: Deringer 20
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 2 1/2
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 16-Jan-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 16-Jan-2026

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Deringer 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 16-Jan-2026

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 16-Jan-2026

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Deringer 20GX
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 4
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 30-Oct-2025
Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 30-Oct-2025
Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 23-Dec-2025
Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 23-Dec-2025
Model: Deringer 20X
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 3
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 3
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 16-Jan-2026

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 16-Jan-2026

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Backflow Direct
Model: Magnum 20G
Size: 8
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2018
Renewed: 31-Jul-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr

Type: DC
Manufacturer: Backflow Direct
Model: Magnum 20GX
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2018
Renewed: 31-Jul-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr

Type: DC
Manufacturer: Backflow Direct
Model: Magnum 20GX
Size: 6
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2018
Renewed: 31-Jul-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr

Type: DC
Manufacturer: Backflow Direct
Model: Magnum 20X
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Mar-2018
Renewed: 15-Mar-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Backflow Direct
Model: Magnum 20X
Size: 6
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Mar-2018
Renewed: 15-Mar-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 2 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 2 1/2
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

2026 © University of Southern California

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 3
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 3
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 6
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 8
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr

Type: DC
Manufacturer: BEECO
Model: Barracuda 20
Size: 8
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr

Type: DC
Manufacturer: BEECO
Model: Barracuda 20X
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: Barracuda 20X
Size: 6
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: DC
Manufacturer: BEECO
Model: FDC
Size: 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Jan-2022
Renewed: 21-Jan-2025
Bypass:
Shutoffs: (yyyyyy)

Type: DC
Manufacturer: BEECO
Model: FDC
Size: 1/2
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Jan-2022
Renewed: 21-Jan-2025
Bypass:
Shutoffs: (yyyyyy)

Type: DC
Manufacturer: BEECO
Model: FDC
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Jan-2022
Renewed: 21-Jan-2025
Bypass:
Shutoffs: (yyyyyy)

Type: DC
Manufacturer: BEECO
Model: FDC
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Jan-2022
Renewed: 21-Jan-2025
Bypass:
Shutoffs: (yyyyyy)

2026 © University of Southern California

Type: DC
Size: 1
Manual: 10
Approved: 11-Oct-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 11-Oct-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 10
Approved: 11-Oct-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Oct-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 10
Approved: 21-Jan-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 21-Jan-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 10
Approved: 21-Jan-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 21-Jan-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 10
Approved: 21-Jan-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 21-Jan-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 10
Approved: 21-Jan-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 21-Jan-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 11-Oct-2022
Shutoffs: (yyyyyy)
Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 11-Oct-2025
Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 11-Oct-2022
Shutoffs: (yyyyyy)

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Oct-2025

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 6
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 18-Dec-2018
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed: 18-Dec-2024

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 28-Feb-2024
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed:

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 28-Feb-2024
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed:

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 10
Manual: 10
Approved: 28-Feb-2024
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: H
0.25% Pb: Yes
Renewed:

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 10
Manual: 10
Approved: 28-Feb-2024
Shutoffs: (vvvvvv), wwwwww

Manufacturer: BEECO
Orientation: VU
0.25% Pb: Yes
Renewed:

Model: FDC
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 8
Approved: 22-Jun-1989
Shutoffs: (gg),hh,qq,rr

Manufacturer: Cla-Val
Orientation: H
0.25% Pb: No
Renewed: 22-Jun-2025

Model: D4
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Manufacturer: Cla-Val
Model: D4
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jun-1989
Renewed: 22-Jun-2025
Bypass:
Shutoffs: (gg),hh,qq,rr

Type: DC
Manufacturer: Conbraco
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: See Apollo/Conbraco

Type: DC
Manufacturer: Febco
Model: 805 Type YD
Size: 2 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 805YD

Type: DC
Manufacturer: Febco
Model: 805 Type YD
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 805YD

Type: DC
Manufacturer: Febco
Model: 805 Type YD
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 805YD

Type: DC
Manufacturer: Febco
Model: 805 Type YD
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 805YD

Type: DC
Manufacturer: Febco
Model: 805 Type YD
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 805YD

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: 805 Type YD
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 805YD

Type: DC
Manufacturer: Febco
Model: 805Y
Size: 3/4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-May-1982
Renewed: 13-May-2024
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: DC
Manufacturer: Febco
Model: 805Y
Size: 1
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-May-1982
Renewed: 13-May-2024
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: DC
Manufacturer: Febco
Model: 805Y
Size: 1 1/2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jan-1983
Renewed: 05-Jan-2025
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: DC
Manufacturer: Febco
Model: 805Y
Size: 2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jan-1983
Renewed: 05-Jan-2025
Bypass:
Shutoffs: ii,fff,ooo

Type: DC
Manufacturer: Febco
Model: 805YB
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable seats beginning with Serial No. A105801

Type: DC
Manufacturer: Febco
Model: 805YB
Size: 3/4
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Apr-1996
Renewed: 16-Apr-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable seats beginning with Serial No. A105801

Type: DC
Manufacturer: Febco
Model: 805YD
Size: 2 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1987
Renewed: 31-May-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg
Notes: formerly 805 Type YD

Type: DC
Manufacturer: Febco
Model: 805YD
Size: 3
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1987
Renewed: 31-May-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg
Notes: formerly 805 Type YD

Type: DC
Manufacturer: Febco
Model: 805YD
Size: 4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1987
Renewed: 31-May-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg
Notes: formerly 805 Type YD

Type: DC
Manufacturer: Febco
Model: 805YD
Size: 6
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1987
Renewed: 31-May-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg
Notes: formerly 805 Type YD

Type: DC
Manufacturer: Febco
Model: 805YD
Size: 8
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1987
Renewed: 31-May-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg
Notes: formerly 805 Type YD

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: 805YD
Size: 10
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1987
Renewed: 31-May-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg
Notes: formerly 805 Type YD

Type: DC
Manufacturer: Febco
Model: 805YR
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jan-1993
Renewed: 22-Jan-2026
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: DC
Manufacturer: Febco
Model: 805YR
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jan-1993
Renewed: 22-Jan-2026
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: DC
Manufacturer: Febco
Model: 850
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Nov-1997
Renewed: 21-Nov-2024
Bypass:
Shutoffs: (fff),ooo

Type: DC
Manufacturer: Febco
Model: 850
Size: 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 13-Apr-2000
Renewed: 13-Apr-2024
Bypass:
Shutoffs: (fff),ooo

Type: DC
Manufacturer: Febco
Model: 850
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 17-Dec-1999
Renewed: 17-Dec-2023
Bypass:
Shutoffs: (fff),ooo

Type: DC
Size: 3/4
Manual: 9
Approved: 21-Nov-1997
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 21-Nov-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 10-Apr-2000
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 10-Apr-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 17-Dec-1999
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 17-Dec-2023
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 21-Nov-1997
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 21-Nov-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 14-Jan-2000
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 14-Jan-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 07-Sep-2000
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 07-Sep-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 21-Nov-1997
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 21-Nov-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/4
Manual: 9
Approved: 13-Apr-2000
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 13-Apr-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 17-Jul-1999
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 17-Jul-2026
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 19-Feb-1998
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 19-Feb-2025
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 13-Apr-2000
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 13-Apr-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 17-Jul-1999
Shutoffs: (fff),jjj,ooo
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 17-Jul-2026
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 19-Feb-1998
Shutoffs: (fff),ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 19-Feb-2025
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 10-Apr-2000
Shutoffs: (fff),ooo
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 10-Apr-2024
Model: 850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Febco
Model: 850
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 17-Jul-1999
Renewed: 17-Jul-2026
Bypass:
Shutoffs: (fff),ooo

Type: DC
Manufacturer: Febco
Model: 850
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Mar-1997
Renewed: 14-Mar-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 2 1/2
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Mar-1997
Renewed: 19-Mar-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Mar-1997
Renewed: 14-Mar-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 3
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Mar-1997
Renewed: 19-Mar-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 4
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Feb-1995
Renewed: 07-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: 850
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 6
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1995
Renewed: 31-May-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-1995
Renewed: 04-Oct-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850
Size: 8
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Oct-1996
Renewed: 14-Oct-2023
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 850F
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 28-Sep-2001
Renewed: 28-Sep-2025
Bypass:
Shutoffs: fff,jjj

Type: DC
Manufacturer: Febco
Model: 850F
Size: 3/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Sep-2001
Renewed: 28-Sep-2025
Bypass:
Shutoffs: (fff),jjj

Type: DC
Manufacturer: Febco
Model: 850F
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Sep-2001
Renewed: 28-Sep-2025
Bypass:
Shutoffs: (fff),jjj

Type: DC
Size: 1/2
Manual: 9
Approved: 12-Oct-1998
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 12-Oct-2025
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 16-Oct-2024
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 17-Dec-1999
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 17-Dec-2023
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 08-Mar-1999
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 08-Mar-2026
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 16-Oct-2024
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 17-Dec-1999
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 17-Dec-2023
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 04-Aug-1999
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 04-Aug-2026
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 14-Jan-2000
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 14-Jan-2024
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 16-Oct-2024
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 12-Oct-1998
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 12-Oct-2025
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 16-Oct-2024
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 04-Aug-1999
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VU
0.25% Pb: No
Renewed: 04-Aug-2026
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 12-Oct-1998
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 12-Oct-2025
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 16-Oct-2000
Shutoffs: (kkk)
Manufacturer: Febco
Orientation: VD
0.25% Pb: No
Renewed: 16-Oct-2024
Model: 850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Febco
Model: 850U
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Aug-1999
Renewed: 04-Aug-2026
Bypass:
Shutoffs: (kkk)

Type: DC
Manufacturer: Febco
Model: 850U
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: DC
Manufacturer: Febco
Model: 850U
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (kkk)

Type: DC
Manufacturer: Febco
Model: 850U
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Aug-1999
Renewed: 04-Aug-2026
Bypass:
Shutoffs: (kkk)

Type: DC
Manufacturer: Febco
Model: 857
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass:
Shutoffs: (oo), gg, hh,ll, mm, pp, tt, uu, yy, fff

Type: DC
Manufacturer: Febco
Model: 857
Size: 2 1/2
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass:
Shutoffs: (oo), gg, hh,ll, mm, pp, tt, uu, yy, fff

Type: DC
Manufacturer: Febco
Model: 857
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass:
Shutoffs: (oo), gg, hh,ll, mm, pp, tt, uu, yy, fff

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: 857
Size: 3
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass:
Shutoffs: (oo), gg, hh,ll, mm, pp, tt, uu, yy, fff

Type: DC
Manufacturer: Febco
Model: 870
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Mar-1995
Renewed: 10-Mar-2025
Bypass:
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870
Size: 3
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Mar-1995
Renewed: 10-Mar-2025
Bypass:
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870
Size: 4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass:
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870
Size: 6
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass:
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870
Size: 8
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-May-1994
Renewed: 24-May-2024
Bypass:
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870
Size: 10
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-1996
Renewed: 04-Oct-2023
Bypass:
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 3
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 3
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 4
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 6
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: 870V
Size: 6
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 8
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jan-1997
Renewed: 06-Jan-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 8
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jan-1997
Renewed: 06-Jan-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,ffff,gggg

Type: DC
Manufacturer: Febco
Model: 870V
Size: 10
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jul-1997
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

---

Type: DC
Manufacturer: Febco
Model: 870V
Size: 10
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jul-1997
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo.pp,tt,uu,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

---

Type: DC
Manufacturer: Febco
Model: LF850
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: DC
Manufacturer: Febco
Model: LF850
Size: 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2019
Renewed: 31-Jul-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: DC
Size: 1/2
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/4
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF850
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Febco
Model: LF850
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2019
Renewed: 31-Jul-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: DC
Manufacturer: Febco
Model: LF850
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2019
Renewed: 31-Jul-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: DC
Manufacturer: Febco
Model: LF850
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF850
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF850
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF850
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF850
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC **Manufacturer:** Febco **Model:** LF850
Size: 10 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Sep-2013
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 03-Sep-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Sep-2013
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 03-Sep-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 03-Sep-2013
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 03-Sep-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 03-Sep-2013
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 03-Sep-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 03-Sep-2013
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 03-Sep-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 31-Jul-2019
Shutoffs: (ppppp), hhhh

Manufacturer: Febco
Orientation: VD
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: LF850U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Febco
Model: LF850U
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2019
Renewed: 31-Jul-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: DC
Manufacturer: Febco
Model: LF850U
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: DC
Manufacturer: Febco
Model: LF850U
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2019
Renewed: 31-Jul-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: DC
Manufacturer: Febco
Model: LF850U
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 31-Jul-2019
Renewed: 31-Jul-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Aug-2012
Renewed: 09-Aug-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Aug-2012
Renewed: 09-Aug-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 10
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-May-2018
Renewed: 29-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870V
Size: 10
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-May-2018
Renewed: 29-May-2024
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 10
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870W
Size: 10
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 10
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Febco
Model: LF870WZ
Size: 10
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (mm),ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: MGI Controls
Model: 40DC
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2025
Renewed:
Bypass:
Shutoffs: (bbbbbbb)

Type: DC
Manufacturer: MGI Controls
Model: 40DC
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2025
Renewed:
Bypass:
Shutoffs: (bbbbbbb)

Type: DC
Manufacturer: MGI Controls
Model: 40DCU
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2025
Renewed:
Bypass:
Shutoffs: (ccccccc)

2026 © University of Southern California

Type: DC
Manufacturer: MGI Controls
Model: 40DCU
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2025
Renewed:
Bypass:
Shutoffs: (ccccccc)

Type: DC
Manufacturer: Neptune
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: See Wilkins

Type: DC
Manufacturer: Watts
Model: 007
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 30-Sep-1990
Renewed: 30-Sep-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 007
Size: 2 1/2
Orientation: VU
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Aug-1996
Renewed: 27-Aug-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 007
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 30-Sep-1990
Renewed: 30-Sep-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 007
Size: 3
Orientation: VU
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Aug-1996
Renewed: 27-Aug-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 007M1-FP
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: DC
Manufacturer: Watts
Model: 007M1-FP
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: DC
Manufacturer: Watts
Model: 007M1PCQT
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: 007M1PCQT
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: 007M1PCQT
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: 007M1PCQT
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: 007M1QT
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Feb-1991
Renewed: 26-Feb-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp
Notes: This assembly is only used as the by-pass assembly for DCDA assemblies

2026 © University of Southern California

Type: DC
Size: 1
Manual: 8
Approved: 26-Feb-1991
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: Upgraded to 9th Ed.

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 26-Feb-2024

Model: 007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: Previous 8th Ed. Approval

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 18-May-2025

Model: 007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 18-May-2025

Model: 007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 30-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: 007M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 30-Jun-1992
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: 007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 08-Mar-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 08-Mar-2026

Model: 007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024
Model: 007M2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024
Model: 007M2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 09-Dec-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Dec-2023
Model: 007M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 09-Dec-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 09-Dec-2023
Model: 007M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Sep-2024
Model: 007M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 05-Apr-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 05-Apr-2026
Model: 007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 27-Aug-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 27-Aug-2026
Model: 007M2QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/4
Manual: 8
Approved: 01-Oct-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Oct-2026

Model: 007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 01-Oct-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 01-Oct-2026

Model: 007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 24-May-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 24-May-2024

Model: 007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 11-Mar-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 11-Mar-2026

Model: 007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024

Model: 007M3-FP
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 18-Oct-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 18-Oct-2023

Model: 007M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 18-Oct-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 18-Oct-2023

Model: 007M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 8
Approved: 17-Feb-1995
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Feb-2025

Model: 007PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 007PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 007PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 8
Approved: 06-Dec-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Upgraded to 9th Ed.

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 08-Dec-2023

Model: 007QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 16-Jun-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previous 8th Ed. Approval

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 16-Jun-2024

Model: 007QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 8
Approved: 19-Apr-1996
Shutoffs: pppp,rrrrr
Notes: Upgraded to 9th Ed.

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 19-Apr-2026

Model: 007QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1/2
Manual: 9
Approved: 16-Jun-1997
Shutoffs: (vv),xx,pppp,rrrrr
Notes: Previous 8th Ed. Approval

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 16-Jun-2024

Model: 007QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: 007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: 007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 7
Approved: 21-Jul-1988
Shutoffs: pppp,rrrrr
Notes: Upgraded to 9th Ed.

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 21-Jul-2024

Model: 007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 7
Approved: 21-Jul-1988
Shutoffs: pppp,rrrrr
Notes: Upgraded to 9th Ed.

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 21-Jul-2024

Model: 007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: 007SSM1PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: 007SSM1PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 26-Feb-1991
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 26-Feb-2024

Model: 007SSM1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 26-Feb-1991
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 26-Feb-2024

Model: 007SSM1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 007SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 007SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: 007SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: 007SSQT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 007SSQT
Size: 1 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jul-1988
Renewed: 21-Jul-2024
Bypass:
Shutoffs: pppp

Type: DC
Manufacturer: Watts
Model: 007SSQT
Size: 2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jul-1988
Renewed: 21-Jul-2024
Bypass:
Shutoffs: pppp

Type: DC
Manufacturer: Watts
Model: 700
Size: 2 1/2
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Jan-1981
Renewed: 10-Jan-2026
Bypass:

Type: DC
Manufacturer: Watts
Model: 700
Size: 3
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Jan-1981
Renewed: 10-Jan-2026
Bypass:

Type: DC
Manufacturer: Watts
Model: 709
Size: 2 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Jun-1986
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 3
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Jun-1986
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 15-Jan-1982
Renewed: 15-Jan-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 4
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-1996
Renewed: 11-Mar-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 6
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-May-1982
Renewed: 18-May-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 6
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 8
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jul-1981
Renewed: 06-Jul-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 8
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 10
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Mar-1983
Renewed: 16-Mar-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709
Size: 10
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 709BB
Size: 2 1/2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jul-1982
Renewed: 20-Jul-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709BB
Size: 3
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jul-1982
Renewed: 20-Jul-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 709QT
Size: 3/4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1982
Renewed: 04-Aug-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp
Notes: Formerly Model 709

Type: DC
Manufacturer: Watts
Model: 709QT
Size: 1
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1982
Renewed: 04-Aug-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp
Notes: Formerly Model 709

Type: DC
Manufacturer: Watts
Model: 709QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Apr-1982
Renewed: 21-Apr-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp
Notes: Formerly Model 709

Type: DC
Manufacturer: Watts
Model: 709QT
Size: 2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Apr-1982
Renewed: 21-Apr-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp
Notes: Formerly Model 709

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jul-2025

Model: 719AQTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jul-2025

Model: 719AQTR10
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Manufacturer: Watts
Model: 719QTR10
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrrr

Type: DC
Manufacturer: Watts
Model: 719QTR10
Size: 3/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrrr

Type: DC
Manufacturer: Watts
Model: 719QTR10
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrrr

Type: DC
Manufacturer: Watts
Model: 757
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 757
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Sep-2004
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Sep-2004
Renewed: 16-Sep-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 757
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Feb-2006
Renewed: 10-Feb-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 10-Feb-2006
Renewed: 10-Feb-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 02-May-2008
Renewed: 02-May-2026
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 02-May-2008
Renewed: 02-May-2026
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 02-May-2008
Renewed: 02-May-2026
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 02-May-2008
Renewed: 02-May-2026
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC
Manufacturer: Watts
Model: 757a
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 757a
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 757N
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,nnnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Jan-2013
Renewed: 03-Jan-2025
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb

Type: DC
Manufacturer: Watts
Model: 757N
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Jan-2013
Renewed: 03-Jan-2025
Bypass:
Shutoffs: yyy, zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn

Type: DC
Manufacturer: Watts
Model: 757N
Size: 10
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (ppp),qqq

Type: DC
Manufacturer: Watts
Model: 757N
Size: 10
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn

Type: DC
Manufacturer: Watts
Model: 757Na
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Mar-2003
Renewed: 20-Mar-2024
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC
Manufacturer: Watts
Model: 757Na
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Mar-2003
Renewed: 20-Mar-2024
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 757Na
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Mar-2003
Renewed: 20-Mar-2024
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC
Manufacturer: Watts
Model: 757Na
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 03-Jul-2003
Renewed: 03-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC
Manufacturer: Watts
Model: 757NQT
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757NQT
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757NQT
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757QT
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757QT
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757QT
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757QT
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757QT
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 757QT
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass:
Shutoffs: fffff

Type: DC
Manufacturer: Watts
Model: 767
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC
Manufacturer: Watts
Model: 767
Size: 2 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC
Manufacturer: Watts
Model: 767
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 29-Sep-2004 **Renewed:** 29-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 21-Apr-2006 **Renewed:** 21-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 21-Apr-2006 **Renewed:** 21-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Sep-2004 **Renewed:** 16-Sep-2025 **Bypass:**
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 10-Feb-2006 **Renewed:** 10-Feb-2024 **Bypass:**
Shutoffs: (yyy),ppp,qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: (yyy), ppp, qqq,zzz, aaaa, bbbb, dddd, eeee, ffff, gggg,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-May-2008 **Renewed:** 02-May-2026 **Bypass:**
Shutoffs: (yyy), ppp, qqq,zzz, aaaa, bbbb, dddd, eeee, ffff, gggg,nnnnn

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Oct-2008 **Renewed:** 20-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg

Type: DC **Manufacturer:** Watts **Model:** 767
Size: 10 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Oct-2008 **Renewed:** 20-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg

Type: DC **Manufacturer:** Watts **Model:** 767a
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767a
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767a
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767a
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 07-Oct-2002 **Renewed:** 07-Oct-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767a
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: DC **Manufacturer:** Watts **Model:** 767a
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767N
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jan-2013 **Renewed:** 03-Jan-2025 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb

Type: DC **Manufacturer:** Watts **Model:** 767N
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 03-Jan-2013 **Renewed:** 03-Jan-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn

Type: DC **Manufacturer:** Watts **Model:** 767N
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 01-Sep-2009 **Renewed:** 01-Sep-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,dddd,eeee,dddd,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: DC **Manufacturer:** Watts **Model:** 767Na
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767Na
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Mar-2003 **Renewed:** 20-Mar-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 767Na
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: DC **Manufacturer:** Watts **Model:** 770
Size: 4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-May-1992 **Renewed:** 20-May-2025 **Bypass:**
Shutoffs: oo,gg,hh,ll,mm,pp,tt,uu,yy

Type: DC **Manufacturer:** Watts **Model:** 770
Size: 8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 13-Jan-1993 **Renewed:** 13-Jan-2026 **Bypass:**
Shutoffs: oo,gg,hh,ll,mm,pp,tt,uu,yy

Type: DC **Manufacturer:** Watts **Model:** 770QTFDA
Size: 4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 12-Jan-1993 **Renewed:** 12-Jan-2026 **Bypass:**
Shutoffs: ww

Type: DC **Manufacturer:** Watts **Model:** 770QTFDA
Size: 8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 12-Jan-1993 **Renewed:** 12-Jan-2026 **Bypass:**
Shutoffs: ww

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 772
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Jul-1992
Renewed: 01-Jul-2025
Bypass:
Shutoffs: oo,yy

Type: DC
Manufacturer: Watts
Model: 772
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass:
Shutoffs: oo,yy

Type: DC
Manufacturer: Watts
Model: 774
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Watts
Model: 774
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Watts
Model: 774
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Watts
Model: 774
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Watts
Model: 774
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Sep-1996
Renewed: 16-Sep-2026
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: DC
Manufacturer: Watts
Model: 774
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Sep-1996
Renewed: 16-Sep-2026
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 16-Feb-2001
Renewed: 16-Feb-2025
Bypass:
Shutoffs: (ll),mm,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774
Size: 12
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Jan-2010
Renewed: 12-Jan-2025
Bypass:
Shutoffs: hh,gg

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: 774
Size: 12
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Jan-2010
Renewed: 12-Jan-2025
Bypass:
Shutoffs: (ll),mm

Type: DC
Manufacturer: Watts
Model: 774
Size: 12
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: pp,

Type: DC
Manufacturer: Watts
Model: 774
Size: 12
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (ll),mm,oo

Type: DC
Manufacturer: Watts
Model: 774X
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass:
Shutoffs: (mm),ee,ff,gg,hh,ll,oo,pp,tt,uu,ccc,ddd,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774X
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Nov-1993
Renewed: 22-Nov-2023
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 774X
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass:
Shutoffs: tt,ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg

Type: DC
Manufacturer: Watts
Model: 775QT
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass:
Shutoffs: int

Type: DC
Size: 1/2
Manual: 9
Approved: 01-Feb-2000
Shutoffs: int
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 01-Feb-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 01-Feb-2000
Shutoffs: int
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Feb-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 01-Feb-2000
Shutoffs: int
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 01-Feb-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 12-Aug-1999
Shutoffs: int
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Aug-2026
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 12-Aug-1999
Shutoffs: int
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 12-Aug-2026
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 07-Sep-2000
Shutoffs: int
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 07-Sep-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 07-Sep-2000
Shutoffs: int
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 07-Sep-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 9
Approved: 07-Sep-2000
Shutoffs: int
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 07-Sep-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 07-Sep-2000
Shutoffs: int
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 07-Sep-2024
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 28-Mar-2002
Shutoffs: int
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 28-Mar-2026
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 28-Mar-2002
Shutoffs: int
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 28-Mar-2026
Model: 775QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2 1/2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (oo)
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF007
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (oo)
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF007
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 9
Approved: 08-Dec-2022
Shutoffs: (oo)
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 08-Dec-2025
Model: LF007IOT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 9
Approved: 08-Dec-2022
Shutoffs: (oo)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 08-Dec-2025

Model: LF007IOT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007M1IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007M1IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007M1IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007M1IOTQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007M3IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF007M3IOTQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 3/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024
Model: LF007M3PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 13-Mar-2024
Model: LF007M3PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026
Model: LF007M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 11-Jan-2026
Model: LF007M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024
Model: LF007PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 13-Mar-2024
Model: LF007PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026
Model: LF007QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Watts
Model: LF007QT
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jan-2008
Renewed: 11-Jan-2026
Bypass:
Shutoffs: (hhhh),rrrrr

Type: DC
Manufacturer: Watts
Model: LF709
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Jan-2010
Renewed: 12-Jan-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Jan-2010
Renewed: 12-Jan-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jul-2012
Renewed: 27-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jul-2012
Renewed: 27-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jul-2012
Renewed: 27-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jul-2012
Renewed: 27-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: LF709
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Jul-2010
Renewed: 01-Jul-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Jul-2010
Renewed: 01-Jul-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Jul-2010
Renewed: 01-Jul-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Jul-2010
Renewed: 01-Jul-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

Type: DC
Manufacturer: Watts
Model: LF709IOT
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Dec-2022
Renewed: 08-Dec-2025
Bypass:
Shutoffs: (ll),oo,dddd,eeee,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LF719AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 03-Jul-2025

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 03-Jul-2025

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 03-Jul-2025

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 03-Jul-2025

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 03-Jul-2025

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 03-Jul-2013
Shutoffs: (hhhh)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 03-Jul-2025

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr
Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: hhhh,rrrrr

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: hhhh,rrrrr

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: hhhh,rrrrr

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: DC
Manufacturer: Watts
Model: LF719QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Aug-2005
Renewed: 22-Aug-2026
Bypass:
Shutoffs: hhhh,rrrrr

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LF719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 3/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LF719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp
Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh
Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026
Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: (vv),xx,ooo,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 22-Aug-2005
Shutoffs: hhhh

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 22-Aug-2026

Model: LFU719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 3
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 03-Aug-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 03-Aug-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 03-Aug-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2 1/2
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 4
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026
Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 6
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 6
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 8
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 20G
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 18-May-2025

Model: SS007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 18-May-2025

Model: SS007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 11-Sep-2000
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Sep-2024

Model: SS007M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Manufacturer: Watts
Model: SS007M3QT
Size: 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Sep-2000
Renewed: 11-Sep-2024
Bypass:
Shutoffs: (hhh)

Type: DC
Manufacturer: Watts
Model: SS007M3QT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Sep-2000
Renewed: 07-Sep-2024
Bypass:
Shutoffs: (hhh)

Type: DC
Manufacturer: Watts
Model: SS007M3QT
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Sep-2000
Renewed: 07-Sep-2024
Bypass:
Shutoffs: (hhh)

Type: DC
Manufacturer: Watts
Model: U007M1APCQT
Size: 3/4
Orientation: VDVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1994
Renewed: 10-Dec-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U007M1APCQT
Size: 3/4
Orientation: VDVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1994
Renewed: 10-Dec-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U007M1APCQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1994
Renewed: 10-Dec-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U007M1APCQT
Size: 3/4
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1994
Renewed: 10-Dec-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

2026 © University of Southern California

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U007M1APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U007M1APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U007M1APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U007M1APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 24-Feb-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Feb-2024
Model: U007M1AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 10-Dec-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023
Model: U007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 10-Dec-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023
Model: U007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U007M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 30-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 28-Aug-2026

Model: U007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 30-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Aug-2026

Model: U007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 20-Oct-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Oct-2023

Model: U007M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 20-Oct-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Oct-2023

Model: U007M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 06-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 06-Sep-2024

Model: U007M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 06-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 06-Sep-2024

Model: U007M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 06-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 06-Sep-2024

Model: U007M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 06-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 06-Sep-2024

Model: U007M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 8
Approved: 01-Oct-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Oct-2026

Model: U007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 06-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Sep-2024

Model: U007M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U007PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U007PCQT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U007PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U007PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 08-Mar-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 08-Mar-2026

Model: U007QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 08-Mar-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 08-Mar-2026

Model: U007QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 7
Approved: 21-Jul-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 21-Jul-2024

Model: U007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 7
Approved: 21-Jul-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 21-Jul-2024

Model: U007QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U007SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U007SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U007SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U007SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U007SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U007SSQT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Watts
Model: U007SSQT
Size: 1 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jul-1988
Renewed: 21-Jul-2024
Bypass:
Shutoffs: vv,xx,pppp

Type: DC
Manufacturer: Watts
Model: U007SSQT
Size: 2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jul-1988
Renewed: 21-Jul-2024
Bypass:
Shutoffs: vv,xx,pppp

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to U719QTR10

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to U719QTR10

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to U719QTR10

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to U719QTR10

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to U719QTR10

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to U719QTR10

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: DC
Manufacturer: Watts
Model: U719QT
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Oct-2005
Renewed: 04-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

2026 © University of Southern California

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QT
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: formerly U719QT

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: formerly U719QT

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: formerly U719QT

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: formerly U719QT

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: formerly U719QT

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

Type: DC
Size: 3/4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: formerly U719QT

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: U719QTR10
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Jul-2005
Renewed: 06-Jul-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Jul-2005
Renewed: 06-Jul-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Apr-2006
Renewed: 21-Apr-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Sep-2001
Renewed: 05-Sep-2025
Bypass:
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Apr-2002 **Renewed:** 03-Apr-2026 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 05-Sep-2001 **Renewed:** 05-Sep-2025 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Apr-2002 **Renewed:** 03-Apr-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 15-Sep-1999 **Renewed:** 15-Sep-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 07-Sep-2000 **Renewed:** 07-Sep-2024 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 18-Oct-1999 **Renewed:** 18-Oct-2023 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 17-Dec-1999 **Renewed:** 17-Dec-2023 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 08-Mar-2002 **Renewed:** 08-Mar-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Jan-2003 **Renewed:** 16-Jan-2024 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 28-Aug-2002 **Renewed:** 28-Aug-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC **Manufacturer:** Wilkins **Model:** 350
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Mar-2003
Renewed: 14-Mar-2024
Bypass:
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 12
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Feb-2009
Renewed: 10-Feb-2024
Bypass:
Shutoffs: (hh),ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number J35214

Type: DC
Manufacturer: Wilkins
Model: 350
Size: 12
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (hh),ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number J35214 and higher

Type: DC
Manufacturer: Wilkins
Model: 350A
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jun-2005
Renewed: 22-Jun-2026
Bypass:
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number J35214 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Jun-2005 **Renewed:** 22-Jun-2026 **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,llllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Jun-2005 **Renewed:** 22-Jun-2026 **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,llllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,llllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Jun-2005 **Renewed:** 22-Jun-2026 **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 3 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Mar-2004 **Renewed:** 16-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Mar-2004 **Renewed:** 16-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 4 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 25-Nov-2003 **Renewed:** 25-Nov-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 25-Nov-2003 **Renewed:** 25-Nov-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 6 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Feb-2004 **Renewed:** 12-Feb-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Feb-2004 **Renewed:** 12-Feb-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 8 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 06-Apr-2006 **Renewed:** 06-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 10 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 06-Apr-2006 **Renewed:** 06-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350A
Size: 10 **Orientation:** VU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number U26097 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 350AR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Jun-2010 **Renewed:** 16-Jun-2025 **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8" Up to serial number U26097

Type: DC **Manufacturer:** Wilkins **Model:** 350AR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

2026 © University of Southern California

Type: DC | **Manufacturer:** Wilkins | **Model:** 350AR
Size: 2 1/2 | **Orientation:** VU | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC | **Manufacturer:** Wilkins | **Model:** 350AR
Size: 2 1/2 | **Orientation:** VU | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 09-Sep-2010 | **Renewed:** 09-Sep-2025 | **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC | **Manufacturer:** Wilkins | **Model:** 350AR
Size: 3 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 3/4" and max. 48 1/8"

Type: DC | **Manufacturer:** Wilkins | **Model:** 350AR
Size: 3 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 09-Sep-2010 | **Renewed:** 09-Sep-2025 | **Bypass:**
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 3/4" and max. 48 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jun-2010
Renewed: 16-Jun-2025
Bypass:
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 35 3/4" and max. 62 1/4"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 3
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 3/4" and max. 48 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 42 1/2" and max. 71 1/4"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 35 3/4" and max. 62 1/4"

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 57 7/8" and max. 86"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 35 3/4" and max. 62 1/4"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 61 3/8" and max. 100 5/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 42 1/2" and max. 71 1/4"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 6
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 42 1/2" and max. 71 1/4"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 57 7/8" and max. 86"

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 8
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 57 7/8" and max. 86"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 61 3/8" and max. 100 5/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: DC
Manufacturer: Wilkins
Model: 350AR
Size: 10
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Notes: Only Serial No. C00102 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 61 3/8" and max. 100 5/8"

Type: DC
Manufacturer: Wilkins
Model: 350AST
Size: 2 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Nov-2011
Renewed: 29-Nov-2023
Bypass:
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC
Manufacturer: Wilkins
Model: 350AST
Size: 2 1/2
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Nov-2012
Renewed: 09-Nov-2024
Bypass:
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC
Manufacturer: Wilkins
Model: 350AST
Size: 3
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Nov-2011
Renewed: 29-Nov-2023
Bypass:
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 3 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Nov-2012 **Renewed:** 09-Nov-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 29-Nov-2011 **Renewed:** 29-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 4 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Nov-2012 **Renewed:** 09-Nov-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 27-Mar-2012 **Renewed:** 27-Mar-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 6 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Oct-2012 **Renewed:** 24-Oct-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 8 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350AST
Size: 10 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 2 1/2 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8"

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 3 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 4 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 6 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Feb-2014 **Renewed:** 25-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 8 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Feb-2014 **Renewed:** 25-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Feb-2014 **Renewed:** 25-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

Type: DC **Manufacturer:** Wilkins **Model:** 350ASTR
Size: 10 **Orientation:** VU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Feb-2014 **Renewed:** 25-Feb-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

Type: DC **Manufacturer:** Wilkins **Model:** 350D
Size: 3/4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 19-May-2009 **Renewed:** 19-May-2024 **Bypass:**
Shutoffs: (ii), ooo

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 350D
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jun-2009
Renewed: 22-Jun-2024
Bypass:
Shutoffs: (ii), ooo

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Oct-2006
Renewed: 27-Oct-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Oct-2006
Renewed: 27-Oct-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 1 1/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 1 1/2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 350XL
Size: 2
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2009
Renewed: 08-Jan-2024
Bypass:
Shutoffs: (int)

Type: DC
Manufacturer: Wilkins
Model: 450
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Jan-2002
Renewed: 24-Jan-2026
Bypass:
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number K01185

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number K01185 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 24-Jan-2002 **Renewed:** 24-Jan-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number K01185

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number K01185 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Apr-2000 **Renewed:** 12-Apr-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number K01185

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number K01185 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 24-May-2000 **Renewed:** 24-May-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number K01185

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number K01185 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number K01185

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number K01185 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 11-Sep-2003 **Renewed:** 11-Sep-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number K01185

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 450
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number K01185 and higher

Type: DC **Manufacturer:** Wilkins **Model:** 450ST
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 13-Jun-2018 **Renewed:** 13-Jun-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 450ST
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 13-Jun-2018 **Renewed:** 13-Jun-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 450ST
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 450ST
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 450STR
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 13-Jun-2018 **Renewed:** 13-Jun-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: DC **Manufacturer:** Wilkins **Model:** 450STR
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 13-Jun-2018 **Renewed:** 13-Jun-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 450STR
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 450STR
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 3/4 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Oct-1976 **Renewed:** 11-Oct-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 1 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Oct-1976 **Renewed:** 11-Oct-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 1 1/4 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Oct-1976 **Renewed:** 11-Oct-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 1 1/2 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Oct-1976 **Renewed:** 11-Oct-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 1 1/2 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Oct-1976 **Renewed:** 11-Oct-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 2 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Oct-1976 **Renewed:** 11-Oct-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 7 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 25-Sep-1986 **Renewed:** 25-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 3 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Aug-1979 **Renewed:** 20-Aug-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 4 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Jun-1980 **Renewed:** 20-Jun-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550
Size: 6 **Orientation:** H **Meters:**
Manual: 6 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 06-Jul-1981 **Renewed:** 06-Jul-2026 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550A
Size: 3/4 **Orientation:** H **Meters:**
Manual: 7 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 17-Apr-1987 **Renewed:** 17-Apr-2026 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

Type: DC **Manufacturer:** Wilkins **Model:** 550A
Size: 1 **Orientation:** H **Meters:**
Manual: 7 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 17-Apr-1987 **Renewed:** 17-Apr-2026 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 550M
Size: 8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 15-Mar-1989 **Renewed:** 15-Mar-2025 **Bypass:**
Shutoffs: (ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa
Notes: 4"x4"x8" Manifold Formerly MBD

Type: DC **Manufacturer:** Wilkins **Model:** 550M
Size: 10 **Orientation:** H **Meters:**
Manual: 6 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 11-Apr-1983 **Renewed:** 11-Apr-2025 **Bypass:**
Shutoffs: (ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa
Notes: 6"x6"x10" Manifold Formerly MBD

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 3/4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Jul-1991 **Renewed:** 18-Jul-2024 **Bypass:**
Shutoffs: (ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 1 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Jul-1991 **Renewed:** 18-Jul-2024 **Bypass:**
Shutoffs: (ppp),sss,ttt,qqq,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 1 1/4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-Apr-1991 **Renewed:** 05-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

2026 © University of Southern California

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 1 1/2 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-Apr-1991 **Renewed:** 05-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 2 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-Apr-1991 **Renewed:** 05-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 26-Nov-1991 **Renewed:** 26-Nov-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 3 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 08-Nov-1991 **Renewed:** 08-Nov-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 08-Nov-1991 **Renewed:** 08-Nov-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 4 **Orientation:** VU **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 29-Aug-1995 **Renewed:** 29-Aug-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 6 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Mar-1992 **Renewed:** 18-Mar-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 6 **Orientation:** VU **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 29-Aug-1995 **Renewed:** 29-Aug-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Mar-1989 **Renewed:** 18-Mar-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 8 **Orientation:** VU **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 29-Aug-1995 **Renewed:** 29-Aug-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950
Size: 10 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 12-Apr-1994 **Renewed:** 12-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950A
Size: 3/4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Jul-1991 **Renewed:** 18-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950A
Size: 1 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Jul-1991 **Renewed:** 18-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa

---

Type: DC **Manufacturer:** Wilkins **Model:** 950A
Size: 1 1/4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 18-Jul-1991 **Renewed:** 18-Jul-2024 **Bypass:**
Shutoffs: ii

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 950A
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Wilkins
Model: 950A
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: DC
Manufacturer: Wilkins
Model: 950XL
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XL
Size: 3/4
Orientation: VU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Dec-1996
Renewed: 12-Dec-2023
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XL
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XL
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),ooo,ggg

Type: DC
Manufacturer: Wilkins
Model: 950XL
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),ooo

Type: DC
Manufacturer: Wilkins
Model: 950XL
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),bbb,ooo

Type: DC
Manufacturer: Wilkins
Model: 950XL3
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: DC
Manufacturer: Wilkins
Model: 950XL3
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: DC
Manufacturer: Wilkins
Model: 950XL3
Size: 1
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: DC
Manufacturer: Wilkins
Model: 950XL3
Size: 1
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: DC
Manufacturer: Wilkins
Model: 950XL3
Size: 1 1/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

2026 © University of Southern California

Type: DC
Size: 1 1/4
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (iiii)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (iiii)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (iiii)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (iiii)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (iiii)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 23-May-2023
Shutoffs: (pppppp)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 23-May-2026
Model: 950XL3BFSS
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 2
Manual: 10
Approved: 23-May-2023
Shutoffs: (pppppp)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 23-May-2026
Model: 950XL3BFSS
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 3/4
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/4
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: VU
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

Type: DC
Size: 1 1/2
Manual: 10
Approved: 06-Sep-2022
Shutoffs: (mmmmm)
Manufacturer: Wilkins
Orientation: H
0.25% Pb: Yes
Renewed: 06-Sep-2025
Model: 950XL3U
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 950XL3U
Size: 1 1/2
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)

Type: DC
Manufacturer: Wilkins
Model: 950XL3U
Size: 2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)

Type: DC
Manufacturer: Wilkins
Model: 950XL3U
Size: 2
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Sep-1999
Renewed: 15-Sep-2026
Bypass:
Shutoffs: (ii),ooo, iiii, mmmmm
Notes: Up to Serial # 3863324 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Sep-1999
Renewed: 15-Sep-2026
Bypass:
Shutoffs: (ii),ooo, iiii, mmmmm
Notes: Starting at Serial # 3863325 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Jul-2013
Renewed: 03-Jul-2025
Bypass:
Shutoffs: (iiii), mmmmm
Notes: Up to Serial # 3863324 Testcocks: Female Threaded End or 45 degree male SAE flare

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Jul-2013
Renewed: 03-Jul-2025
Bypass:
Shutoffs: (iiii), mmmmm
Notes: Starting at Serial # 3863325 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Jan-2000
Renewed: 05-Jan-2026
Bypass:
Shutoffs: (ii),ooo, iiii, mmmmm
Notes: Up to Serial # 3863324 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Jan-2000
Renewed: 05-Jan-2026
Bypass:
Shutoffs: (ii),ooo, iiii, mmmmm
Notes: Starting at Serial # 3863325 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Jul-2013
Renewed: 03-Jul-2025
Bypass:
Shutoffs: (iiii), mmmmm
Notes: Up to Serial # 3863324 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLD
Size: 3/4
Orientation: VU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Jul-2013
Renewed: 03-Jul-2025
Bypass:
Shutoffs: (iiii), mmmmm
Notes: Starting at Serial # 3863325 Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLDTCU
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (iiii), mmmmm

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 950XLT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-May-1997
Renewed: 09-May-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-May-1997
Renewed: 09-May-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Jun-1998
Renewed: 19-Jun-2025
Bypass:
Shutoffs: (ii),ooo

Type: DC
Manufacturer: Wilkins
Model: 950XLT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Apr-1998
Renewed: 09-Apr-2025
Bypass:
Shutoffs: (ii),ooo

Type: DC
Manufacturer: Wilkins
Model: 950XLT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Apr-1998
Renewed: 09-Apr-2025
Bypass:
Shutoffs: (ii),ooo,bbbbb,ccccc,pppppp

Type: DC
Manufacturer: Wilkins
Model: 950XLT2
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: DC
Manufacturer: Wilkins
Model: 950XLT2
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLT2
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii)

Type: DC
Manufacturer: Wilkins
Model: 950XLT2
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii)

Type: DC
Manufacturer: Wilkins
Model: 950XLT2
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii),pppppp

Type: DC
Manufacturer: Wilkins
Model: 950XLT2BFSS
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass:
Shutoffs: (pppppp)

Type: DC
Manufacturer: Wilkins
Model: 950XLT2U
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

2026 © University of Southern California

Type: DC
Manufacturer: Wilkins
Model: 950XLTBF
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (bbbbb),pppppp

Type: DC
Manufacturer: Wilkins
Model: 950XLTBFSS
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (ccccc),pppppp

Type: DC
Manufacturer: Wilkins
Model: 950XLTU
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Aug-2006
Renewed: 14-Aug-2024
Bypass:
Shutoffs: (ggg),xxx

Type: DC
Manufacturer: Wilkins
Model: 950XLTU
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Aug-2006
Renewed: 14-Aug-2024
Bypass:
Shutoffs: (ggg),xxx

Type: DC
Manufacturer: Wilkins
Model: 950XLU
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Feb-1994
Renewed: 15-Feb-2024
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: DC
Manufacturer: Wilkins
Model: 950XLU
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Feb-1994
Renewed: 15-Feb-2024
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: DC
Manufacturer: Wilkins
Model: 950XLU
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Feb-1994
Renewed: 15-Feb-2024
Bypass:
Shutoffs: (ggg),xxx

Type: DC
Manufacturer: Wilkins
Model: 950XLU
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Feb-1994
Renewed: 15-Feb-2024
Bypass:
Shutoffs: (ggg),xxx

Type: DC
Manufacturer: Wilkins
Model: MBD
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: 4"x4"x8" Manifold, Model designation changed to 550M

Type: DC
Manufacturer: Wilkins
Model: MBD
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: 6"x6"x10" Manifold, Model designation changed to 550M

Type: DCDA
Manufacturer: Ames
Model: 3000-1SS
Size: 12
Orientation: H
Meters: (N), H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass: Ames 200B 3/4" (H); Watts 719QT 3/4" (H)
Shutoffs: (mm), ll

Type: DCDA
Manufacturer: Ames
Model: 3000-1SS
Size: 12
Orientation: VU
Meters: (N), H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass: Ames 200B 3/4" (VU); Watts 719QT 3/4" (VU)
Shutoffs: (mm), ll

2026 © University of Southern California

Type: DCDA
Size: 2
Manual: 9
Approved: 16-Jun-1997
Shutoffs: (bbb),jjjj,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 16-Jun-2024

Model: 3000B
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000B 1/2" (H), Watts 007QT 1/2" (H)

Type: DCDA
Size: 2
Manual: 9
Approved: 16-Jun-1997
Shutoffs: (bbb),jjjj,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 16-Jun-2024

Model: 3000B
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000B 1/2" (VU), Watts 007QT 1/2" (VU)

Type: DCDA
Size: 2
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024

Model: 3000B-FP
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000B 1/2" (H), Watts 007QT 1/2" (H)

Type: DCDA
Size: 2
Manual: 9
Approved: 19-Jun-2015
Shutoffs: (eeeee), bbb, jjjj,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 19-Jun-2024

Model: 3000BM1
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000B 1/2" (H), Watts 007QT 1/2" (H)

Type: DCDA
Size: 2
Manual: 9
Approved: 19-Jun-2015
Shutoffs: (eeeee), bbb, jjjj,rrrrr

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 19-Jun-2024

Model: 3000BM1
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000B 1/2" (VU), Watts 007QT 1/2" (VU)

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 4
Orientation: H
Meters: (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Jul-1987
Renewed: 27-Jul-2026
Bypass: Ames 2000B 1/2"(H),Watts 007QT 1/2"(H)
Shutoffs: (pp),hh,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 4
Orientation: VU
Meters: (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Aug-1996
Renewed: 27-Aug-2026
Bypass: Ames 2000B 1/2"(VU),Watts 007QT 1/2"(VU)
Shutoffs: (pp),hh,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 6
Orientation: H
Meters: (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Jul-1987
Renewed: 27-Jul-2026
Bypass: Ames 2000B 1/2"(H),Watts 007QT 1/2"(H)
Shutoffs: (pp),hh,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 6
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass: Ames 2000B 1/2" (VU), Watts 007QT 1/2" (VU)
Shutoffs: (pp),hh,mm,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 8
Orientation: H
Meters: (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Apr-1987
Renewed: 19-Apr-2026
Bypass: Ames 2000B 1/2"(H),Watts 007QT 1/2"(H)
Shutoffs: (pp),hh,mm,uu,eee

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 8
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass: Ames 2000B 1/2" (VU), Watts 007QT 1/2" (VU)
Shutoffs: (pp),hh,mm,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 10
Orientation: H
Meters: (N),E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Jul-1987
Renewed: 27-Jul-2026
Bypass: Ames 2000B 1/2"(H),Watts 007QT 1/2"(H)
Shutoffs: (pp),hh,mm,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000CIV
Size: 10
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass: Ames 2000B 1/2" (VU), Watts 007QT 1/2" (VU)
Shutoffs: (pp),hh,mm,uu,eee

Type: DCDA
Manufacturer: Ames
Model: 3000DCDA
Size: 4
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass: Watts 007QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,mm,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA

Type: DCDA
Manufacturer: Ames
Model: 3000DCDA
Size: 6
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass: Watts 709QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,mm,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA-I

Type: DCDA
Manufacturer: Ames
Model: 3000DCDA
Size: 8
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass: Watts 007QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,mm,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA

Type: DCDA
Manufacturer: Ames
Model: 3000DCDC
Size: 10
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1987
Renewed: 04-Aug-2026
Bypass: Watts007M2QT 3/4" (H),Watts 709QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA

Type: DCDA
Manufacturer: Ames
Model: 3000GDCDA
Size: 4
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass: Watts 007QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,mm,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA

Type: DCDA
Manufacturer: Ames
Model: 3000GDCDA
Size: 6
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass: Watts 709QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,mm,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA-I

Type: DCDA
Manufacturer: Ames
Model: 3000GDCDA
Size: 8
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass: Watts 007QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,mm,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDA

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: 3000GDCDC
Size: 10
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1987
Renewed: 04-Aug-2026
Bypass: Watts 709QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,oo,pp,ccc,ddd,ffff,gggg
Notes: formerly DCDC

Type: DCDA
Manufacturer: Ames
Model: 3000SE
Size: 2 1/2
Orientation: H
Meters: (M),N,O,P,Q
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass: Watts007M2QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: (mm),ee,ff,gg,hh,ll,oo,pp,tt,uu,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: 3000SE
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-May-1995
Renewed: 24-May-2025
Bypass: Watts007M2QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: 3000SE
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: 3000SEA
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass: Ames 2000SS 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: 3000SEWM1
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Nov-1993
Renewed: 22-Nov-2023
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg
Notes: formerly 3000SS prior to S/N 2EK0320

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 2 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: to S/N 2EK0320 model designation changed to 3000SSWM1

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 2 1/2
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1995
Renewed: 16-Jan-2026
Bypass: Watts007M2QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: to S/N 2EK0320 model designation changed to 3000SSWM1

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1995
Renewed: 16-Jan-2026
Bypass: Watts007M2QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: to S/N 2EK0320 model designation changed to 3000SSWM1

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1995
Renewed: 16-Jan-2026
Bypass: Watts007M2QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: to S/N 2EK0320 model designation changed to 3000SEWM1

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass: Watts 007M1QT 3/4" (H)), Watts 007M3QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Sep-1996
Renewed: 16-Sep-2026
Bypass: Watts007M2QT 3/4" (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 10
Orientation: H
Meters: (J),C,E,F,G,H,I,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Feb-2001
Renewed: 16-Feb-2025
Bypass: Ames 2000B 3/4" (H)
Shutoffs: (ll),mm,oo,pp,ffff,gggg,zzzzzz,aaaaaaa

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 12
Orientation: H
Meters: (N), H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Dec-2009
Renewed: 04-Dec-2024
Bypass: Ames 2000BM3 3/4" (H)
Shutoffs: (mm), ll

Type: DCDA
Manufacturer: Ames
Model: 3000SS
Size: 12
Orientation: VU
Meters: (N), H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass: Ames 2000BM3 3/4" (VU)
Shutoffs: (mm), ll

Type: DCDA
Manufacturer: Ames
Model: 3000SSA
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass: Ames 2000SS 3/4" (H)
Shutoffs: uu,ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: 3000SSM
Size: 4
Orientation: H
Meters: (R)
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass: Ames 2000SS 1" (H)
Shutoffs: uu,ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: 3000SSM
Size: 6
Orientation: H
Meters: (S)
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-May-1995
Renewed: 05-May-2025
Bypass: Watts 007M2QT 1 1/2" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa

---

Type: DCDA
Manufacturer: Ames
Model: 3000SSWM1
Size: 2 1/2
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa
Notes: formerly 3000SS prior to S/N 2EK0320

Type: DCDA
Manufacturer: Ames
Model: 3000SSWM1
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa
Notes: formerly 3000SS prior to S/N 2EK0320

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: 3000SSWM1
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jul-1991
Renewed: 11-Jul-2024
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg,zzzzzz,aaaaaaa
Notes: formerly 3000SS prior to S/N 2EK0320

Type: DCDA
Manufacturer: Ames
Model: Colt 300aBF
Size: 2 1/2
Orientation: H
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Ames 2000BM3 3/4" (H)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Ames
Model: Colt 300aBF
Size: 2 1/2
Orientation: VU
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Ames 2000BM3 3/4" (VU)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Ames
Model: Colt 300aBF
Size: 3
Orientation: H
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Ames 2000BM3 3/4" (H)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Ames
Model: Colt 300aBF
Size: 3
Orientation: VU
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Ames 2000BM3 3/4" (VU)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Ames
Model: Colt 300aBF
Size: 4
Orientation: H
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Ames 2000BM3 3/4" (H)
Shutoffs: (yyy)

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: Colt 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 29-Sep-2004
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 29-Sep-2025
Model: Colt 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: Colt 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

2026 © University of Southern California

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 03-Nov-2004
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 03-Nov-2025
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4 (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: Colt 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 02-Mar-2025
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(H)

Type: DCDA
Size: 6
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 02-Mar-2025
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(V)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025
Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

2026 © University of Southern California

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Colt 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 02-Mar-2025

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(H)

Type: DCDA
Size: 6
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 02-Mar-2025

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(V)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

2026 © University of Southern California

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Colt 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: Colt 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: Colt 300NBF
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H), Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 300NGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

2026 © University of Southern California

Type: DCDA
Size: 8
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: Colt 300NGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: Colt 300NGV
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H), Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual:
Approved:
Notes: model designation changed to 3000DCDA

Manufacturer: Ames
Orientation:
0.25% Pb: No
Renewed:

Model: DCDA
Meters:
Spare Parts Only: No
Bypass:

Type: DCDA
Size: 4
Manual:
Approved:
Notes: model designation changed to 3000GDCDA

Manufacturer: Ames
Orientation:
0.25% Pb: No
Renewed:

Model: DCDA
Meters:
Spare Parts Only: No
Bypass:

Type: DCDA
Size: 8
Manual:
Approved:
Notes: model designation changed to 3000DCDA

Manufacturer: Ames
Orientation:
0.25% Pb: No
Renewed:

Model: DCDA
Meters:
Spare Parts Only: No
Bypass:

Type: DCDA
Size: 8
Manual:
Approved:
Notes: model designation changed to 3000GDCDA

Manufacturer: Ames
Orientation:
0.25% Pb: No
Renewed:

Model: DCDA
Meters:
Spare Parts Only: No
Bypass:

Type: DCDA
Manufacturer: Ames
Model: DCDA
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 3000DCDC

Type: DCDA
Manufacturer: Ames
Model: DCDA-I
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 3000DCDA

Type: DCDA
Manufacturer: Ames
Model: DCDA-I
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 3000GDCDA

Type: DCDA
Manufacturer: Ames
Model: DCDC
Size: 4
Orientation: H
Meters: (K),A,B,C,D,E,F,G,H,I,J,L,M,N,O,P,Q,T
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-1985
Renewed: 14-Jun-2024
Bypass: Watts 709QT 3/4" (H)
Shutoffs: ee,ff,gg,hh,oo,pp,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: DCDC
Size: 6
Orientation: H
Meters: (K),A,B,C,D,E,F,G,H,I,J,L,M,N,O,P,Q,T
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-1985
Renewed: 14-Jun-2024
Bypass: Watts 709QT 3/4" (H)
Shutoffs: ee,ff,gg,hh,oo,pp,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Ames
Model: DCDC
Size: 8
Orientation: H
Meters: (K),A,B,C,D,E,F,G,H,I,J,L,M,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Aug-1987
Renewed: 04-Aug-2026
Bypass: Watts 709QT 3/4" (H)
Shutoffs: ee,ff,gg,hh,oo,pp,ccc,ddd,ffff,gggg

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: DCDC
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 3000GDCDC

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 2 1/2
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 3
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 4
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 6
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 8
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 8
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 10
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300BF
Size: 10
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 2 1/2
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 3
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 4
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 6
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 8
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 8
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 10
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300GV
Size: 10
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NBF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NBF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NBF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NBF
Size: 6
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NBF
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NBF
Size: 10
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NGV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NGV
Size: 6
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NGV
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFColt 300NGV
Size: 10
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 2 1/2
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 3
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 4
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 6
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 8
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 8
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 10
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300BF
Size: 10
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 2 1/2
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 3
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 4
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 6
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 8
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 8
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 10
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300GV
Size: 10
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU), Ames LF2000BM3 3/4" (VU)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NBF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NBF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NBF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NBF
Size: 6
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NBF
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NBF
Size: 10
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Ames
Model: LFMaxim 300NGV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Size: 6
Manual: 9
Approved: 08-Jan-2014
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: Yes
Renewed: 08-Jan-2026
Model: LFMaxim 300NGV
Meters: (O)
Spare Parts Only: No
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Size: 8
Manual: 9
Approved: 08-Jan-2014
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: Yes
Renewed: 08-Jan-2026
Model: LFMaxim 300NGV
Meters: (O)
Spare Parts Only: No
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Size: 10
Manual: 9
Approved: 08-Jan-2014
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: Yes
Renewed: 08-Jan-2026
Model: LFMaxim 300NGV
Meters: (O)
Spare Parts Only: No
Bypass: Watts LF007M3QT 3/4" (H), Ames LF2000BM3 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: Maxim 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: Maxim 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Maxim 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Maxim 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 03-Nov-2004
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 03-Nov-2025
Model: Maxim 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4 (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: Maxim 300aBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Maxim 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Maxim 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Maxim 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Oct-2003
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 06-Oct-2024
Model: Maxim 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

2026 © University of Southern California

Type: DCDA
Size: 4
Manual: 9
Approved: 03-Nov-2004
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 03-Nov-2025
Model: Maxim 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4 (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (zzz)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: Maxim 300aGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 02-Mar-2025
Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(H)

Type: DCDA
Size: 4
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: Vu
0.25% Pb: No
Renewed: 02-Mar-2025

Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(V)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025

Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025

Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

2026 © University of Southern California

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024
Model: Maxim 300BF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 02-Mar-2025
Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(H)

Type: DCDA
Size: 4
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 02-Mar-2025

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4"(V)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

2026 © University of Southern California

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: Maxim 300GV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Maxim 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Maxim 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Maxim 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: Maxim 300NBF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 28-May-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: Maxim 300NBF
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H), Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (yyy)
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025
Model: Maxim 300NBF
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H), Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: Maxim 300NGV
Meters: (N),G,H,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: Maxim 300NGV
Meters: (N),G,H,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: Maxim 300NGV
Meters: (N),G,H,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025
Model: Maxim 300NGV
Meters: (N),G,H,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 28-May-2013
Shutoffs: (zzz),ssssss
Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025
Model: Maxim 300NGV
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Ames 2000BM3 3/4" (H), Watts 007M3QT 3/4" (H)

2026 © University of Southern California

Type: DCDA
Manufacturer: Ames
Model: Maxim 300NGV
Size: 10
Orientation: VUVD
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass: Ames 2000BM3 3/4" (H), Watts 007M3QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 10DCDA
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4S

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 10DCDA
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4S

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA
Size: 2 1/2
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA
Size: 2 1/2
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA6
Size: 2 1/2
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA6
Size: 2 1/2
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA7
Size: 2 1/2
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA7
Size: 2 1/2
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA8
Size: 2 1/2
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDA8
Size: 2 1/2
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ppp),qqq

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 2 1/2DCDAU
Size: 2 1/2
Orientation: VUVD
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA
Size: 3
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA
Size: 3
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA6
Size: 3
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA6
Size: 3
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA7
Size: 3
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA7
Size: 3
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA8
Size: 3
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDA8
Size: 3
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 3DCDAU
Size: 3
Orientation: VUVD
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 40600000
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Aug-1996
Renewed: 20-Aug-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060003

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060003
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 40600000

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060003
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 40600C3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 40600C3
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Aug-1996
Renewed: 20-Aug-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060003

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060A03
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060AC3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060A03
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060AE3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060AC3
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-1993
Renewed: 13-Apr-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060A03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060AC6
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060AE3
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-1993
Renewed: 13-Apr-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060A03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060AE6
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060C03
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060CC3

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060C03
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060CE3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060CC3
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Jun-1993
Renewed: 02-Jun-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060C03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060CC6
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060CE3
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Jun-1993
Renewed: 02-Jun-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060C03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060CE6
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060E03
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060EC3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060E03
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060EE3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060EC3
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-1993
Renewed: 13-Apr-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060E03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060EC6
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060EE3
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-1993
Renewed: 13-Apr-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060E03

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060EE6
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060G03
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060GC3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060G03
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 4060GE3

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060GC3
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-1993
Renewed: 13-Apr-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060G03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060GC6
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060GE3
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Apr-1993
Renewed: 12-Apr-2026
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: uu,cc,mm
Notes: formerly 4060G03

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4060GE6
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-2000
Renewed: 01-Feb-2024
Bypass: Apollo/Conbraco 4010402 3/4" (H)
Shutoffs: mm[#1SOV], nnn[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA
Size: 4
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA
Size: 4
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA6
Size: 4
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA6
Size: 4
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA7
Size: 4
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA7
Size: 4
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA8
Size: 4
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDA8
Size: 4
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4DCDAU
Size: 4
Orientation: VUVD
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG 600U
Size: 2 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SGN

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG 600U
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SGN

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG 600U
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SGN

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG 600U
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SGN

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG 600U
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SGN

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** 4SG-600
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to DCDA4SG

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG-600
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SG

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG-600
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SG

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 4SG-600
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to DCDA4SG

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA
Size: 6
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA
Size: 6
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA6
Size: 6
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA6
Size: 6
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV],(nnn)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA7
Size: 6
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA7
Size: 6
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA8
Size: 6
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDA8
Size: 6
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 6DCDAU
Size: 6
Orientation: VUVD
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Apr-2001
Renewed: 10-Apr-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ll),mm

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 8DCDA
Size: 8
Orientation: H
Meters: (M),F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm),ll

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 8DCDA
Size: 8
Orientation: VU
Meters: (M),F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm),ll

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 8DCDA7
Size: 8
Orientation: H
Meters: (M),F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 8DCDA7
Size: 8
Orientation: VU
Meters: (M),F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm)[#1SOV], (qqq)[#2SOV]

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 8DCDA8
Size: 8
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: 8DCDA8
Size: 8
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (ppp),qqq

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4S
Size: 10
Orientation: H
Meters: (M),F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (mm),ll, xxxxx, zzzzz, bbbbbb, cccccc
Notes: formerly 10DCDA

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4S
Size: 10
Orientation: VU
Meters: (M),F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2003
Renewed: 16-Jan-2024
Bypass: Apollo/Conbraco 1/2DC 1/2" (VU), Apollo/Conbraco W432100 1/2" (VU)
Shutoffs: (mm),ll, xxxxx, zzzzz, bbbbbb, cccccc
Notes: formerly 10DCDA

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 2 1/2
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 2 1/2
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (VU), Apollo/Conbraco W432100 1/2" (V)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 3
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 3
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (VU), Apollo/Conbraco W432100 1/2" (V)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 4
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 4
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (VU), Apollo/Conbraco W432100 1/2" (V)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 6
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 6
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (VU), Apollo/Conbraco W432100 1/2" (V)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 8
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SG
Size: 8
Orientation: VU
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (VU), Apollo/Conbraco W432100 1/2" (V)
Shutoffs: (yyy)ppp,qqq,ttt,xxxxx,yyyyy,zzzzz,aaaaaa, xxxxxx
Notes: formerly 4SG-600

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDA4SGN
Size: 2 1/2
Orientation: VUVD
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Oct-2007
Renewed: 18-Oct-2025
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG 600U

Type: DCDA
Size: 3
Manual: 9
Approved: 18-Oct-2007
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG 600U

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 18-Oct-2025

Model: DCDA4SGN
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: Yes
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 18-Oct-2007
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG 600U

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 18-Oct-2025

Model: DCDA4SGN
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: Yes
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 18-Oct-2007
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG 600U

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 18-Oct-2025

Model: DCDA4SGN
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: Yes
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 18-Oct-2007
Shutoffs: (yyy)ppp,qqq,ttt
Notes: formerly 4SG 600U

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 18-Oct-2025

Model: DCDA4SGN
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: Yes
Bypass: Apollo/Conbraco 4S103 1/2" (H), Apollo/Conbraco W432100 1/2" (H)

Type: DCDA
Size: 2 1/2
Manual: 10
Approved: 30-Oct-2013
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 30-Oct-2025

Model: DCDALF4A
Meters: (P),G,H,I,J,K,L,M,N,O,Q,T
Spare Parts Only: No
Bypass: Apollo DCLF4A 1/2" (H)

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 2 1/2 | **Orientation:** VU | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 30-Oct-2013 | **Renewed:** 30-Oct-2025 | **Bypass:** Apollo DCLF4A 1/2" (VU)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 3 | **Orientation:** H | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 30-Oct-2013 | **Renewed:** 30-Oct-2025 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 3 | **Orientation:** VU | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 30-Oct-2013 | **Renewed:** 30-Oct-2025 | **Bypass:** Apollo DCLF4A 1/2" (VU)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 4 | **Orientation:** H | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 24-Jun-2013 | **Renewed:** 24-Jun-2025 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 4 | **Orientation:** VU | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 24-Jun-2013 | **Renewed:** 24-Jun-2025 | **Bypass:** Apollo DCLF4A 1/2" (VU)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 6 | **Orientation:** H | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 24-Jun-2013 | **Renewed:** 24-Jun-2025 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 6 | **Orientation:** VU | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 24-Jun-2013 | **Renewed:** 24-Jun-2025 | **Bypass:** Apollo DCLF4A 1/2" (VU)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 8 | **Orientation:** H | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 15-May-2014 | **Renewed:** 15-May-2026 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4A
Size: 8 | **Orientation:** VU | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 15-May-2014 | **Renewed:** 15-May-2026 | **Bypass:** Apollo DCLF4A 1/2" (VU)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4AN
Size: 2 1/2 | **Orientation:** VUVD | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 10-Jun-2014 | **Renewed:** 10-Jun-2026 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4AN
Size: 3 | **Orientation:** VUVD | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 08-Apr-2014 | **Renewed:** 08-Apr-2026 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4AN
Size: 4 | **Orientation:** VUVD | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 23-Jan-2014 | **Renewed:** 23-Jan-2026 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4AN
Size: 6 | **Orientation:** VUVD | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 10-Jun-2014 | **Renewed:** 10-Jun-2026 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA | **Manufacturer:** Apollo/Conbraco | **Model:** DCDALF4AN
Size: 8 | **Orientation:** VUVD | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 14-Mar-2014 | **Renewed:** 14-Mar-2026 | **Bypass:** Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AP
Size: 8
Orientation: H
Meters: (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Oct-2019
Renewed: 30-Oct-2025
Bypass: Apollo DCLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AP
Size: 8
Orientation: VU
Meters: (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Oct-2019
Renewed: 30-Oct-2025
Bypass: Apollo DCLF4A 1/2" (VU)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 2 1/2
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 09-Nov-2015
Renewed: 09-Nov-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (H)
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 2 1/2
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 09-Nov-2015
Renewed: 09-Nov-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (VU)
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 3
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 09-Nov-2015
Renewed: 09-Nov-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (H)
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 3
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 09-Nov-2015
Renewed: 09-Nov-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (VU)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 4
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 21-Sep-2015
Renewed: 21-Sep-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (H)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 4
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 21-Sep-2015
Renewed: 21-Sep-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (VU)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 6
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 21-Sep-2015
Renewed: 21-Sep-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (H)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

2026 © University of Southern California

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 6
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 21-Sep-2015
Renewed: 21-Sep-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (VU)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 8
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 21-Dec-2015
Renewed: 21-Dec-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (H)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: DCDA
Manufacturer: Apollo/Conbraco
Model: DCDALF4AR
Size: 8
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 21-Dec-2015
Renewed: 21-Dec-2024
Bypass: Apollo/Conbraco DCLF4A 1/2" (VU)

Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: DCDA
Manufacturer: Conbraco
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:

Notes: See Apollo/Conbraco

Type: DCDA
Manufacturer: Febco
Model: 806 Type YD
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:

Notes: model designation changed to 806YD

Type: DCDA
Manufacturer: Febco
Model: 806 Type YD
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 806YD

Type: DCDA
Manufacturer: Febco
Model: 806 Type YD
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 806YD

Type: DCDA
Manufacturer: Febco
Model: 806 Type YD
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 806YD

Type: DCDA
Manufacturer: Febco
Model: 806 Type YD
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 806YD

Type: DCDA
Manufacturer: Febco
Model: 806YD
Size: 3
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 26-Sep-1988
Renewed: 26-Sep-2024
Bypass: Febco 805Y 3/4" (H), Febco 805YB 3/4"(H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 806 Type YD

Type: DCDA
Manufacturer: Febco
Model: 806YD
Size: 4
Orientation: H
Meters: (F),A,B,C,D,E,G,H,I,J,K,L,M,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Jul-1987
Renewed: 10-Jul-2026
Bypass: Febco 805Y 3/4" (H), Febco 805YB 3/4"(H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 806 Type YD

2026 © University of Southern California

Type: DCDA
Manufacturer: Febco
Model: 806YD
Size: 6
Orientation: H
Meters: (F),A,B,C,D,E,G,H,I,J,K,L,M,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Jul-1987
Renewed: 10-Jul-2026
Bypass: Febco 805Y 3/4" (H), Febco 805YB 3/4"(H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 806 Type YD

Type: DCDA
Manufacturer: Febco
Model: 806YD
Size: 8
Orientation: H
Meters: (F),A,B,C,D,E,G,H,I,J,K,L,M,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Jul-1987
Renewed: 10-Jul-2026
Bypass: Febco 805Y 3/4" (H), Febco 805YB 3/4"(H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 806 Type YD

Type: DCDA
Manufacturer: Febco
Model: 806YD
Size: 10
Orientation: H
Meters: (F),A,B,C,D,E,G,H,I,J,K,L,M,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Jul-1987
Renewed: 10-Jul-2026
Bypass: Febco 805Y 3/4" (H), Febco 805YB 3/4"(H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 806 Type YD

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 2 1/2
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Mar-1997
Renewed: 19-Mar-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 2 1/2
Orientation: VU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jan-2000
Renewed: 05-Jan-2026
Bypass: Febco 805YB 3/4" (VU)
Shutoffs: (ff),mm,oo,pp,uu,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 3
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Mar-1997
Renewed: 19-Mar-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 3
Orientation: VU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jan-2000
Renewed: 05-Jan-2026
Bypass: Febco 805YB 3/4" (VU)
Shutoffs: (ff),mm,oo,pp,uu,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 4
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,nnn,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 4
Orientation: VU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Apr-1996
Renewed: 16-Apr-2026
Bypass: Febco 805YB 3/4" (VU)
Shutoffs: (ff),mm,oo,pp,uu,nnn,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 6
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,nnn,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 6
Orientation: VU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Apr-1996
Renewed: 16-Apr-2026
Bypass: Febco 805YB 3/4" (VU)
Shutoffs: (ff),mm,oo,pp,uu,nnn,zzz,cccc,ffff,gggg

2026 © University of Southern California

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 8
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-1995
Renewed: 04-Oct-2025
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,nnn,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856
Size: 8
Orientation: VU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jan-2000
Renewed: 05-Jan-2026
Bypass: Febco 805YB 3/4" (VU)
Shutoffs: (ff),mm,oo,pp,uu,nnn,zzz,cccc,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 856ST
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 856ST
Size: 2 1/2
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (VU)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 856ST
Size: 3
Orientation: H
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 856ST
Size: 3
Orientation: VU
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (VU)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 4 **Orientation:** H **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:** Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 4 **Orientation:** VU **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:** Watts 719QT 3/4" (VU)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 6 **Orientation:** H **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:** Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 6 **Orientation:** VU **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 09-Aug-2012 **Renewed:** 09-Aug-2024 **Bypass:** Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 8 **Orientation:** H **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 22-May-2012 **Renewed:** 22-May-2024 **Bypass:** Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 8 **Orientation:** VU **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 09-Aug-2012 **Renewed:** 09-Aug-2024 **Bypass:** Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA **Manufacturer:** Febco **Model:** 856ST
Size: 10 **Orientation:** H **Meters:** (O),H,I,J,K,L,M,N,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Sep-2013 **Renewed:** 03-Sep-2025 **Bypass:** Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

2026 © University of Southern California

Type: DCDA
Manufacturer: Febco
Model: 856ST
Size: 10
Orientation: VU
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 858
Size: 2
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass: Watts 007QT 1/2" (H)
Shutoffs: bbb,jjjj

Type: DCDA
Manufacturer: Febco
Model: 858
Size: 2
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass: Watts 007QT 1/2" (VU)
Shutoffs: bbb,jjjj

Type: DCDA
Manufacturer: Febco
Model: 858
Size: 2 1/2
Orientation: H
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass: Watts 007M2QT 3/4" (H), Watts 007M1QT 3/4" (H)
Shutoffs: (pp), gg, hh,ll, mm, oo, tt, uu, zz, fff

Type: DCDA
Manufacturer: Febco
Model: 858
Size: 2 1/2
Orientation: VU
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass: Watts 007M2QT 3/4" (VU)
Shutoffs: (pp), gg, hh,ll, mm, oo, tt, uu, zz, fff

Type: DCDA
Manufacturer: Febco
Model: 858
Size: 3
Orientation: H
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-2006
Renewed: 01-Aug-2024
Bypass: Watts 007M2QT 3/4" (H), Watts 007M1QT 3/4" (H)
Shutoffs: (pp), gg, hh,ll, mm, oo, tt, uu, zz, fff

Type: DCDA
Manufacturer: Febco
Model: 876
Size: 2 1/2
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Mar-1995
Renewed: 10-Mar-2025
Bypass: Febco 805YB 3/4" (H)
Shutoffs: ff,mm,oo,pp,uu,cccc,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876
Size: 3
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Mar-1995
Renewed: 10-Mar-2025
Bypass: Febco 805YB 3/4" (H)
Shutoffs: ff,mm,oo,pp,uu,cccc,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876
Size: 4
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: ff,mm,oo,pp,uu,cccc,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876
Size: 6
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-May-1994
Renewed: 04-May-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: ff,mm,oo,pp,uu,cccc,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876
Size: 8
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-May-1995
Renewed: 24-May-2025
Bypass: Febco 805YB 3/4" (H)
Shutoffs: ff,mm,oo,pp,uu,cccc,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876
Size: 10
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-1996
Renewed: 04-Oct-2023
Bypass: Febco 805YB 3/4" (H)
Shutoffs: ff,mm,oo,pp,uu,cccc,zzz,ffff,gggg

2026 © University of Southern California

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 2 1/2
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 2 1/2
Orientation: VUVU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 3
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 3
Orientation: VUVU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 4
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 4
Orientation: VUVU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 6
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 6
Orientation: VUVU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Mar-1996
Renewed: 08-Mar-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),ee,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 8
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jan-1997
Renewed: 06-Jan-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 8
Orientation: VUVU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jan-1997
Renewed: 06-Jan-2026
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 10
Orientation: VUVD
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jul-1997
Renewed: 11-Jul-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: DCDA
Manufacturer: Febco
Model: 876V
Size: 10
Orientation: VUVU
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jul-1997
Renewed: 11-Jul-2024
Bypass: Febco 805YB 3/4" (H)
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

2026 © University of Southern California

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 2 1/2
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 2 1/2
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 3
Orientation: VUVD
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 3
Orientation: VUVU
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 4
Orientation: VUVD
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 4
Orientation: VUVU
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 6
Orientation: VUVD
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 6
Orientation: VUVU
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 8
Orientation: VUVD
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Febco
Model: 876VST
Size: 8
Orientation: VUVU
Meters: (O),H,I,J,K,L,M,N,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-May-2012
Renewed: 22-May-2024
Bypass: Watts 719QT 3/4" (H)
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn

Type: DCDA
Manufacturer: Watts
Model: 007DCDA
Size: 2
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Jun-1997
Renewed: 16-Jun-2024
Bypass: Watts 007QT 1/2" (H)
Shutoffs: (bbb),jjjj,rrrrr
Notes: Previously Approved 8th Ed. (19 Apr 1996)

Type: DCDA
Manufacturer: Watts
Model: 007DCDA
Size: 2
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Jun-1997
Renewed: 16-Jun-2024
Bypass: Watts 007QT 1/2" (VU)
Shutoffs: (bbb),jjjj,rrrrr
Notes: Previously Approved 8th Ed. (10 Sept 1996)

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: 007DCDA
Size: 2 1/2
Orientation: H
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Oct-1993
Renewed: 11-Oct-2023
Bypass: Watts 007M2QT 3/4" (H), Watts 007M1QT 3/4" (H)
Shutoffs: (pp),gg,hh,ll,mm,oo,tt,uu,zz,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 007DCDA
Size: 2 1/2
Orientation: VU
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Aug-1996
Renewed: 27-Aug-2026
Bypass: Watts 007M2QT 3/4" (VU)
Shutoffs: (pp),gg,hh,ll,mm,oo,tt,uu,zz,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 007DCDA
Size: 3
Orientation: H
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Sep-1992
Renewed: 19-Sep-2025
Bypass: Watts 007M2QT 3/4" (H), Watts 007M1QT 3/4" (H)
Shutoffs: (pp),hh,mm,uu,zz,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 007DCDA-FP
Size: 2
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass: Ames 2000B 1/2" (H), Watts 007QT 1/2" (H)
Shutoffs: (eeeee)

Type: DCDA
Manufacturer: Watts
Model: 007M1DCDA
Size: 2
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Jun-2015
Renewed: 19-Jun-2024
Bypass: Watts 007QT 1/2" (H)
Shutoffs: (eeeee), bbb, jjjj,rrrrr

Type: DCDA
Manufacturer: Watts
Model: 007M1DCDA
Size: 2
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Jun-2015
Renewed: 19-Jun-2024
Bypass: Watts 007QT 1/2" (VU)
Shutoffs: (eeeee), bbb, jjjj,rrrrr

Type: DCDA
Manufacturer: Watts
Model: 709DCDA
Size: 3
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Apr-1987
Renewed: 19-Apr-2026
Bypass: Watts 007QT 1/2" (H), Watts 007M1QT 3/4" (H), Watts 709QT 3/4" (H)
Shutoffs: (pp),hh,uu,zz,eee,ffff,gggg,aaaaaaa
Notes: formerly 709DDC

Type: DCDA
Manufacturer: Watts
Model: 709DCDA
Size: 4
Orientation: H
Meters: (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jul-1987
Renewed: 27-Jul-2026
Bypass: Watts 007QT 1/2" (H), Watts 007M1QT 3/4" (H), Watts 709QT 3/4" (H)
Shutoffs: (pp),hh,uu,zz,eee,ffff,gggg,aaaaaaa
Notes: formerly 709DDC

Type: DCDA
Manufacturer: Watts
Model: 709DCDA
Size: 4
Orientation: VU
Meters: (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Aug-1996
Renewed: 27-Aug-2026
Bypass: Watts 007QT 1/2" (VU), Watts 007M2QT 3/4" (VU)
Shutoffs: (pp),hh,uu,zz,eee,ffff,gggg,aaaaaaa
Notes: formerly 709DDC

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Watts | **Model:** 709DCDA

Size: 6 | **Orientation:** H | **Meters:** (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U

Manual: 6 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 27-Jul-1987 | **Renewed:** 27-Jul-2026 | **Bypass:** Watts 007QT 1/2" (H), Watts 007M1QT 3/4" (H), Watts 709QT 3/4" (H)

Shutoffs: (pp),hh,uu,zz,eee,ffff,gggg,aaaaaaa

Notes: formerly 709DDC

Type: DCDA | **Manufacturer:** Watts | **Model:** 709DCDA

Size: 6 | **Orientation:** VU | **Meters:** (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U

Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 05-Dec-1996 | **Renewed:** 05-Dec-2023 | **Bypass:** Watts 007QT 1/2" (VU)

Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Type: DCDA | **Manufacturer:** Watts | **Model:** 709DCDA

Size: 8 | **Orientation:** H | **Meters:** (N),A,B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U

Manual: 6 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 19-Apr-1987 | **Renewed:** 19-Apr-2026 | **Bypass:** Watts 007QT 1/2" (H), Watts 007M1QT 3/4" (H), Watts 709QT 3/4" (H)

Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Notes: formerly 709DDC

Type: DCDA | **Manufacturer:** Watts | **Model:** 709DCDA

Size: 8 | **Orientation:** VU | **Meters:** (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U

Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 05-Dec-1996 | **Renewed:** 05-Dec-2023 | **Bypass:** Watts 007QT 1/2" (VU)

Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Type: DCDA
Manufacturer: Watts
Model: 709DCDA
Size: 10
Orientation: H
Meters: (N),E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jul-1987
Renewed: 27-Jul-2026
Bypass: Watts 007QT 1/2" (H), Watts 007M1QT 3/4" (H), Watts 709QT 3/4" (H)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa
Notes: formerly 709DDC

Type: DCDA
Manufacturer: Watts
Model: 709DCDA
Size: 10
Orientation: VU
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass: Watts 007QT 1/2" (VU)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Type: DCDA
Manufacturer: Watts
Model: 709DDC
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 709DCDA

Type: DCDA
Manufacturer: Watts
Model: 709DDC
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 709DCDA

Type: DCDA
Manufacturer: Watts
Model: 709DDC
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 709DCDA

Type: DCDA
Manufacturer: Watts
Model: 709DDC
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 709DCDA

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: 709DDC
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 709DCDA

Type: DCDA
Manufacturer: Watts
Model: 709DDC
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 709DCDA

Type: DCDA
Manufacturer: Watts
Model: 757aDCDABF
Size: 2 1/2
Orientation: H
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Watts 007M3QT 3/4" (H)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Watts
Model: 757aDCDABF
Size: 2 1/2
Orientation: VU
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Watts 007M3QT 3/4" (VU)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Watts
Model: 757aDCDABF
Size: 3
Orientation: H
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Watts 007M3QT 3/4" (H)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Watts
Model: 757aDCDABF
Size: 3
Orientation: VU
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Watts 007M3QT 3/4" (VU)
Shutoffs: (yyy)

Type: DCDA
Manufacturer: Watts
Model: 757aDCDABF
Size: 4
Orientation: H
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-2003
Renewed: 06-Nov-2024
Bypass: Watts 007M3QT 3/4" (H)
Shutoffs: (yyy)

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 03-Nov-2004
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 03-Nov-2025
Model: 757aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4 (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: 757aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

2026 © University of Southern California

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 18-Jan-2026
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: 757aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 6
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025
Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

2026 © University of Southern California

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 757DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023

Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 6
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

2026 © University of Southern California

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024
Model: 757DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: 757NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: 757NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: 757NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024
Model: 757NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: 757NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: 757NDCDABF
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 757NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 757NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 757NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 757NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

2026 © University of Southern California

Type: DCDA
Size: 8
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: 757NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: 757NDCDAGV
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024

Model: 767aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024

Model: 767aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024

Model: 767aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024

Model: 767aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Aug-2024
Model: 767aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: 767aDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 767aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 767aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 767aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 767aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 4
Manual: 9
Approved: 06-Nov-2003
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 06-Nov-2024
Model: 767aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (H)

2026 © University of Southern California

Type: DCDA
Size: 4
Manual: 9
Approved: 18-Jan-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 18-Jan-2026
Model: 767aDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 4
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025

Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025

Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

2026 © University of Southern California

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 04-Oct-2005
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 04-Oct-2023
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V)

Type: DCDA
Size: 4
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 19-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 23-Mar-2025
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Mar-2025
Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

Type: DCDA
Size: 6
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 09-Mar-2025

Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H & VU)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000 BM3 (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 17-Sep-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 17-Sep-2024

Model: 767DCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (V), Ames 2000 BM3 (V)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 767NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

2026 © University of Southern California

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 767NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 767NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: 767NDCDABF
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 28-May-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: 767NDCDABF
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: 767NDCDABF
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 767NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 767NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 767NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 6
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 03-Jan-2025

Model: 767NDCDAGV
Meters: (N),G,H,I,J,K,L,M,O,P,Q,T
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H)

Type: DCDA
Size: 8
Manual: 9
Approved: 28-May-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: 767NDCDAGV
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 10
Manual: 9
Approved: 28-May-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2025

Model: 767NDCDAGV
Meters: (N), H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 007M3QT 3/4" (H), Ames 2000BM3 3/4" (H)

Type: DCDA
Size: 4
Manual: 8
Approved: 20-May-1992
Shutoffs: pp,hh,mm,uu,zz

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-May-2025

Model: 770DCDA
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 007M1QT 3/4" (H)

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: 770DCDA
Size: 8
Orientation: H
Meters: (N),D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: oo,gg,hh,ll,mm,pp,tt,uu

Type: DCDA
Manufacturer: Watts
Model: 772DCDA
Size: 4
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Aug-1992
Renewed: 01-Aug-2025
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: oo

Type: DCDA
Manufacturer: Watts
Model: 772DCDA
Size: 10
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: oo

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 2 1/2
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1995
Renewed: 16-Jan-2026
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1995
Renewed: 16-Jan-2026
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-May-1995
Renewed: 16-Jan-2026
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass: Watts 007M1QT 3/4" (H)), Watts 007M3QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Sep-1996
Renewed: 16-Sep-2026
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (mm),ee,ff,gg,hh,ll,oo,pp,tt,uu,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 10
Orientation: H
Meters: (J),C,E,F,G,H,I,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Feb-2001
Renewed: 16-Feb-2025
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (ll),mm,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 12
Orientation: H
Meters: (N),H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass: Ames 2000BM3 3/4" (H); Watts 007M3QT 3/4" (H)
Shutoffs: (mm), ll

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: 774DCDA
Size: 12
Orientation: VU
Meters: (N),H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass: Ames 2000BM3 3/4" (H); Watts 007M3QT 3/4" (H)
Shutoffs: (mm), ll

Type: DCDA
Manufacturer: Watts
Model: 774DCDA-1
Size: 12
Orientation: H
Meters: (N),H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass: Ames 200B 3/4" (H); Watts 719QT 3/4" (H)
Shutoffs: (mm), ll

Type: DCDA
Manufacturer: Watts
Model: 774DCDA-1
Size: 12
Orientation: VU
Meters: (N), H,I,J,K,L,M,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass: Ames 200B 3/4" (VU); Watts 719QT 3/4" (VU)
Shutoffs: (mm), ll

Type: DCDA
Manufacturer: Watts
Model: 774XDCDA
Size: 2 1/2
Orientation: H
Meters: (M),N,O,P,Q
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (mm),ee,ff,gg,hh,ll,oo,pp,tt,uu,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: 774XDCDA
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-May-1995
Renewed: 24-May-2025
Bypass: Watts 007M2QT 3/4: (H), Ames 2000B 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,uu,ccc,ddd,ffff,gggg

---

Type: DCDA
Manufacturer: Watts
Model: 774XDCDA
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Sep-1992
Renewed: 09-Sep-2025
Bypass: Watts 007M1QT 3/4" (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 2 1/2
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 3
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 4
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 6
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 8
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 8
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 10
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDABF
Size: 10
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 2 1/2
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 3
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 4
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 6
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 8
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 8
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 10
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757DCDAGV
Size: 10
Orientation: VU
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (VU)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDABF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDABF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDABF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDABF
Size: 6
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDABF
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDABF
Size: 10
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDAGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDAGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDAGV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDAGV
Size: 6
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDAGV
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA
Manufacturer: Watts
Model: LF757NDCDAGV
Size: 10
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF007M3QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 2 1/2 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 22-Jun-2005 | **Renewed:** 22-Jun-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 2 1/2 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 2 1/2 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 22-Jun-2005 | **Renewed:** 22-Jun-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 2 1/2 | **Orientation:** VU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 3 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 22-Jun-2005 | **Renewed:** 22-Jun-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 3 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 3 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 22-Jun-2005 | **Renewed:** 22-Jun-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 3 | **Orientation:** VU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 4 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 16-Mar-2004 | **Renewed:** 16-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 4 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA

Size: 4 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 16-Mar-2004 | **Renewed:** 16-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA

Size: 4 | **Orientation:** VU | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA

Size: 6 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Nov-2003 | **Renewed:** 25-Nov-2024 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA

Size: 6 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA

Size: 6 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Nov-2003 | **Renewed:** 25-Nov-2024 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

2026 © University of Southern California

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADA
Size: 6 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADA
Size: 8 **Orientation:** H **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Feb-2004 **Renewed:** 12-Feb-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADA
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADA
Size: 8 **Orientation:** VU **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Feb-2004 **Renewed:** 12-Feb-2025 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADA
Size: 8 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADA
Size: 10 **Orientation:** H **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 06-Apr-2006 **Renewed:** 06-Apr-2024 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 10 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 10 | **Orientation:** VU | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 06-Apr-2006 | **Renewed:** 06-Apr-2024 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADA
Size: 10 | **Orientation:** VU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # V39030; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 2 1/2 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 2 1/2 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 2 1/2 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 2 1/2 | **Orientation:** VU | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 3 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 3 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 3 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADAR
Size: 3 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADAR
Size: 4 **Orientation:** H **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 25-Mar-2010 **Renewed:** 25-Mar-2025 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADAR
Size: 4 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADAR
Size: 4 **Orientation:** VU **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 25-Mar-2010 **Renewed:** 25-Mar-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ADAR
Size: 4 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 6 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 6 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 6 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 6 | **Orientation:** VU | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 8 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 57 7/8" and max. 86"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 8 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 57 7/8" and max. 86" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 8 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 57 7/8" and max. 86"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 8 | **Orientation:** VU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 57 7/8" and max. 86" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 10 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 61 3/8" and max. 100 5/8"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR
Size: 10 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 61 3/8" and max. 100 5/8" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 10 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 61 3/8" and max. 100 5/8"

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ADAR

Size: 10 | **Orientation:** VU | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 61 3/8" and max. 100 5/8" and Lead free compliant version: Starting Serial # E00687; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ASTDA

Size: 2 1/2 | **Orientation:** H | **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T

Manual: 10 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 18-Apr-2013 | **Renewed:** 18-Apr-2025 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ASTDA

Size: 2 1/2 | **Orientation:** H | **Meters:** (O), M

Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350ASTDA

Size: 2 1/2 | **Orientation:** VU | **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T

Manual: 10 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 18-Apr-2013 | **Renewed:** 18-Apr-2025 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 2 1/2 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 3 **Orientation:** H **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 10 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 18-Apr-2013 **Renewed:** 18-Apr-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 3 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 3 **Orientation:** VU **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 10 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 18-Apr-2013 **Renewed:** 18-Apr-2025 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 3 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 4 **Orientation:** H **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 10 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 18-Apr-2013 **Renewed:** 18-Apr-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

2026 © University of Southern California

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 4 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 4 **Orientation:** VU **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 10 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 18-Apr-2013 **Renewed:** 18-Apr-2025 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 4 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 6 **Orientation:** H **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 10 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2013 **Renewed:** 03-Jul-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 6 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 6 **Orientation:** VU **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 10 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2013 **Renewed:** 03-Jul-2025 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 6 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # 1458B; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 8 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 10 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDA
Size: 10 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 2 1/2 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 31" and max. 47 1/8"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 2 1/2 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 31" and max. 47 1/8"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 3 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 31 1/2" and max. 48 1/8"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 3 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 31 1/2" and max. 48 1/8"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 4 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 32 5/8" and max. 62 1/4"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 4 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 32 5/8" and max. 62 1/4"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 6 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 39" and max. 71 1/4"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 6 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 39" and max. 71 1/4"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 8 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 10 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

Type: DCDA **Manufacturer:** Wilkins **Model:** 350ASTDAR
Size: 10 **Orientation:** VU **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 2 1/2 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 03-Apr-2002 | **Renewed:** 03-Apr-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 2 1/2 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 2 1/2 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 08-Oct-2002 | **Renewed:** 08-Oct-2023 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 2 1/2 | **Orientation:** VU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 3 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 03-Apr-2002 | **Renewed:** 03-Apr-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 3 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 03-Apr-2002 | **Renewed:** 03-Apr-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 3 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn

Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 3 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 08-Oct-2002 | **Renewed:** 08-Oct-2023 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 3 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 08-Oct-2002 | **Renewed:** 08-Oct-2023 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 3 | **Orientation:** VU | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn

Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 4 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 15-Sep-1999 | **Renewed:** 15-Sep-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 4 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 15-Sep-1999 | **Renewed:** 15-Sep-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 4 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn

Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 4 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 09-Sep-2000 | **Renewed:** 09-Sep-2024 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 4 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 09-Sep-2000 | **Renewed:** 09-Sep-2024 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 4 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 6 **Orientation:** H **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 18-Oct-1999 **Renewed:** 18-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 6 **Orientation:** H **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Oct-1999 **Renewed:** 18-Oct-2023 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 6 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 6 **Orientation:** VU **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 05-Jan-2000 **Renewed:** 05-Jan-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

2026 © University of Southern California

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 6 | **Orientation:** VU | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 05-Jan-2000 | **Renewed:** 05-Jan-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 6 | **Orientation:** VU | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (VU)

Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn

Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 8 | **Orientation:** H | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 03-Jul-2002 | **Renewed:** 03-Jul-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 8 | **Orientation:** H | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 03-Jul-2002 | **Renewed:** 03-Jul-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn

Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA

Size: 8 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)

Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn

Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 8 **Orientation:** VU **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Jan-2003 **Renewed:** 16-Jan-2024 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 8 **Orientation:** VU **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2003 **Renewed:** 16-Jan-2024 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 8 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 10 **Orientation:** H **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 28-Aug-2002 **Renewed:** 28-Aug-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 10 **Orientation:** H **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 28-Aug-2002 **Renewed:** 28-Aug-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 10 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 10 **Orientation:** VU **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Mar-2003 **Renewed:** 14-Mar-2024 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 10 **Orientation:** VU **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Mar-2003 **Renewed:** 14-Mar-2024 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www,zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 10 **Orientation:** VU **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (VU)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 350DA
Size: 12 **Orientation:** H **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Oct-2009 **Renewed:** 20-Oct-2024 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to Serial # N4230

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 12 | **Orientation:** H | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 20-Oct-2009 | **Renewed:** 20-Oct-2024 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),ssss,tttt,vvvv,wwww,yyyy,zzzz,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and Lead free compliant version identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 350DA
Size: 12 | **Orientation:** H | **Meters:** (O)
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # N4231; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 450DA
Size: 4 | **Orientation:** VUVD | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 12-Apr-2000 | **Renewed:** 12-Apr-2024 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 450DA
Size: 4 | **Orientation:** VUVD | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # P07372; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA | **Manufacturer:** Wilkins | **Model:** 450DA
Size: 6 | **Orientation:** VUVD | **Meters:** (M),C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 24-May-2000 | **Renewed:** 24-May-2024 | **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

2026 © University of Southern California

Type: DCDA **Manufacturer:** Wilkins **Model:** 450DA
Size: 6 **Orientation:** VUVD **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # P07372; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450DA
Size: 8 **Orientation:** VUVD **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Aug-2004 **Renewed:** 03-Aug-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450DA
Size: 8 **Orientation:** VUVD **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # P07372; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450DA
Size: 10 **Orientation:** VUVD **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Aug-2004 **Renewed:** 03-Aug-2025 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450DA
Size: 10 **Orientation:** VUVD **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # P07372; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDA
Size: 4 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLDTCU 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDA
Size: 6 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLDTCU 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDA
Size: 8 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLDTCU 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDA
Size: 10 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLDTCU 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDAR
Size: 4 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDAR
Size: 6 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDAR
Size: 8 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: DCDA **Manufacturer:** Wilkins **Model:** 450STDAR
Size: 10 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 950XLD 3/4" (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

2026 © University of Southern California

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 2 1/2
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Jan-1994
Renewed: 02-Jan-2026
Bypass: Wilkins 950XL 3/4" (H), Wilkins 950 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 2 1/2
Orientation: VU
Meters: (M),D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Dec-1996
Renewed: 12-Dec-2023
Bypass: Wilkins 950XL 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Jan-1994
Renewed: 02-Jan-2026
Bypass: Wilkins 950XL 3/4" (H), Wilkins 950 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 3
Orientation: VU
Meters: (M),D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Dec-1996
Renewed: 12-Dec-2023
Bypass: Wilkins 950XL 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 4
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Jun-1993
Renewed: 09-Jun-2026
Bypass: Wilkins 950XL 3/4" (H), Wilkins 950 3/4" (H)
Shutoffs: hh,ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 4
Orientation: VU
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Dec-1996
Renewed: 12-Dec-2023
Bypass: Wilkins 950XL 3/4" (VU)
Shutoffs: hh,ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Jun-1993
Renewed: 09-Jun-2026
Bypass: Wilkins 950XL 3/4" (H), Wilkins 950 3/4" (H)
Shutoffs: hh,ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 6
Orientation: VU
Meters: (M),D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Dec-1996
Renewed: 12-Dec-2023
Bypass: Wilkins 950XL 3/4" (VU)
Shutoffs: hh,ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 8
Orientation: H
Meters: (M),E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Jun-1993
Renewed: 09-Jun-2026
Bypass: Wilkins 950XL 3/4" (H), Wilkins 950 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy.zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 8
Orientation: VU
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Dec-1996
Renewed: 12-Dec-2023
Bypass: Wilkins 950XL 3/4" (VU)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy.zzzz

2026 © University of Southern California

Type: DCDA
Manufacturer: Wilkins
Model: 950DA
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 23-Jun-1994
Renewed: 23-Jun-2024
Bypass: Wilkins 950XL 3/4" (H), Wilkins 950 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy.zzzz

Type: DCDA
Manufacturer: Wilkins
Model: 950XLTDA
Size: 2
Orientation: H
Meters: (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 19-May-2009
Renewed: 19-May-2024
Bypass: Wilkins 350D 3/4" (H)
Shutoffs: (bbb)

Type: DCDA
Manufacturer: Wilkins
Model: 950XLTDA
Size: 2
Orientation: VU
Meters: (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jun-2009
Renewed: 22-Jun-2024
Bypass: Wilkins 350D 3/4" (VU)
Shutoffs: (bbb)

Type: DCDA
Manufacturer: Wilkins
Model: 950XLTDABF
Size: 2
Orientation: H
Meters: (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 19-May-2009
Renewed: 19-May-2024
Bypass: Wilkins 350D 3/4" (H)
Shutoffs: (bbbbb), ccccc,pppppp

Type: DCDA
Manufacturer: Wilkins
Model: 950XLTDABF
Size: 2
Orientation: VU
Meters: (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jun-2009
Renewed: 22-Jun-2024
Bypass: Wilkins 350D 3/4" (VU)
Shutoffs: (bbbbb), ccccc,pppppp

Type: DCDA
Manufacturer: Wilkins
Model: DCDA
Size: 2 1/2
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Mar-1987
Renewed: 05-Mar-2026
Bypass: Wilkins 550A 3/4" (H)
Shutoffs: hh,ff,mm,uu,zz

Type: DCDA
Manufacturer: Wilkins
Model: DCDA
Size: 3
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Mar-1987
Renewed: 05-Mar-2026
Bypass: Wilkins 550A 3/4" (H)
Shutoffs: hh,ff,mm,uu,zz

Type: DCDA
Manufacturer: Wilkins
Model: DCDA
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-May-1988
Renewed: 18-May-2024
Bypass: Wilkins 550A 3/4" (H)
Shutoffs: hh,ff,mm,uu,zz

Type: DCDA
Manufacturer: Wilkins
Model: DCDA
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Jun-1988
Renewed: 01-Jun-2024
Bypass: Wilkins 550A 3/4" (H)
Shutoffs: hh,ff,mm,uu,zz

Type: DCDA-II
Manufacturer: Ames
Model: Deringer 30
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: DCDA-II
Manufacturer: Ames
Model: Deringer 30
Size: 2 1/2
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(VUH)
Shutoffs: (int)

Type: DCDA-II
Manufacturer: Ames
Model: Deringer 30
Size: 3
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

2026 © University of Southern California

Type: DCDA-II
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

2026 © University of Southern California

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026
Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: VU
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 1 1/2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (dddddd)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA24A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVA4A (HVD)

Type: DCDA-II
Size: 1 1/2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (dddddd)

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA24A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVA4A (VUH)

2026 © University of Southern California

Type: DCDA-II
Size: 2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (dddddd)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA24A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVA4A (HVD)

Type: DCDA-II
Size: 2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (dddddd)

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA24A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVA4A (VUH)

Type: DCDA-II
Size: 1 1/2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (eeeeee)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA2LF4A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVALF4A (HVD)

Type: DCDA-II
Size: 1 1/2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (eeeeee)

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA2LF4A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVALF4A (VUH)

Type: DCDA-II
Size: 2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (eeeeee)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA2LF4A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVALF4A (HVD)

Type: DCDA-II
Size: 2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (eeeeee)

Manufacturer: Apollo/Conbraco
Orientation: VU
0.25% Pb: No
Renewed: 31-Oct-2025

Model: DCDA2LF4A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVALF4A (VUH)

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 2 1/2
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 2 1/2
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (VUH)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 3
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 3
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (VUH)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 4
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 4
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (H)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

2026 © University of Southern California

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 6
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 6
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (H)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 8
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 8
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (H)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 10
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4A
Size: 12
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AN
Size: 10
Orientation: VUVD
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2022
Renewed: 12-Apr-2025
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (zzzzz), yyy,zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AN
Size: 12
Orientation: VUVD
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2022
Renewed: 12-Apr-2025
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 2 1/2
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 2 1/2
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (VUH)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 3
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

2026 © University of Southern California

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 3
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (VUH)

Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 4
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)

Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 4
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (H)

Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 6
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)

Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa

Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 6
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (H)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 8
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 8
Orientation: VU
Meters: (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (H)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: DCDA-II
Manufacturer: Apollo/Conbraco
Model: DCDA2LF4AR
Size: 10
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 65 3/4" and max. 100 5/8"

Type: DCDA-II
Manufacturer: Backflow Direct
Model: Deringer 30
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Dec-2015
Renewed: 21-Dec-2024
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

2026 © University of Southern California

Type: DCDA-II
Size: 2 1/2
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 21-Dec-2024
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 3
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 21-Dec-2024
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 3
Manual: 10
Approved: 21-Dec-2015
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 21-Dec-2024
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 30-Sep-2015
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 30-Sep-2024
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 30-Sep-2015
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 30-Sep-2024
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 30-Oct-2025
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 30-Oct-2025
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 23-Dec-2025
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 23-Dec-2025
Model: Deringer 30
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 2 1/2
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 2 1/2
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 3
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 3
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

2026 © University of Southern California

Type: DCDA-II
Size: 4
Manual: 10
Approved: 07-Dec-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 07-Dec-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 16-Jan-2026
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 16-Jan-2026
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 31-Jul-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 8
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2024
Model: Deringer 30G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 16-Jan-2026
Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 16-Jan-2020
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 16-Jan-2026
Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 31-Jul-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 31-Jul-2024

Model: Deringer 30GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 30-Oct-2025

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 4
Manual: 10
Approved: 30-Oct-2019
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 30-Oct-2025

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 23-Dec-2025

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: DCDA-II
Size: 6
Manual: 10
Approved: 23-Dec-2016
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: VU
0.25% Pb: Yes
Renewed: 23-Dec-2025

Model: Deringer 30X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(VUH)

Type: DCDA-II
Size: 2 1/2
Manual: 10
Approved: 01-May-2026
Shutoffs: (wwwwww)

Manufacturer: Beeco
Orientation: H
0.25% Pb: No
Renewed:

Model: FDCDA
Meters: (H),G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: No
Bypass: Beeco 3/4" BSC (HVD)

2026 © University of Southern California

Type: DCDA-II
Manufacturer: Beeco
Model: FDCDA
Size: 2 1/2
Orientation: VU
Meters: (H),G,I,J,K,L,M,N,O,P,Q,T
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass: Beeco 3/4" BSC (VUH)
Shutoffs: (wwwwww)

Type: DCDA-II
Manufacturer: Beeco
Model: FDCDA
Size: 3
Orientation: H
Meters: (H),G,I,J,K,L,M,N,O,P,Q,T
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass: Beeco 3/4" BSC (HVD)
Shutoffs: (wwwwww)

Type: DCDA-II
Manufacturer: Beeco
Model: FDCDA
Size: 3
Orientation: VU
Meters: (H),G,I,J,K,L,M,N,O,P,Q,T
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass: Beeco 3/4" BSC (VUH)
Shutoffs: (wwwwww)

Type: DCDA-II
Manufacturer: Beeco
Model: FDCDA
Size: 4
Orientation: H
Meters: (H),G,I,J,K,L,M,N,O,P,Q,T
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass: Beeco 3/4" BSC (HVD)
Shutoffs: (wwwwww)

Type: DCDA-II
Manufacturer: Beeco
Model: FDCDA
Size: 4
Orientation: VU
Meters: (H),G,I,J,K,L,M,N,O,P,Q,T
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass: Beeco 3/4" BSC (VUH)
Shutoffs: (wwwwww)

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 2 1/2
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 3
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 3
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 4
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 4
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 6
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Mar-2015
Renewed: 13-Mar-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 6
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Mar-2015
Renewed: 13-Mar-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 8
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

2026 © University of Southern California

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 8
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 10
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF856
Size: 10
Orientation: VU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 2 1/2
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 2 1/2
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 3
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 3
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 4
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 4
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 6
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 6
Orientation: VUVU
Meters: (O),J,K,L,M,N,P,Q
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 8
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 8
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 10
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-May-2018
Renewed: 29-May-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

2026 © University of Southern California

Type: DCDA-II
Manufacturer: Febco
Model: LF876V
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-May-2018
Renewed: 29-May-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 4
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 4
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 6
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 6
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 8
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 8
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 10
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876W
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 4
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 4
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 6
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 6
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 8
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

2026 © University of Southern California

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 8
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 10
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: DCDA-II
Manufacturer: Febco
Model: LF876WZ
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: PVB
Manufacturer: Ames
Model: A200
Size: 3/4
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Apr-1993
Renewed: 06-Apr-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: PVB
Manufacturer: Ames
Model: A200
Size: 1
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 25-May-1993
Renewed: 25-May-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: PVB
Manufacturer: Ames
Model: A200
Size: 1 1/2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jun-1993
Renewed: 21-Jun-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: PVB
Manufacturer: Ames
Model: A200
Size: 2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 21-Jun-1993
Renewed: 21-Jun-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: PVB
Manufacturer: Apollo/Conbraco
Model: 4050302
Size: 1/2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Sep-1991
Renewed: 06-Sep-2024
Bypass:
Shutoffs: dd

Type: PVB
Manufacturer: Apollo/Conbraco
Model: 4050402
Size: 3/4
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Sep-1991
Renewed: 06-Sep-2024
Bypass:
Shutoffs: (dd)

Type: PVB
Manufacturer: Apollo/Conbraco
Model: 4050502
Size: 1
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Sep-1991
Renewed: 06-Sep-2024
Bypass:
Shutoffs: (dd)

Type: PVB
Manufacturer: Apollo/Conbraco
Model: 4050602
Size: 1 1/4
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Dec-1993
Renewed: 01-Dec-2023
Bypass:
Shutoffs: (dd)

Type: PVB
Manufacturer: Apollo/Conbraco
Model: 4050702
Size: 1 1/2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Dec-1993
Renewed: 01-Dec-2023
Bypass:
Shutoffs: (dd)

Type: PVB
Manufacturer: Apollo/Conbraco
Model: 4050802
Size: 2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Dec-1993
Renewed: 01-Dec-2023
Bypass:
Shutoffs: (dd)

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to PVB4V

2026 © University of Southern California

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to PVB4V

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to PVB4V

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB
Size: 1 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to PVB4V

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to PVB4V

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB
Size: 2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to PVB4V

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB4A
Size: 1/2
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Nov-2010
Renewed: 18-Nov-2025
Bypass:
Shutoffs: (iiiii),sssss

Type: PVB
Manufacturer: Apollo/Conbraco
Model: PVB4A
Size: 3/4
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Nov-2010
Renewed: 18-Nov-2025
Bypass:
Shutoffs: (iiiii),sssss

Type: PVB
Size: 1
Manual: 9
Approved: 18-Nov-2010
Shutoffs: (iiiii),sssss
Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 18-Nov-2025
Model: PVB4A
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 27-Apr-2011
Shutoffs: (iiiii),sssss
Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 27-Apr-2026
Model: PVB4A
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 27-Apr-2011
Shutoffs: (iiiii),sssss
Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 27-Apr-2026
Model: PVB4A
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 30-Jan-2012
Shutoffs: (iiiii),sssss
Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 30-Jan-2024
Model: PVB4A
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 23-Sep-1999
Shutoffs: (dd)
Notes: formerly PVB
Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 23-Sep-2026
Model: PVB4V
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 9
Approved: 23-Sep-1999
Shutoffs: (dd)
Notes: formerly PVB
Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 23-Sep-2026
Model: PVB4V
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: PVB
Size: 1
Manual: 9
Approved: 23-Sep-1999
Shutoffs: (dd)
Notes: formerly PVB

Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 23-Sep-2026

Model: PVB4V
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 07-Oct-2002
Shutoffs: (dd)
Notes: formerly PVB

Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 07-Oct-2023

Model: PVB4V
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 07-Oct-2002
Shutoffs: (dd)
Notes: formerly PVB

Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 07-Oct-2023

Model: PVB4V
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 18-Jun-2003
Shutoffs: (dd)
Notes: formerly PVB

Manufacturer: Apollo/Conbraco
Orientation: VUH
0.25% Pb: No
Renewed: 18-Jun-2024

Model: PVB4V
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1/2
Manual: 10
Approved: 06-Sep-2018
Shutoffs: (int)

Manufacturer: ARI
Orientation: VUH
0.25% Pb: No
Renewed: 06-Sep-2024

Model: VB-501
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 3/4
Manual: 10
Approved: 13-Jun-2018
Shutoffs: (int)

Manufacturer: ARI
Orientation: VUH
0.25% Pb: No
Renewed: 13-Jun-2024

Model: VB-501
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Manufacturer: ARI
Model: VB-501
Size: 1
Orientation: VUH
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 13-Jun-2018
Renewed: 13-Jun-2024
Bypass:
Shutoffs: (int)

Type: PVB
Manufacturer: Conbraco
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: See Apollo/Conbraco

Type: PVB
Manufacturer: Febco
Model: 765
Size: 1/2
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Mar-1974
Renewed: 26-Mar-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo

Type: PVB
Manufacturer: Febco
Model: 765
Size: 3/4
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Mar-1974
Renewed: 26-Mar-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo,xxx

Type: PVB
Manufacturer: Febco
Model: 765
Size: 1
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Mar-1974
Renewed: 26-Mar-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo,xxx

Type: PVB
Manufacturer: Febco
Model: 765
Size: 1 1/4
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Mar-1974
Renewed: 26-Mar-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo

Type: PVB
Manufacturer: Febco
Model: 765
Size: 1 1/2
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Mar-1974
Renewed: 26-Mar-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo,xxx

2026 © University of Southern California

Type: PVB
Size: 2
Manual: 5
Approved: 26-Mar-1974
Shutoffs: (ii),fff,ooo,xxx
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 26-Mar-2025
Model: 765
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 01-Aug-2006
Shutoffs: (vv), xx,pppp,rrrrr
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 01-Aug-2024
Model: 767-FR
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 9
Approved: 01-Aug-2006
Shutoffs: (vv), xx,pppp,rrrrr
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 01-Aug-2024
Model: 767-FR
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1
Manual: 9
Approved: 01-Aug-2006
Shutoffs: (vv), xx,pppp,rrrrr
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 01-Aug-2024
Model: 767-FR
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 01-Aug-2006
Shutoffs: (vv), xx,pppp,rrrrr
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 01-Aug-2024
Model: 767-FR
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 01-Aug-2006
Shutoffs: (vv), xx,pppp,rrrrr
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 01-Aug-2024
Model: 767-FR
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 01-Aug-2006
Shutoffs: (vv), xx,pppp,rrrrr
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 01-Aug-2024
Model: 767-FR
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 04-May-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 04-May-2025

Model: LF767FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 3/4
Manual: 9
Approved: 04-May-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 04-May-2025

Model: LF767FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1
Manual: 9
Approved: 04-May-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 04-May-2025

Model: LF767FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 04-May-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 04-May-2025

Model: LF767FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 04-May-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 04-May-2025

Model: LF767FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 04-May-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 04-May-2025

Model: LF767FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size:
Manual:
Approved:
Notes: See Wilkins

Manufacturer: Neptune
Orientation:
0.25% Pb: No
Renewed:

Model:
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: PVB
Size: 1/2
Manual: 8
Approved: 18-Jul-1989
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 18-Jul-2025

Model: 800CMQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 8
Approved: 18-Jul-1989
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 18-Jul-2025

Model: 800CMQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1/2
Manual: 8
Approved: 09-Jul-1991
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 09-Jul-2024

Model: 800M2QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 8
Approved: 09-Jul-1991
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 09-Jul-2024

Model: 800M2QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1
Manual: 8
Approved: 09-Jul-1991
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 09-Jul-2024

Model: 800M2QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/4
Manual: 8
Approved: 25-Mar-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 25-Mar-2026

Model: 800M2QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/2
Manual: 8
Approved: 25-Mar-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 25-Mar-2026

Model: 800M2QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 2
Manual: 8
Approved: 25-Mar-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 25-Mar-2026

Model: 800M2QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1/2
Manual: 8
Approved: 24-Feb-1992
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 24-Feb-2025

Model: 800M3QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 8
Approved: 24-Feb-1992
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 24-Feb-2025

Model: 800M3QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 12-May-1998
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 12-May-2025

Model: 800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 3/4
Manual: 9
Approved: 12-May-1998
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 12-May-2025

Model: 800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1
Manual: 9
Approved: 01-Sep-1995
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 01-Sep-2025

Model: 800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 13-May-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 13-May-2024

Model: 800M4FR
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 13-May-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 13-May-2024
Model: 800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 13-May-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 13-May-2024
Model: 800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1/2
Manual: 8
Approved: 06-Sep-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 06-Sep-2026
Model: 800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 3/4
Manual: 8
Approved: 06-Apr-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 06-Apr-2026
Model: 800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1
Manual: 8
Approved: 25-May-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 25-May-2026
Model: 800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/4
Manual: 8
Approved: 24-May-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 24-May-2024
Model: 800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/2
Manual: 8
Approved: 21-Jun-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 21-Jun-2026
Model: 800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 2
Manual: 8
Approved: 21-Jun-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 21-Jun-2026

Model: 800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1/2
Manual: 8
Approved: 18-Jul-1989
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 18-Jul-2025

Model: 800MQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 8
Approved: 18-Jul-1989
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 18-Jul-2025

Model: 800MQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 3/4
Manual: 5
Approved: 14-Feb-1978
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 14-Feb-2026

Model: 800QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1
Manual: 5
Approved: 14-Feb-1978
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 14-Feb-2026

Model: 800QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/4
Manual: 5
Approved: 14-Feb-1978
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 14-Feb-2026

Model: 800QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1 1/2
Manual: 5
Approved: 14-Feb-1978
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 14-Feb-2026

Model: 800QT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: PVB
Size: 2
Manual: 5
Approved: 14-Feb-1978
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 14-Feb-2026
Model: 800QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 3/4
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1
Manual: 9
Approved: 05-Dec-2014
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 05-Dec-2023
Model: LF800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025
Model: LF800M4FR
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 3/4
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1
Manual: 9
Approved: 05-Dec-2014
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 05-Dec-2023

Model: LF800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/4
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1 1/2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF800M4QT
Meters:
Spare Parts Only: No
Bypass:

Type: PVB
Size: 1/2
Manual: 9
Approved: 17-Jul-1999
Shutoffs: (ii),ooo

Manufacturer: Wilkins
Orientation: VUH
0.25% Pb: No
Renewed: 17-Jul-2026

Model: 420
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: PVB
Manufacturer: Wilkins
Model: 420
Size: 3/4
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 17-Jul-1999
Renewed: 17-Jul-2026
Bypass:
Shutoffs: (ii),ooo

Type: PVB
Manufacturer: Wilkins
Model: 420
Size: 1
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2000
Renewed: 29-Sep-2024
Bypass:
Shutoffs: (ii),ooo

Type: PVB
Manufacturer: Wilkins
Model: 420XL
Size: 1/2
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: PVB
Manufacturer: Wilkins
Model: 420XL
Size: 3/4
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: PVB
Manufacturer: Wilkins
Model: 420XL
Size: 1
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 03-Aug-2011
Renewed: 03-Aug-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: PVB
Manufacturer: Wilkins
Model: 710
Size: 3/4
Orientation: VUH
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2020
Renewed: 16-Jan-2026
Bypass:
Shutoffs: (ooo)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: PVB
Manufacturer: Wilkins
Model: 710
Size: 1
Orientation: VUH
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2020
Renewed: 16-Jan-2026
Bypass:
Shutoffs: (ooo)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: PVB
Manufacturer: Wilkins
Model: 720A
Size: 1/2
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Aug-1978
Renewed: 28-Aug-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Beginning with Serial No. T00001 the test cocks were moved from the body to the shutoff valves. Testcocks: Female Threaded End or 45 degree male SAE flare.

Type: PVB
Manufacturer: Wilkins
Model: 720A
Size: 3/4
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Aug-1978
Renewed: 28-Aug-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Beginning with Serial No. T00001 the test cocks were moved from the body to the shutoff valves. Testcocks: Female Threaded End or 45 degree male SAE flare.

Type: PVB
Manufacturer: Wilkins
Model: 720A
Size: 1
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Aug-1978
Renewed: 28-Aug-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Beginning with Serial No. T00001 the test cocks were moved from the body to the shutoff valves. Testcocks: Female Threaded End or 45 degree male SAE flare.

Type: PVB
Manufacturer: Wilkins
Model: 720A
Size: 1 1/4
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Aug-1978
Renewed: 28-Aug-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Beginning with Serial No. T00001 the test cocks were moved from the body to the shutoff valves.

2026 © University of Southern California

Type: PVB
Manufacturer: Wilkins
Model: 720A
Size: 1 1/2
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Aug-1978
Renewed: 28-Aug-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Beginning with Serial No. T00001 the test cocks were moved from the body to the shutoff valves.

Type: PVB
Manufacturer: Wilkins
Model: 720A
Size: 2
Orientation: VUH
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: No
Approved: 28-Aug-1978
Renewed: 28-Aug-2026
Bypass:
Shutoffs: (ii),ooo
Notes: Beginning with Serial No. T00001 the test cocks were moved from the body to the shutoff valves.

Type: RP
Manufacturer: Ames
Model: 4000B
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously Approved 8th Ed. (26 May 1993)

Type: RP
Manufacturer: Ames
Model: 4000B
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 31-Oct-1992
Renewed: 31-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000B
Size: 1
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000B
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Aug-1993
Renewed: 24-Aug-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000B
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Aug-1993
Renewed: 24-Aug-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000B
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000B-FP
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: RP
Manufacturer: Ames
Model: 4000B-FP
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: RP
Manufacturer: Ames
Model: 4000B-FP
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)
Notes: Model Designation Changed to 4000BM2-FP

Type: RP
Manufacturer: Ames
Model: 4000B-FP
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)
Notes: Model Designation Changed to 4000BM2-FP

2026 © University of Southern California

Type: RP
Manufacturer: Ames
Model: 4000B-FP
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)
Notes: Model Designation Changed to 4000BM2-FP

Type: RP
Manufacturer: Ames
Model: 4000BM2
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-May-1998
Renewed: 18-May-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000BM2-FP
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: RP
Manufacturer: Ames
Model: 4000BM2-FP
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Mar-2018
Renewed: 15-Mar-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Mod 4000B-FP

Type: RP
Manufacturer: Ames
Model: 4000BM2-FP
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Mar-2018
Renewed: 15-Mar-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Mod 4000B-FP

Type: RP
Manufacturer: Ames
Model: 4000BM2-FP
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Mar-2018
Renewed: 15-Mar-2024
Bypass:
Shutoffs: (eeeee),uuuuuu
Notes: formerly Mod 4000B-FP

Type: RP
Manufacturer: Ames
Model: 4000BM3
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 4000BM3-FP
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Sep-2009
Renewed: 01-Sep-2024
Bypass:
Shutoffs: (eeeee)

Type: RP
Manufacturer: Ames
Model: 4000CIV
Size: 2 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu

Type: RP
Manufacturer: Ames
Model: 4000CIV
Size: 3
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu

Type: RP
Manufacturer: Ames
Model: 4000CIV
Size: 4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Jun-2000
Renewed: 19-Jun-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: RP
Manufacturer: Ames
Model: 4000CIV
Size: 6
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Jun-2000
Renewed: 19-Jun-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,eee

Type: RP
Manufacturer: Ames
Model: 4000CIV
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Jun-2000
Renewed: 19-Jun-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu

2026 © University of Southern California

Type: RP
Manufacturer: Ames
Model: 4000CIV
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Jun-2000
Renewed: 19-Jun-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu

Type: RP
Manufacturer: Ames
Model: 4000RP
Size: 4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Oct-1987
Renewed: 13-Oct-2023
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model RP

Type: RP
Manufacturer: Ames
Model: 4000RP
Size: 6
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Oct-1987
Renewed: 13-Oct-2023
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model RP

Type: RP
Manufacturer: Ames
Model: 4000RP
Size: 8
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Oct-1987
Renewed: 13-Oct-2023
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model RP

Type: RP
Manufacturer: Ames
Model: 4000RP
Size: 10
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Oct-1987
Renewed: 13-Oct-2023
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,ll,mm,oo,pp,uu,ccc,ddd,ffff,gggg
Notes: formerly Model RP

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Sep-1997
Renewed: 22-Sep-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Ames
Model: 4000SS
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Sep-1997
Renewed: 22-Sep-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: RP
Manufacturer: Ames
Model: 400B
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 400B
Size: 3/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 400B
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 400B
Size: 1
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 400B
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 400B
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Ames
Model: 400B
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Size: 1 1/2
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: 400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: 400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 05-Sep-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 05-Sep-2024

Model: 400B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-A
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: RP
Size: 2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-A
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 400B-Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Sep-2004
Renewed: 29-Sep-2025
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 13-Aug-2007
Renewed: 13-Aug-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Aug-2007
Renewed: 13-Aug-2025
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,sss,ttt,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Colt 400
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: zzz,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: RP
Manufacturer: Ames
Model: Colt 400BF
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 17-Sep-2007
Renewed: 17-Sep-2025
Bypass:
Shutoffs: (yyy)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400BF
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 17-Sep-2007
Renewed: 17-Sep-2025
Bypass:
Shutoffs: (yyy)

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Colt 400N
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

2026 © University of Southern California

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400N
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP **Manufacturer:** Ames **Model:** Colt 400Z
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: RP
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 03-Aug-2022
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2025

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 01-Oct-2024
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed:

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 01-Oct-2024
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed:

Model: Deringer 40GX
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40GX
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 03-Aug-2022
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2025

Model: Deringer 40X
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 40X
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF4000B
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF4000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF4000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF4000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 25-Sep-2013
Shutoffs: (hhhh)
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 25-Sep-2025
Model: LF4000BM2
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025
Model: LF4000BM2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 12-Mar-2019
Shutoffs: (eeeee),uuuuuu
Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025
Model: LF4000BM2-FP
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Ames
Model: LF4000BM2-FP
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: RP
Manufacturer: Ames
Model: LF4000BM2-FP
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs: (eeeee),uuuuuu

Type: RP
Manufacturer: Ames
Model: LF4000BM3
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 25-Sep-2013
Renewed: 25-Sep-2025
Bypass:
Shutoffs: (hhhh)

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Jan-2005
Renewed: 18-Jan-2026
Bypass:
Shutoffs: (ppp),qqq,aaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Jan-2005
Renewed: 18-Jan-2026
Bypass:
Shutoffs: kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 13-Aug-2007
Renewed: 13-Aug-2025
Bypass:
Shutoffs: (ppp),qqq,sss,ttt,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Aug-2007
Renewed: 13-Aug-2025
Bypass:
Shutoffs: cccc,dddd,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP
Manufacturer: Ames
Model: Maxim 400
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,sss,ttt,aaaa,bbbb,nnnnn

2026 © University of Southern California

Type: RP **Manufacturer:** Ames **Model:** Maxim 400
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-Jul-2009 **Renewed:** 22-Jul-2024 **Bypass:**
Shutoffs: zzz,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Jul-2009 **Renewed:** 22-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,aaaa,bbbb

Type: RP **Manufacturer:** Ames **Model:** Maxim 400
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-Jul-2009 **Renewed:** 22-Jul-2024 **Bypass:**
Shutoffs: zzz,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 15-Nov-2010 **Renewed:** 15-Nov-2025 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-Nov-2010 **Renewed:** 15-Nov-2025 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

2026 © University of Southern California

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP **Manufacturer:** Ames **Model:** Maxim 400N
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

2026 © University of Southern California

Type: RP **Manufacturer:** Ames **Model:** Maxim 400Z
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Jun-2013 **Renewed:** 14-Jun-2025 **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn,ssssss,qqqqqq,rrrrrr,tttttt

---

Type: RP **Manufacturer:** Ames **Model:** RP
Size: 4 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 4000RP

Type: RP **Manufacturer:** Ames **Model:** RP
Size: 6 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 4000RP

Type: RP **Manufacturer:** Ames **Model:** RP
Size: 8 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 4000RP

Type: RP **Manufacturer:** Ames **Model:** RP
Size: 10 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 4000RP

Type: RP **Manufacturer:** Ames **Model:** U400B
Size: 1 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 20-Jun-2006 **Renewed:** 20-Jun-2024 **Bypass:**
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP **Manufacturer:** Ames **Model:** U400B
Size: 1 **Orientation:** VD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 30-Aug-2006 **Renewed:** 30-Aug-2024 **Bypass:**
Shutoffs: (vv),xx,ooo,hhhh,pppp

2026 © University of Southern California

Type: RP
Size: 1 1/4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: U400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: U400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: U400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: U400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: U400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: U400B
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 20-Jun-2024

Model: U400B-A
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Ames
Model: U400B-A
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Ames
Model: U400B-A
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Ames
Model: U400B-A
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Ames
Model: U400B-A
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020002
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020003
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020005
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020102
Size: 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 03-May-1991
Renewed: 03-May-2024
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020199T
Size: 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40201A2
Size: 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Apr-1996
Renewed: 19-Apr-2026
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40201A2S
Size: 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RPS40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40201T2
Size: 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40201T2S
Size: 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RPS40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020202
Size: 3/8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 03-May-1991
Renewed: 03-May-2024
Bypass:
Shutoffs: dd

2026 © University of Southern California

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020299T
Size: 3/8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40202A2
Size: 3/8 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 19-Apr-1996 | **Renewed:** 19-Apr-2026 | **Bypass:**
Shutoffs: dd

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40202A2S
Size: 3/8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RPS40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40202T2
Size: 3/8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40202T2S
Size: 3/8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RPS40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020302
Size: 1/2 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 03-May-1991 | **Renewed:** 03-May-2026 | **Bypass:**
Shutoffs: dd

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020399T
Size: 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40203A2
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Apr-1996
Renewed: 19-Apr-2026
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40203A2S
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RPS40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40203T2
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40203T2S
Size: 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RPS40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020402
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020499T
Size: 3/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40204A2
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Nov-1991
Renewed: 27-Nov-2024
Bypass:
Shutoffs: dd

2026 © University of Southern California

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204A2S
Size: 3/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RPS40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204A2U
Size: 3/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40N

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204A2Z
Size: 3/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40Z

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204T2
Size: 3/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204T2S
Size: 3/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RPS40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204TC2
Size: 3/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40204TCU
Size: 3/4 | **Orientation:** VUVD | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 30-Nov-1998 | **Renewed:** 30-Nov-2025 | **Bypass:**
Shutoffs: (dd)

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020502
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020599T
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205A2
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Nov-1991
Renewed: 27-Nov-2024
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205A2S
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RPS40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205A2U
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 40205T2U

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205A2Z
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 40205T2Z

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205T2
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

2026 © University of Southern California

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205T2S
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RPS40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205T2U
Size: 1
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 15-Sep-1993
Renewed: 15-Sep-2026
Bypass:
Shutoffs: (dd)
Notes: formerly 40205A2U

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205T2Z
Size: 1
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 15-Sep-1993
Renewed: 15-Sep-2026
Bypass:
Shutoffs: (dd)
Notes: formerly 40205A2Z

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205TC2
Size: 1
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40205TCU
Size: 1
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 30-Nov-1998
Renewed: 30-Nov-2025
Bypass:
Shutoffs: (dd)

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020602
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Apr-1992
Renewed: 06-Apr-2025
Bypass:
Shutoffs: dd

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020699T
Size: 1 1/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40206A2
Size: 1 1/4 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 21-Jun-1993 | **Renewed:** 21-Jun-2026 | **Bypass:**
Shutoffs: dd

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40206A2U
Size: 1 1/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40N

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40206A2Z
Size: 1 1/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40Z

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40206T2
Size: 1 1/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40206T2U
Size: 1 1/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40N

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40206T2Z
Size: 1 1/4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40Z

2026 © University of Southern California

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020702
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Mar-1989
Renewed: 17-Mar-2025
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020799T
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40207A2
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1992
Renewed: 16-Sep-2025
Bypass:
Shutoffs: dd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40207A2U
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40U

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40207A2Z
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40Z

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40207T2
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 40207T2U
Size: 1 1/2
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40U

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40207T2Z
Size: 1 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40Z

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020802
Size: 2 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 17-Mar-1989 | **Renewed:** 17-Mar-2025 | **Bypass:**
Shutoffs: dd

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020899T
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208A2
Size: 2 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 16-Sep-1992 | **Renewed:** 16-Sep-2025 | **Bypass:**
Shutoffs: dd

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208A2U
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40U

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208A4
Size: 2 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 24-May-2000 | **Renewed:** 24-May-2024 | **Bypass:**
Shutoffs: rrr

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208AZ2
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40Z

2026 © University of Southern California

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208T2
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208T2U
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40U

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 40208T2Z
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40Z

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020902
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020903
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020905
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020A02
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020A03
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020A05
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020C02
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020C03
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020C05
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020E02
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** 4020E03
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to RP40

2026 © University of Southern California

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020G02
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4020G03
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to RP40

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4D-200
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-2009
Renewed: 11-Mar-2024
Bypass:
Shutoffs: (yyy), cccc, dddd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4D-200
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-2009
Renewed: 11-Mar-2024
Bypass:
Shutoffs: (yyy), cccc, dddd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4D-200
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-2009
Renewed: 11-Mar-2024
Bypass:
Shutoffs: (yyy), cccc, dddd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4D-200U
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-2009
Renewed: 11-Mar-2024
Bypass:
Shutoffs: (yyy), cccc, dddd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4D-200U
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-2009
Renewed: 11-Mar-2024
Bypass:
Shutoffs: (yyy), cccc, dddd

Type: RP
Manufacturer: Apollo/Conbraco
Model: 4D-200U
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Mar-2009
Renewed: 11-Mar-2024
Bypass:
Shutoffs: (yyy), cccc, dddd

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020199T, 40201T2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 3/8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020299T, 40202T2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 15-Sep-1994
Renewed: 15-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020399T, 40203T2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020499T, 40204T2, 40204TC2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020599T, 40205T2, 40205TC2

2026 © University of Southern California

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020699T, 40206T2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020799T, 40207T2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 16-Sep-1998
Renewed: 16-Sep-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 4020899T, 40208T2

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: (tt),bb,cc,ee,ll,mm,uu,mmm
Notes: formerly 4020902, 4020903, 4020905

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: (tt),bb,cc,ee,ll,mm,uu,mmm
Notes: formerly 4020002, 4020003, 4020005

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: (tt),bb,cc,ee.ll,mm,uu,mmm
Notes: formerly 4020A02, 4020A03, 4020A05

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Apr-1991
Renewed: 08-Apr-2024
Bypass:
Shutoffs: (tt),bb,ee,ll
Notes: formerly 4020C02, 4020C03, 4020C05

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Oct-1991
Renewed: 22-Oct-2024
Bypass:
Shutoffs: (tt),bb,cc,ee,ll,mm,uu
Notes: formerly 4020E02, 4020E03

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-1993
Renewed: 13-Apr-2026
Bypass:
Shutoffs: (tt),bb,cc,ee,ll,mm,uu
Notes: formerly 4020G02, 4020G03

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40N
Size: 3/4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Nov-1992
Renewed: 06-Nov-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 40204A2U

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40N
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 40206A2U, 40206T2U

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP40U
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (dd)
Notes: formerly 40207A2U, 40207T2U

2026 © University of Southern California

Type: RP
Size: 2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (dd)
Notes: formerly 40208A2U, 40208T2U

Manufacturer: Apollo/Conbraco
Orientation: VUVD
0.25% Pb: No
Renewed: 02-Feb-2025

Model: RP40U
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 06-Nov-1992
Shutoffs: (dd)
Notes: formerly 40204A2Z

Manufacturer: Apollo/Conbraco
Orientation: VUVU
0.25% Pb: No
Renewed: 06-Nov-2025

Model: RP40Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (dd)
Notes: formerly 40206A2Z, 40206T2Z

Manufacturer: Apollo/Conbraco
Orientation: VUVU
0.25% Pb: No
Renewed: 02-Feb-2025

Model: RP40Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (dd)
Notes: formerly 40207A2Z, 40207T2Z

Manufacturer: Apollo/Conbraco
Orientation: VUVU
0.25% Pb: No
Renewed: 02-Feb-2025

Model: RP40Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (dd)
Notes: formerly 40208AZ2, 40208T2Z

Manufacturer: Apollo/Conbraco
Orientation: VUVU
0.25% Pb: No
Renewed: 02-Feb-2025

Model: RP40Z
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 29-Nov-2011
Shutoffs: (iiiii),sssss

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 29-Nov-2023

Model: RP4A
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4A
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2011
Renewed: 14-Jun-2026
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4A
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Sep-2011
Renewed: 27-Sep-2026
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4A
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Dec-2013
Renewed: 11-Dec-2025
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4A
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 11-Dec-2013
Renewed: 11-Dec-2025
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4A
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 29-Nov-2011
Renewed: 29-Nov-2023
Bypass:
Shutoffs: (iiiii),sssss,wwwww

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4AN
Size: 3/4
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2020
Renewed: 16-Jan-2026
Bypass:
Shutoffs: (sssss), wwwww

Type: RP
Manufacturer: Apollo/Conbraco
Model: RP4AN
Size: 1
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jan-2019
Renewed: 16-Jan-2025
Bypass:
Shutoffs: (sssss), wwwww

2026 © University of Southern California

Type: RP
Size: 1/2
Manual: 9
Approved: 18-Nov-2010
Shutoffs: (jjjjj)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Nov-2025

Model: RPLF40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 18-Nov-2010
Shutoffs: (jjjjj)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Nov-2025

Model: RPLF40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 18-Nov-2010
Shutoffs: (jjjjj)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Nov-2025

Model: RPLF40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 18-Nov-2010
Shutoffs: (jjjjj)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Nov-2025

Model: RPLF40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 29-Nov-2011
Shutoffs: (jjjjj),ttttt,uuuuu

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 29-Nov-2023

Model: RPLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 14-Jun-2011
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 14-Jun-2026

Model: RPLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 27-Sep-2011
Shutoffs: (jjjjj),ttttt,vvvvv

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: Yes
Renewed: 27-Sep-2026

Model: RPLF4A
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Dec-2013
Renewed: 11-Dec-2025
Bypass:
Shutoffs: (jjjjj),ttttt,vvvvv

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Dec-2013
Renewed: 11-Dec-2025
Bypass:
Shutoffs: (jjjjj),ttttt,vvvvv

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Nov-2011
Renewed: 29-Nov-2023
Bypass:
Shutoffs: (jjjjj),ttttt,vvvvv

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 2 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 25-Feb-2014
Renewed: 25-Feb-2026
Bypass:
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 3
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 25-Feb-2014
Renewed: 25-Feb-2026
Bypass:
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 24-Jun-2013
Renewed: 24-Jun-2025
Bypass:
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP
Manufacturer: Apollo/Conbraco
Model: RPLF4A
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 24-Jun-2013
Renewed: 24-Jun-2025
Bypass:
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

2026 © University of Southern California

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4A
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Jan-2017 **Renewed:** 20-Jan-2026 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4A
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4A
Size: 12 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2021 **Renewed:** 05-Nov-2024 **Bypass:**
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4AN
Size: 3/4 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2020 **Renewed:** 16-Jan-2026 **Bypass:**
Shutoffs: (ttttt), vvvvv

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4AN
Size: 1 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2019 **Renewed:** 16-Jan-2025 **Bypass:**
Shutoffs: (ttttt), vvvvv

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4AN
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 27-Apr-2015 **Renewed:** 27-Apr-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP **Manufacturer:** Apollo/Conbraco **Model:** RPLF4AN
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 27-Apr-2015 **Renewed:** 27-Apr-2024 **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 3 | **Orientation:** VUVD | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 27-Apr-2015 | **Renewed:** 27-Apr-2024 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 3 | **Orientation:** VUVU | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 27-Apr-2015 | **Renewed:** 27-Apr-2024 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 4 | **Orientation:** VUVD | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 15-May-2014 | **Renewed:** 15-May-2026 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 4 | **Orientation:** VUVU | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 11-Jun-2014 | **Renewed:** 11-Jun-2026 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 6 | **Orientation:** VUVD | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 10-Jun-2014 | **Renewed:** 10-Jun-2026 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 6 | **Orientation:** VUVU | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 11-Jun-2014 | **Renewed:** 11-Jun-2026 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 8 | **Orientation:** VUVD | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 20-Mar-2017 | **Renewed:** 20-Mar-2026 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

2026 © University of Southern California

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 8 | **Orientation:** VUVU | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 20-Mar-2017 | **Renewed:** 20-Mar-2026 | **Bypass:**
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 10 | **Orientation:** VUVD | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 05-Nov-2021 | **Renewed:** 05-Nov-2024 | **Bypass:**
Shutoffs: (zzzzz), yyy,zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AN
Size: 12 | **Orientation:** VUVD | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 05-Nov-2021 | **Renewed:** 05-Nov-2024 | **Bypass:**
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AR
Size: 2 1/2 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AR
Size: 3 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AR
Size: 4 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AR
Size: 6 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:**
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AR
Size: 8 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 22-Feb-2018 | **Renewed:** 22-Feb-2024 | **Bypass:**
Shutoffs: (xxxxx), cccc, dddd, mmmm, nnnn, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPLF4AR
Size: 10 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 05-Nov-2021 | **Renewed:** 05-Nov-2024 | **Bypass:**
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 65 3/4" and max. 100 5/8"

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPS40
Size: 1/4 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 19-Apr-1996 | **Renewed:** 19-Apr-2026 | **Bypass:**
Shutoffs: (uuu)
Notes: formerly 40201A2S, 40201T2S

Type: RP | **Manufacturer:** Apollo/Conbraco | **Model:** RPS40
Size: 3/8 | **Orientation:** H | **Meters:**
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 19-Apr-1996 | **Renewed:** 19-Apr-2026 | **Bypass:**
Shutoffs: (uuu)
Notes: formerly 40202A2S, 40202T2S

2026 © University of Southern California

Type: RP
Size: 1/2
Manual: 8
Approved: 19-Apr-1996
Shutoffs: (dd)
Notes: formerly 40203A2S, 40203T2S

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 19-Apr-2026

Model: RPS40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 16-Aug-1994
Shutoffs: (uuu)
Notes: formerly 40204A2S

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 16-Aug-2024

Model: RPS40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 16-Aug-1994
Shutoffs: (uuu)
Notes: formerly 40204A2S, 40204T2S

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 16-Aug-2024

Model: RPS40
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 03-Jan-2013
Shutoffs: (ooooo), ii, ooo,ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: No
Renewed: 03-Jan-2025

Model: RP 500
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 18-Feb-2014
Shutoffs: (ooooo),ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2026

Model: RP 500
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 02-Mar-2007
Shutoffs: (ii),ooo, ooooo, ffffff

Manufacturer: ARI
Orientation: H
0.25% Pb: No
Renewed: 02-Mar-2025

Model: RP 500
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: ARI
Model: RP 500
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: RP
Manufacturer: ARI
Model: RP 500
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Mar-2007
Renewed: 02-Mar-2025
Bypass:
Shutoffs: (ii),ooo, ooooo, ffffff

Type: RP
Manufacturer: ARI
Model: RP 500
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: RP
Manufacturer: ARI
Model: RP 500
Size: 1 1/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: RP
Manufacturer: ARI
Model: RP 500
Size: 1 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: RP
Manufacturer: ARI
Model: RP 500
Size: 2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass:
Shutoffs: (ooooo), ffffff

Type: RP
Manufacturer: ARI
Model: RP 501
Size: 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2018
Renewed: 06-Sep-2024
Bypass:
Shutoffs: (int)

2026 © University of Southern California

Type: RP
Size: 3/4
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: RP 501
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: RP 501
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: RP 501
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: RP 501
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 10
Approved: 20-Mar-2017
Shutoffs: (int)

Manufacturer: ARI
Orientation: H
0.25% Pb: Yes
Renewed: 20-Mar-2026

Model: RP 501
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2 1/2
Manual: 10
Approved: 20-Jan-2017
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 20-Jan-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 20-Jan-2017
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 20-Jan-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 20-Jan-2017
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 20-Jan-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 03-Aug-2022
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2025

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 27-Jun-2017
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 27-Jun-2026

Model: Deringer 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2 1/2
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 01-Oct-2024
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed:

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 8
Manual: 10
Approved: 12-Mar-2019
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: Deringer 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 01-Oct-2024
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed:

Model: Deringer 40GX
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 12-Mar-2019
Shutoffs: (ssssss), tttttt

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025

Model: Deringer 40GX
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 03-Aug-2022
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2025

Model: Deringer 40X
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 27-Jun-2017
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 27-Jun-2026

Model: Deringer 40X
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2 1/2
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024

Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)

Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024

Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 15-Mar-2018
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 15-Mar-2024
Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2 1/2
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024
Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024
Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024
Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 12-Mar-2019
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025
Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 12-Mar-2019
Shutoffs: (qqqqqq), rrrrrr
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 12-Mar-2025
Model: Magnum 40GX
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Backflow Direct
Model: Magnum 40X
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Mar-2018
Renewed: 15-Mar-2024
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: BEECO
Model: Barracuda 40
Size: 2 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: RP
Manufacturer: BEECO
Model: Barracuda 40
Size: 3
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: RP
Manufacturer: BEECO
Model: Barracuda 40
Size: 4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: RP
Manufacturer: BEECO
Model: Barracuda 40
Size: 8
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs: (qqqqqq), rrrrrr

Type: RP
Manufacturer: BEECO
Model: Barracuda 40X
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs: (qqqqqq), rrrrrr, vvvvvv, wwwwww

Type: RP
Manufacturer: Cla-Val
Model: RP4
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jun-1989
Renewed: 22-Jun-2025
Bypass:
Shutoffs: (gg),hh,qq,rr

Type: RP
Manufacturer: Cla-Val
Model: RP4
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jun-1989
Renewed: 22-Jun-2025
Bypass:
Shutoffs: (gg),hh,qq,rr

Type: RP
Manufacturer: Conbraco
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: See Apollo/Conbraco

Type: RP
Manufacturer: Febco
Model: 825Y
Size: 3/4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Mar-1982
Renewed: 19-Mar-2024
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825Y
Size: 1
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 19-Mar-1982
Renewed: 19-Mar-2024
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825Y
Size: 1 1/4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 03-Jun-1982
Renewed: 01-Jun-2024
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: RP
Manufacturer: Febco
Model: 825Y
Size: 1 1/2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Aug-1982
Renewed: 06-Aug-2024
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

2026 © University of Southern California

Type: RP
Manufacturer: Febco
Model: 825Y
Size: 2
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Aug-1982
Renewed: 06-Aug-2024
Bypass:
Shutoffs: (ii),fff,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 3/4
Orientation: HVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 3/4
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 3/4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1
Orientation: HVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Mar-1990
Renewed: 05-Mar-2026
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1 1/2
Orientation: HVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1 1/2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

2026 © University of Southern California

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,jjj,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 2
Orientation: HVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 2
Orientation: VUH
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YA
Size: 2
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 08-May-1989
Renewed: 08-May-2025
Bypass:
Shutoffs: (ii),fff,ooo
Notes: Replaceable check valve seats starting with serial No. J000001

Type: RP
Manufacturer: Febco
Model: 825YAR
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jan-1993
Renewed: 22-Jan-2026
Bypass:
Shutoffs: ii,fff,jjj,ooo

Type: RP
Size: 3/4
Manual: 8
Approved: 22-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: HVD
0.25% Pb: No
Renewed: 22-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 22-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 22-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 22-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: VUVD
0.25% Pb: No
Renewed: 22-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 21-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 21-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 21-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: HVD
0.25% Pb: No
Renewed: 21-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 21-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 21-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 21-Jan-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: VUVD
0.25% Pb: No
Renewed: 21-Jan-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: HVD
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,jjj,ooo
Manufacturer: Febco
Orientation: VUVD
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,ooo
Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,ooo
Manufacturer: Febco
Orientation: HVD
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 19-Aug-1993
Shutoffs: ii,fff,ooo
Manufacturer: Febco
Orientation: VUH
0.25% Pb: No
Renewed: 19-Aug-2026
Model: 825YAR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Manufacturer: Febco
Model: 825YAR
Size: 2
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Aug-1993
Renewed: 19-Aug-2026
Bypass:
Shutoffs: ii,fff,ooo

Type: RP
Manufacturer: Febco
Model: 825YD
Size: 2 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-Feb-1989
Renewed: 24-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 825YD
Size: 3
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-Feb-1989
Renewed: 24-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 825YD
Size: 4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-Feb-1989
Renewed: 24-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 825YD
Size: 6
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-Feb-1989
Renewed: 24-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 825YD
Size: 8
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-Feb-1989
Renewed: 24-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 825YD
Size: 10
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 24-Feb-1989
Renewed: 24-Feb-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

2026 © University of Southern California

Type: RP
Size: 3/4
Manual: 8
Approved: 22-Jan-1993
Shutoffs: ii,fff,jjj

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 22-Jan-2026

Model: 825YR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 22-Jan-1993
Shutoffs: ii,fff,jjj

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 22-Jan-2026

Model: 825YR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 23-Jul-1993
Shutoffs: ii,fff,jjj

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 23-Jul-2026

Model: 825YR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 23-Jul-1993
Shutoffs: ii,fff

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 23-Jul-2026

Model: 825YR
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 09-Apr-1998
Shutoffs: (fff),ooo

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 09-Apr-2025

Model: 860
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 21-Nov-1997
Shutoffs: (fff),jjj,ooo

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 21-Nov-2024

Model: 860
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 21-Nov-1997
Shutoffs: (fff),jjj,ooo

Manufacturer: Febco
Orientation: H
0.25% Pb: No
Renewed: 21-Nov-2024

Model: 860
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Febco
Model: 860
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Jun-1998
Renewed: 04-Jun-2025
Bypass:
Shutoffs: (fff),jjj,ooo

Type: RP
Manufacturer: Febco
Model: 860
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Apr-1998
Renewed: 09-Apr-2025
Bypass:
Shutoffs: (fff),jjj,ooo

Type: RP
Manufacturer: Febco
Model: 860
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Apr-1998
Renewed: 09-Apr-2025
Bypass:
Shutoffs: (fff),ooo

Type: RP
Manufacturer: Febco
Model: 860
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Apr-1996
Renewed: 19-Apr-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu.zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 860
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Apr-1996
Renewed: 19-Apr-2026
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu.zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 860
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-May-1995
Renewed: 31-May-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 860
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Aug-1995
Renewed: 07-Aug-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

2026 © University of Southern California

Type: RP
Manufacturer: Febco
Model: 860
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 04-Oct-1995
Renewed: 04-Oct-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 860U
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: RP
Manufacturer: Febco
Model: 860U
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: RP
Manufacturer: Febco
Model: 860U
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: RP
Manufacturer: Febco
Model: 860U
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: RP
Manufacturer: Febco
Model: 860U
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: RP
Manufacturer: Febco
Model: 860U
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Oct-1998
Renewed: 12-Oct-2025
Bypass:
Shutoffs: (kkk)

Type: RP **Manufacturer:** Febco **Model:** 867
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 01-Aug-2006 **Renewed:** 01-Aug-2024 **Bypass:**
Shutoffs: (oo), gg, hh,ll, mm, pp, tt, uu, yy, fff

Type: RP **Manufacturer:** Febco **Model:** 867
Size: 3 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 01-Aug-2006 **Renewed:** 01-Aug-2024 **Bypass:**
Shutoffs: (oo), gg, hh,ll, mm, pp, tt, uu, yy, eee, fff

Type: RP **Manufacturer:** Febco **Model:** 880
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 24-May-1995 **Renewed:** 24-May-2025 **Bypass:**
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 24-May-1995 **Renewed:** 24-May-2025 **Bypass:**
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 10-Mar-1995 **Renewed:** 10-Mar-2025 **Bypass:**
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 19-May-1995 **Renewed:** 19-May-2025 **Bypass:**
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 19-May-1995 **Renewed:** 19-May-2025 **Bypass:**
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

2026 © University of Southern California

Type: RP **Manufacturer:** Febco **Model:** 880
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 04-Oct-1996 **Renewed:** 04-Oct-2023 **Bypass:**
Shutoffs: ee,ff,ll,mm,oo,pp,tt,uu,zzz,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880V
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 30-Jun-1995 **Renewed:** 30-Jun-2025 **Bypass:**
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880V
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 30-Jun-1995 **Renewed:** 30-Jun-2025 **Bypass:**
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880V
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 30-Jun-1995 **Renewed:** 30-Jun-2025 **Bypass:**
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880V
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 30-Jun-1995 **Renewed:** 30-Jun-2025 **Bypass:**
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880V
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 08-Aug-1995 **Renewed:** 08-Aug-2025 **Bypass:**
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP **Manufacturer:** Febco **Model:** 880V
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 08-Aug-1995 **Renewed:** 08-Aug-2025 **Bypass:**
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 880V
Size: 6
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jul-1995
Renewed: 05-Jul-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 880V
Size: 6
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Jul-1995
Renewed: 05-Jul-2025
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 880V
Size: 8
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Dec-1996
Renewed: 18-Dec-2023
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 880V
Size: 8
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Dec-1996
Renewed: 18-Dec-2023
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 880V
Size: 10
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Jun-1997
Renewed: 17-Jun-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: 880V
Size: 10
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Jun-1997
Renewed: 17-Jun-2024
Bypass:
Shutoffs: (ee),ff,ll,mm,oo,pp,tt,uu,nnn,zzz,cccc,ffff,gggg

Type: RP
Manufacturer: Febco
Model: LF825Y
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass:
Shutoffs: (qqqqq), hhhh

2026 © University of Southern California

Type: RP
Size: 1
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825Y
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825Y
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825Y
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: HVD
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUVD
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: HVD
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUVD
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: HVD
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUVD
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: HVD
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUH
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 25-Mar-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: VUVD
0.25% Pb: Yes
Renewed: 25-Mar-2025

Model: LF825YA
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF860
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (qqqqq), hhhh

Manufacturer: Febco
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025

Model: LF860
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Febco
Model: LF860
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: RP
Manufacturer: Febco
Model: LF860
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: RP
Manufacturer: Febco
Model: LF860
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: RP
Manufacturer: Febco
Model: LF860
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2010
Renewed: 18-Feb-2025
Bypass:
Shutoffs: (qqqqq), hhhh

Type: RP
Manufacturer: Febco
Model: LF860
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF860
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF860
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: RP
Manufacturer: Febco
Model: LF860
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF860
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF860
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 25-Sep-2013
Renewed: 25-Sep-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF860U
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: RP
Manufacturer: Febco
Model: LF860U
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: RP
Manufacturer: Febco
Model: LF860U
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: RP
Manufacturer: Febco
Model: LF860U
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: RP
Manufacturer: Febco
Model: LF860U
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: RP
Manufacturer: Febco
Model: LF860U
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Sep-2013
Renewed: 03-Sep-2025
Bypass:
Shutoffs: (ppppp), hhhh

Type: RP
Manufacturer: Febco
Model: LF880V
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF880V
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF880V
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF880V
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF880V
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 28-May-2013
Renewed: 28-May-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 28-May-2013 **Renewed:** 28-May-2025 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 03-Sep-2013 **Renewed:** 03-Sep-2025 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 03-Sep-2013 **Renewed:** 03-Sep-2025 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Nov-2013 **Renewed:** 26-Nov-2025 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Nov-2013 **Renewed:** 26-Nov-2025 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 29-May-2018 **Renewed:** 29-May-2024 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880V
Size: 10 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 29-May-2018 **Renewed:** 29-May-2024 **Bypass:**
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2020 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2020 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2020 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

2026 © University of Southern California

Type: RP **Manufacturer:** Febco **Model:** LF880W
Size: 10 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2020 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880WZ
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880WZ
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880WZ
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880WZ
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Mar-2020 **Renewed:** 26-Mar-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880WZ
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2020 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP **Manufacturer:** Febco **Model:** LF880WZ
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 15-May-2020 **Renewed:** 15-May-2026 **Bypass:**
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

Type: RP
Manufacturer: Febco
Model: LF880WZ
Size: 10
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Febco
Model: LF880WZ
Size: 10
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: MGI Controls
Model: 70RP
Size: 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Jun-2026
Renewed:
Bypass:
Shutoffs: (bbbbbbb)

Type: RP
Manufacturer: MGI Controls
Model: 70RPU
Size: 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Jun-2026
Renewed:
Bypass:
Shutoffs: (ccccccc)

Type: RP
Manufacturer: Neptune
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: See Wilkins

Type: RP
Manufacturer: Watts
Model: 009
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-Aug-1990
Renewed: 31-Aug-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 009
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 31-Aug-1990
Renewed: 31-Aug-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,eee,ffff,gggg

2026 © University of Southern California

Type: RP
Size: 1 1/4
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 009M1PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 009M1PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 009M1PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 30-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: 009M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 30-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: 009M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 19-Dec-1991
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 19-Dec-2024

Model: 009M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024

Model: 009M2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024
Model: 009M2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024
Model: 009M2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024
Model: 009M2-FP
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 07-Oct-2002
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 07-Oct-2023
Model: 009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2026
Model: 009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Sep-2024
Model: 009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Sep-2024
Model: 009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 26-Aug-2024

Model: 009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 31-Oct-1992
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: 009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 18-May-2025

Model: 009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 24-Aug-2026

Model: 009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 24-Aug-2026

Model: 009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 10-Sep-1996
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Sep-2026

Model: 009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 01-Sep-2009
Shutoffs: (eeeee)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Sep-2024

Model: 009M3-FP
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Watts
Model: 009M3QT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Oct-1999
Renewed: 18-Oct-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009PCQT
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Feb-1995
Renewed: 17-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009PCQT
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009PCQT
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009PCQT
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009PCQT
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009PCQT
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Aug-1995
Renewed: 07-Aug-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 3/8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Aug-1995
Renewed: 07-Aug-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Sep-1996
Renewed: 10-Sep-2026
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously approved 8th Ed. 26 May 1993

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 3/4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 1
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Jan-1988
Renewed: 11-Jan-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Aug-1988
Renewed: 09-Aug-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Aug-1988
Renewed: 09-Aug-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009QT
Size: 2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Aug-1988
Renewed: 09-Aug-2024
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 009SSM1PCQT
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: vv,xx,pppp

Type: RP
Manufacturer: Watts
Model: 009SSM1QT
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Dec-1991
Renewed: 19-Dec-2024
Bypass:
Shutoffs: vv,xx,pppp

Type: RP
Manufacturer: Watts
Model: 009SSPCQT
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,pppp

Type: RP
Manufacturer: Watts
Model: 009SSPCQT
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,pppp

Type: RP
Manufacturer: Watts
Model: 009SSPCQT
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Sep-1994
Renewed: 27-Sep-2024
Bypass:
Shutoffs: vv,xx,pppp

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: 009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: 009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: 009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: 009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: 009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: 009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Manufacturer: Watts
Model: 909
Size: 2 1/2
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Jun-1986
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 909
Size: 3
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Jun-1986
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg
Notes: formerly 909NRS/909OSY/909NRSRW/909OSYRW/909RW

Type: RP
Manufacturer: Watts
Model: 909
Size: 4
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 15-Jan-1982
Renewed: 15-Jan-2024
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg
Notes: formerly 909NRS/909OSY/909NRSRW/909OSYRW/909RW

Type: RP
Manufacturer: Watts
Model: 909
Size: 6
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jul-1981
Renewed: 06-Jul-2026
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,eee,ffff,gggg
Notes: formerly 909NRS/909OSY/909NRSRW/909OSYRW/909RW

Type: RP
Manufacturer: Watts
Model: 909
Size: 8
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jul-1981
Renewed: 06-Jul-2026
Bypass:
Notes: formerly 909NRS/909OSY/909NRSRW/909OSYRW/909RW

Type: RP
Manufacturer: Watts
Model: 909
Size: 10
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Jul-1981
Renewed: 06-Jul-2026
Bypass:
Notes: formerly 909NRS/909OSY/909NRSRW/909OSYRW/909RW

2026 © University of Southern California

Type: RP **Manufacturer:** Watts **Model:** 909BB
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 6 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 04-Feb-1983 **Renewed:** 04-Feb-2025 **Bypass:**
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: RP **Manufacturer:** Watts **Model:** 909BB
Size: 3 **Orientation:** H **Meters:**
Manual: 6 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 04-Feb-1983 **Renewed:** 04-Feb-2025 **Bypass:**
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ffff,gggg

Type: RP **Manufacturer:** Watts **Model:** 909HWQT
Size: 3/4 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 29-Sep-1979 **Renewed:** 29-Sep-2024 **Bypass:**
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP **Manufacturer:** Watts **Model:** 909HWQT
Size: 1 **Orientation:** H **Meters:**
Manual: 5 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 29-Sep-1979 **Renewed:** 29-Sep-2024 **Bypass:**
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP **Manufacturer:** Watts **Model:** 909HWQT
Size: 1 1/4 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 909M1HWQT

Type: RP **Manufacturer:** Watts **Model:** 909HWQT
Size: 1 1/2 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 909M1HWQT

Type: RP **Manufacturer:** Watts **Model:** 909HWQT
Size: 2 **Orientation:** **Meters:**
Manual: **0.25% Pb:** No **Spare Parts Only:** No
Approved: **Renewed:** **Bypass:**
Notes: model designation changed to 909M1HWQT

Type: RP
Manufacturer: Watts
Model: 909M1
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-May-1989
Renewed: 01-May-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,yy,ww,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 909M1
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-May-1989
Renewed: 01-May-2025
Bypass:
Shutoffs: (oo),gg,hh,ll,mm,pp,tt,uu,ww,yy,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 909M1HWQT
Size: 1 1/4
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Feb-1980
Renewed: 07-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,rrrrr
Notes: formerly 909HWQT

Type: RP
Manufacturer: Watts
Model: 909M1HWQT
Size: 1 1/2
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Feb-1980
Renewed: 07-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,rrrrr
Notes: formerly 909HWQT

Type: RP
Manufacturer: Watts
Model: 909M1HWQT
Size: 2
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Feb-1980
Renewed: 07-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,rrrrr
Notes: formerly 909HWQT

Type: RP
Manufacturer: Watts
Model: 909M1PCHWQT
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,rrrrr

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (vv),xx,ooo,hhhh,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 02-Feb-2025
Model: 909M1PCHWQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (vv),xx,ooo,hhhh,rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 02-Feb-2025
Model: 909M1PCHWQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 6
Approved: 15-Jan-1982
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: formerly 909QT
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2024
Model: 909M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 6
Approved: 15-Jan-1982
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: formerly 909QT
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2024
Model: 909M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 6
Approved: 15-Jan-1982
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: formerly 909QT
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2024
Model: 909M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3
Manual:
Approved:
Notes: model designation changed to 909
Manufacturer: Watts
Orientation:
0.25% Pb: No
Renewed:
Model: 909NRS
Meters:
Spare Parts Only: No
Bypass:

Type: RP | **Manufacturer:** Watts | **Model:** 909NRS
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRS
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRS
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRS
Size: 10 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRSRW
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRSRW
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRSRW
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

2026 © University of Southern California

Type: RP | **Manufacturer:** Watts | **Model:** 909NRSRW
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909NRSRW
Size: 10 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909OSY
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909OSY
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909OSY
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909OSY
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909OSY
Size: 10 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP
Manufacturer: Watts
Model: 909OSYRW
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909

Type: RP
Manufacturer: Watts
Model: 909OSYRW
Size: 4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909

Type: RP
Manufacturer: Watts
Model: 909OSYRW
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909

Type: RP
Manufacturer: Watts
Model: 909OSYRW
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909

Type: RP
Manufacturer: Watts
Model: 909OSYRW
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909

Type: RP
Manufacturer: Watts
Model: 909PCHWQT
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 909PCHWQT
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 909PCM1QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 909PCM1QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 909PCM1QT
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 02-Feb-1995
Renewed: 02-Feb-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 909PCQT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously Approved 8th Ed (2 February 1995) 9th Ed. for Ser. Nos. 464100 and higher

---

Type: RP
Manufacturer: Watts
Model: 909PCQT
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Serial number 464100 and higher

Type: RP
Manufacturer: Watts
Model: 909PCQT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously Approved 8th Ed (2 February 1995) 9th Ed. for Ser. Nos. 464100 and higher

Type: RP
Manufacturer: Watts
Model: 909PCQT
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously Approved 8th Ed (2 February 1995) 9th Ed. for Ser. Nos. 464100 and higher

---

Type: RP
Manufacturer: Watts
Model: 909QT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jun-1998
Renewed: 18-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously Approved 6th Ed. (15 Jan 1982) 9th Ed. For Ser. Nos. 461650 and higher

---

Type: RP
Manufacturer: Watts
Model: 909QT
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jun-1998
Renewed: 18-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Serial number 461650 and higher

Type: RP
Manufacturer: Watts
Model: 909QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jun-1998
Renewed: 18-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Previously Approved 6th Ed. (15 Jan 1982) 9th Ed. For Ser. Nos. 461650 and higher

---

Type: RP
Manufacturer: Watts
Model: 909QT
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jun-1998
Renewed: 18-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr
Notes: Serial number 461650 and higher

Type: RP
Manufacturer: Watts
Model: 909QT
Size: 1 1/4
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909M1QT

2026 © University of Southern California

Type: RP | **Manufacturer:** Watts | **Model:** 909QT
Size: 1 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909M1QT

Type: RP | **Manufacturer:** Watts | **Model:** 909QT
Size: 2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909M1QT

Type: RP | **Manufacturer:** Watts | **Model:** 909RW
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909RW
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909RW
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909RW
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP | **Manufacturer:** Watts | **Model:** 909RW
Size: 10 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 909

Type: RP
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: 919AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: 919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 05-Sep-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 05-Sep-2024

Model: 919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: 919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: 919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: 919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: 919QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 1
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919QT
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919ZQT
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919ZQT
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919ZQT
Size: 1 1/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919ZQT
Size: 1 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: 919ZQT
Size: 2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 957
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

Type: RP
Manufacturer: Watts
Model: 957
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Dec-2004
Renewed: 20-Dec-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: RP
Manufacturer: Watts
Model: 957
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Dec-2004
Renewed: 20-Dec-2025
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: RP
Manufacturer: Watts
Model: 957
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 13-Aug-2007
Renewed: 13-Aug-2025
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: RP
Manufacturer: Watts
Model: 957
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Aug-2007
Renewed: 13-Aug-2025
Bypass:
Shutoffs: zzz,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: RP
Manufacturer: Watts
Model: 957
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb

Type: RP
Manufacturer: Watts
Model: 957
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Jul-2009
Renewed: 22-Jul-2024
Bypass:
Shutoffs: zzz,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 957 BF
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 17-Jan-2008
Renewed: 17-Jan-2026
Bypass:
Shutoffs: (yyy)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957 BF
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 17-Jan-2008
Renewed: 17-Jan-2026
Bypass:
Shutoffs: (yyy)

Type: RP
Manufacturer: Watts
Model: 957N
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

Type: RP
Manufacturer: Watts
Model: 957N
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 957N
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Watts
Model: 957N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn

Type: RP
Manufacturer: Watts
Model: 957N
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP
Manufacturer: Watts
Model: 957N
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

Type: RP
Manufacturer: Watts
Model: 957N
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP
Manufacturer: Watts
Model: 957N
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

---

Type: RP
Manufacturer: Watts
Model: 957NQT
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957NQT
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957NQT
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957NQT
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 957NQT
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957NQT
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957QT
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957QT
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957QT
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Apr-2003
Renewed: 14-Apr-2024
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP **Manufacturer:** Watts **Model:** 957Z
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Watts **Model:** 957Z
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Watts **Model:** 957Z
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Watts **Model:** 957Z
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,aaaa,bbbb,nnnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Watts **Model:** 957Z
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP **Manufacturer:** Watts **Model:** 957Z
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 8
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

---

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP
Manufacturer: Watts
Model: 957Z
Size: 8
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

---

Type: RP
Manufacturer: Watts
Model: 957ZQT
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957ZQT
Size: 2 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957ZQT
Size: 3
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 957ZQT
Size: 3
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957ZQT
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 957ZQT
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Oct-2009
Renewed: 20-Oct-2024
Bypass:
Shutoffs: (fffff)
Notes: Check valve discs may be black EPDM or orange Silicone

---

Type: RP
Manufacturer: Watts
Model: 967
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP
Manufacturer: Watts
Model: 967
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Oct-2002
Renewed: 07-Oct-2023
Bypass:
Shutoffs: (ppp),qqq,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP
Manufacturer: Watts
Model: 967
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 18-Jan-2005
Renewed: 18-Jan-2026
Bypass:
Shutoffs: (ppp),qqq,aaaa,bbbb,gggg,kkkk,llll,mmmm,nnnn,nnnnn

Type: RP **Manufacturer:** Watts **Model:** 967
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 13-Aug-2007 **Renewed:** 13-Aug-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss, ttt, aaaa,bbbb,cccc,dddd,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP **Manufacturer:** Watts **Model:** 967
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Jul-2009 **Renewed:** 22-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,zzz,aaaa,bbbb,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP **Manufacturer:** Watts **Model:** 967
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Jul-2009 **Renewed:** 22-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,zzz,aaaa,bbbb,cccc,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn

---

Type: RP **Manufacturer:** Watts **Model:** 967N
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP **Manufacturer:** Watts **Model:** 967N
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP **Manufacturer:** Watts **Model:** 967N
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 14-Apr-2003 **Renewed:** 14-Apr-2024 **Bypass:**
Shutoffs: (ppp),qqq,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP **Manufacturer:** Watts **Model:** 967N
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 26-Jul-2021 **Renewed:** 26-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,zzz,aaaa,bbbb,dddd,eeee,ffff,gggg,kkkk,llll,mmmm,nnnn,nnnnn

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 967N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Watts
Model: 967N
Size: 4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn

Type: RP
Manufacturer: Watts
Model: 967N
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: ppp,qqq,aaaa,bbbb,nnnnn

Type: RP
Manufacturer: Watts
Model: 967N
Size: 4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: yyy,zzz,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn

Type: RP
Manufacturer: Watts
Model: 967N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP
Manufacturer: Watts
Model: 967N
Size: 6
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

---

Type: RP
Manufacturer: Watts
Model: 967N
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 26-Jul-2021
Renewed: 26-Jul-2024
Bypass:
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP | **Manufacturer:** Watts | **Model:** 967N
Size: 6 | **Orientation:** VUVU | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 26-Jul-2021 | **Renewed:** 26-Jul-2024 | **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

---

Type: RP | **Manufacturer:** Watts | **Model:** 967Z
Size: 2 1/2 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 26-Jul-2021 | **Renewed:** 26-Jul-2024 | **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP | **Manufacturer:** Watts | **Model:** 967Z
Size: 2 1/2 | **Orientation:** VUVU | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 14-Apr-2003 | **Renewed:** 14-Apr-2024 | **Bypass:**
Shutoffs: (ppp),qqq,yyy,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP | **Manufacturer:** Watts | **Model:** 967Z
Size: 3 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 26-Jul-2021 | **Renewed:** 26-Jul-2024 | **Bypass:**
Shutoffs: (ppp),qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP | **Manufacturer:** Watts | **Model:** 967Z
Size: 3 | **Orientation:** VUVU | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 14-Apr-2003 | **Renewed:** 14-Apr-2024 | **Bypass:**
Shutoffs: (ppp),qqq,zzz,aaaa,bbbb,dddd,eeee,gggg,kkkk,llll,mmmm,nnnn,nnnnn

---

Type: RP | **Manufacturer:** Watts | **Model:** 967Z
Size: 6 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 26-Jul-2021 | **Renewed:** 26-Jul-2024 | **Bypass:**
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP | **Manufacturer:** Watts | **Model:** 967Z
Size: 6 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 26-Jul-2021 | **Renewed:** 26-Jul-2024 | **Bypass:**
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 967Z
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: ppp, qqq, aaaa, bbbb,

Type: RP
Manufacturer: Watts
Model: 967Z
Size: 6
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass:
Shutoffs: (yyy), zzz, dddd, eeee, gggg, kkkk, llll, mmmm, nnnn

---

Type: RP
Manufacturer: Watts
Model: 990
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Nov-1992
Renewed: 01-Nov-2025
Bypass:
Shutoffs: oo,gg,hh,pp,tt,uu,yy

Type: RP
Manufacturer: Watts
Model: 990
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass:
Shutoffs: oo,gg,hh,pp,tt,uu,yy

Type: RP
Manufacturer: Watts
Model: 990QTFDA
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass:
Shutoffs: ww

Type: RP
Manufacturer: Watts
Model: 990QTFDA
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass:
Shutoffs: ww

Type: RP
Manufacturer: Watts
Model: 992
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Nov-1992
Renewed: 01-Nov-2025
Bypass:
Shutoffs: oo

Type: RP
Manufacturer: Watts
Model: 992
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass:
Shutoffs: oo

Type: RP
Manufacturer: Watts
Model: 994
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Watts
Model: 994
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 994
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Watts
Model: 994
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 994
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Watts
Model: 994
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Apr-1994
Renewed: 15-Apr-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: 994
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Sep-1997
Renewed: 22-Sep-2024
Bypass:
Shutoffs: (tt),ee,ff,gg,hh,pp,uu,ccc,ddd

Type: RP
Manufacturer: Watts
Model: 994
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Sep-1997
Renewed: 22-Sep-2024
Bypass:
Shutoffs: ll,mm,oo,ffff,gggg

Type: RP
Manufacturer: Watts
Model: 995QT
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-2000
Renewed: 13-Apr-2024
Bypass:
Shutoffs: int

Type: RP
Manufacturer: Watts
Model: 995QT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Apr-2000
Renewed: 13-Apr-2024
Bypass:
Shutoffs: int

Type: RP
Manufacturer: Watts
Model: 995QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jan-1999
Renewed: 14-Jan-2026
Bypass:
Shutoffs: int

Type: RP
Manufacturer: Watts
Model: 995QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 28-Mar-2002
Renewed: 28-Mar-2026
Bypass:
Shutoffs: int

Type: RP
Manufacturer: Watts
Model: 995QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 28-Mar-2002
Renewed: 28-Mar-2026
Bypass:
Shutoffs: int

Type: RP
Size: 1 1/4
Manual: 5
Approved: 07-Feb-1980
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 07-Feb-2025

Model: FAE909HWQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 5
Approved: 07-Feb-1980
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 07-Feb-2025

Model: FAE909HWQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 5
Approved: 07-Feb-1980
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 07-Feb-2025

Model: FAE909HWQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 6
Approved: 15-Jan-1982
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2024

Model: FAE909QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 6
Approved: 15-Jan-1982
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2024

Model: FAE909QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 6
Approved: 15-Jan-1982
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2024

Model: FAE909QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2 1/2
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (oo),ll,mm

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF009
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 3
Manual: 9
Approved: 12-Jan-2010
Shutoffs: (oo),ll,mm

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 12-Jan-2025

Model: LF009
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF009IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF009M2IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF009M2IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 25-Feb-2021
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 25-Feb-2024

Model: LF009M3IOTQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF009M3PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 11-Jan-2008
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 11-Jan-2026

Model: LF009M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF009PCQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: LF009QT
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 11-Jan-2008
Renewed: 11-Jan-2026
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF909
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Jan-2010
Renewed: 12-Jan-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Watts
Model: LF909
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Jan-2010
Renewed: 12-Jan-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Watts
Model: LF909
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jul-2012
Renewed: 27-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Watts
Model: LF909
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jul-2012
Renewed: 27-Jul-2024
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Watts
Model: LF909M1
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Jul-2010
Renewed: 01-Jul-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

---

Type: RP
Manufacturer: Watts
Model: LF909M1
Size: 10
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Jul-2010
Renewed: 01-Jul-2025
Bypass:
Shutoffs: (ll),mm,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,zzzzzz,aaaaaaa

Type: RP
Size: 12
Manual: 10
Approved: 01-May-2026
Shutoffs: (ll),mm
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed:
Model: LF909M1
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025
Model: LF909M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025
Model: LF909M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025
Model: LF909M1QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 3/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: No
Renewed: 13-Mar-2024
Model: LF909PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025
Model: LF909QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: VU
0.25% Pb: Yes
Renewed: 15-Nov-2025
Model: LF909QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 18-Feb-2010
Shutoffs: (hhhh),rrrrr
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 18-Feb-2025
Model: LF909QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Watts
Model: LF909QT
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919AQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919AQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919AQT
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919AQT
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919AQT
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Sep-2006
Renewed: 05-Sep-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919AQT
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Sep-2006
Renewed: 05-Sep-2024
Bypass:
Shutoffs: (hhhh),rrrrr

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 9
Approved: 12-Apr-2006
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 12-Apr-2024

Model: LF919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 12-Apr-2006
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: Yes
Renewed: 12-Apr-2024

Model: LF919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 12-Apr-2006
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 12-Apr-2024

Model: LF919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 12-Apr-2006
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: Yes
Renewed: 12-Apr-2024

Model: LF919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 14-Jun-2024

Model: LF919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (hhhh),rrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 14-Jun-2024

Model: LF919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: LF919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 3/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (hhhh),rrrrr

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919QT
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (hhhh),rrrrr

Type: RP
Manufacturer: Watts
Model: LF919ZQT
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919ZQT
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919ZQT
Size: 1 1/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LF919ZQT
Size: 1 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: LF919ZQT
Size: 2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 14-Jun-2006
Renewed: 14-Jun-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919AQT
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 1
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

2026 © University of Southern California

Type: RP
Size: 1
Manual: 9
Approved: 30-Aug-2006
Shutoffs: hhhh
Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 30-Aug-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 12-Apr-2006
Shutoffs: (vv),xx,ooo,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Apr-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 12-Apr-2006
Shutoffs: hhhh
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 12-Apr-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,pppp
Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 30-Aug-2006
Shutoffs: hhhh
Manufacturer: Watts
Orientation: VD
0.25% Pb: Yes
Renewed: 30-Aug-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 12-Apr-2006
Shutoffs: (vv),xx,ooo,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Apr-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 12-Apr-2006
Shutoffs: hhhh
Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 12-Apr-2024
Model: LFU919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2006
Renewed: 12-Apr-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,pppp

Type: RP
Manufacturer: Watts
Model: LFU919QT
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: hhhh

Type: RP
Manufacturer: Watts
Model: Magnum 40
Size: 2 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass:
Shutoffs: (int)

2026 © University of Southern California

Type: RP
Size: 3
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2 1/2
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 4
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 8
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40G
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 15-May-2020
Shutoffs: (qqqqqq), rrrrrr

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40GX
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 6
Manual: 10
Approved: 15-May-2020
Shutoffs: (int)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 15-May-2026

Model: Magnum 40X
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/4
Manual: 9
Approved: 19-Dec-2001
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 19-Dec-2025

Model: SS009M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/8
Manual: 9
Approved: 19-Dec-2001
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 19-Dec-2025

Model: SS009M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 9
Approved: 19-Dec-2001
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 19-Dec-2025

Model: SS009M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 9
Approved: 31-Jul-2001
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: Yes
Renewed: 31-Jul-2025

Model: SS009M3QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 18-May-1998
Shutoffs: (hhh)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 18-May-2025

Model: SS009QT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 3/4
Orientation: VDVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 3/4
Orientation: VDVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 3/4
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 1
Orientation: VDVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 1
Orientation: VDVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 1
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009APCQT
Size: 1
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 10-Dec-1993
Renewed: 10-Dec-2023
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009AQT
Size: 3/4
Orientation: VDVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Jun-1992
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009AQT
Size: 3/4
Orientation: VDVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Jun-1992
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009AQT
Size: 3/4
Orientation: VUVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Jun-1992
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009AQT
Size: 3/4
Orientation: VUVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 12-Jun-1992
Renewed: 12-Jun-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009AQT
Size: 1
Orientation: VDVD
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Jun-1992
Renewed: 12-Jun-2025
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U009AQT
Size: 1
Orientation: VDVU
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 12-Jun-1992
Renewed: 12-Jun-2025
Bypass:
Shutoffs: vv,xx,ooo,hhhh,pppp

2026 © University of Southern California

Type: RP
Size: 1
Manual: 8
Approved: 12-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 12-Jun-2025
Model: U009AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 12-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 12-Jun-2025
Model: U009AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1APCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 16-Dec-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 16-Dec-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 16-Dec-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 16-Dec-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 16-Dec-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 16-Dec-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 16-Dec-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 16-Dec-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: RP
Size: 2
Manual: 8
Approved: 09-Nov-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 09-Nov-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 09-Nov-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 09-Nov-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 09-Nov-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 09-Nov-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 09-Nov-1992
Shutoffs: vv,xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 09-Nov-2025
Model: U009M1AQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024
Model: U009M1PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 30-Jun-1992
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: U009M1QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 30-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: U009M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 30-Jun-1992
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 30-Jun-2025

Model: U009M1QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 15-Jan-2026

Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 15-Jan-2026

Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Jan-2026

Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 15-Jan-2026

Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 12-Sep-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 12-Sep-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 12-Sep-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 12-Sep-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2APCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 15-Jan-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 15-Jan-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Jan-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 15-Jan-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 24-Aug-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 24-Aug-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 24-Aug-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Aug-2026
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVD
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VDVU
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 26-Aug-2024
Model: U009M2AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2026
Model: U009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 12-Sep-1994
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 12-Sep-2024

Model: U009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 26-Aug-2024

Model: U009M2PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 16-Nov-1992
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 16-Nov-2025

Model: U009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 15-Jan-1999
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Jan-2026

Model: U009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 24-Aug-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 24-Aug-2026

Model: U009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 26-Aug-1997
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 26-Aug-2024

Model: U009M2QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1/2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 02-Feb-2025

Model: U009PCQT
Meters:
Spare Parts Only: No
Bypass:

2026 © University of Southern California

Type: RP
Size: 3/4
Manual: 8
Approved: 10-Dec-1993
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U009PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U009PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U009PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U009PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U009PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1/2
Manual: 8
Approved: 02-Feb-1995
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 02-Feb-2025

Model: U009QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U009QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U009QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: U009QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: U009QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: U009QT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 10-Dec-1993
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 10-Dec-2023

Model: U009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: RP
Size: 1 1/2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 27-Sep-1994
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2024

Model: U009SSPCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3/4
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 7
Approved: 11-Jan-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 11-Jan-2024

Model: U009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: U009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/2
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: U009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2
Manual: 7
Approved: 09-Aug-1988
Shutoffs: vv,xx,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 09-Aug-2024

Model: U009SSQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Manufacturer: Watts
Model: U909HWQT
Size: 3/4
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-1979
Renewed: 29-Sep-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U909HWQT
Size: 1
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 29-Sep-1979
Renewed: 29-Sep-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U909QT
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: Approved 6th Ed. (15 Jan 1982), 9th Ed. Approval for S/N 464100 and higher

---

Type: RP
Manufacturer: Watts
Model: U909QT
Size: 3/4
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: S/N 464100 and greater

Type: RP
Manufacturer: Watts
Model: U909QT
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: Approved 6th Ed. (15 Jan 1982), 9th Ed. Approval for S/N 464100 and higher

---

Type: RP
Manufacturer: Watts
Model: U909QT
Size: 1
Orientation: VU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Oct-1998
Renewed: 09-Oct-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp
Notes: S/N 464100 and greater

2026 © University of Southern California

Type: RP
Size: 3/4
Manual: 9
Approved: 14-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2024

Model: U919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: U919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: U919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: U919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 01-Jun-2024

Model: U919AQT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 01-Jun-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Jun-2024

Model: U919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 9
Approved: 30-Aug-2006
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VD
0.25% Pb: No
Renewed: 30-Aug-2024

Model: U919QT
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Watts
Model: U919QT
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U919QT
Size: 1 1/4
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U919QT
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U919QT
Size: 1 1/2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U919QT
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 01-Jun-2006
Renewed: 01-Jun-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: RP
Manufacturer: Watts
Model: U919QT
Size: 2
Orientation: VD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-2006
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 375
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 06-Apr-2011
Renewed: 06-Apr-2026
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Mar-2007
Renewed: 09-Mar-2025
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Mar-2007
Renewed: 09-Mar-2025
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Apr-2010
Renewed: 20-Apr-2025
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Apr-2010
Renewed: 20-Apr-2025
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Apr-2010
Renewed: 20-Apr-2025
Bypass:
Shutoffs: (int)

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 28-Sep-2001 **Renewed:** 28-Sep-2025 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 28-Sep-2001 **Renewed:** 28-Sep-2025 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 27-Mar-2000 **Renewed:** 27-Mar-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number L61205

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,ggggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 27-Jul-2000 **Renewed:** 27-Jul-2024 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,ggggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,ggggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 11-Nov-2002 **Renewed:** 11-Nov-2023 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,ggggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,ggggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Nov-2004 **Renewed:** 22-Nov-2025 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Oct-2008 **Renewed:** 20-Oct-2023 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number X18805

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number X18805 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Oct-2008 **Renewed:** 20-Oct-2023 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number X18805

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number X18805 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-Jun-2004 **Renewed:** 02-Jun-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number X18805

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number X18805 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 25-Nov-2003 **Renewed:** 25-Nov-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number X18805

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number X18805 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 15-Jun-2004 **Renewed:** 15-Jun-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number X18805

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number X18805 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-Mar-2007 **Renewed:** 02-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Up to serial number X18805

Type: RP **Manufacturer:** Wilkins **Model:** 375A
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number X18805 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375AMS
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375AMS
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375AMS
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AMS
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AMS
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AMS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Jun-2010 **Renewed:** 16-Jun-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8" Up to serial number X18805

Type: RP **Manufacturer:** Wilkins **Model:** 375AR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375AR
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Jun-2010 **Renewed:** 16-Jun-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,yyy,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375AR
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375AR
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 25-Mar-2010 **Renewed:** 25-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375AR
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 35 3/4" and max. 62 1/4"

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 375AR
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP
Manufacturer: Wilkins
Model: 375AR
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 42 1/2" and max. 71 1/4"

Type: RP
Manufacturer: Wilkins
Model: 375AR
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 25-Mar-2010
Renewed: 25-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP
Manufacturer: Wilkins
Model: 375AR
Size: 8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 57 7/8" and max. 86"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375AR
Size: 10 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375AR
Size: 10 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 09-Sep-2010 | **Renewed:** 09-Sep-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: Only Serial No G00110 and higher approved. These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 61 3/8" and max. 100 5/8"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ARMS
Size: 2 1/2 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 05-Nov-2014 | **Renewed:** 05-Nov-2023 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ARMS
Size: 3 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 05-Nov-2014 | **Renewed:** 05-Nov-2023 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 48 1/8"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ARMS
Size: 4 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 05-Nov-2014 | **Renewed:** 05-Nov-2023 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 35 3/4" and max. 62 1/4"

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375ARMS
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 42 1/2" and max. 71 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARMS
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 57 7/8" and max. 86"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARMS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 61 3/8" and max. 100 5/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARW1
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 1/4" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARW1
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 34 3/4" and max. 48 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARW1
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 35 3/4" and max. 62 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARW1
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 42 1/2" and max. 71 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARW1
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Apr-2019 **Renewed:** 25-Apr-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 57 7/8" and max. 86"

Type: RP **Manufacturer:** Wilkins **Model:** 375ARW1
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Apr-2019 **Renewed:** 25-Apr-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o
Notes: These have an Integral grooved spool between the #2 ck and #2 SOV with length: min. 61 3/8" and max. 100 5/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375AST
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375AST
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AST
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 31-May-2012 **Renewed:** 31-May-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AST
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 24-Jun-2013 **Renewed:** 24-Jun-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AST
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Nov-2013 **Renewed:** 26-Nov-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 375AST
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 26-Nov-2013 **Renewed:** 26-Nov-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTMS
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTMS
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTMS
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTMS
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTMS
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTMS
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTR
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 31" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTR
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Jun-2015 **Renewed:** 12-Jun-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 31 1/2" and max. 48 1/8"

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTR
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 31-May-2012 **Renewed:** 31-May-2024 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 32 5/8" and max. 62 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTR
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2013 **Renewed:** 05-Nov-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 39" and max. 71 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTR
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2014 **Renewed:** 23-Jan-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTR
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 23-Jan-2014 **Renewed:** 23-Jan-2026 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRMS
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 31" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRMS
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 31 1/2" and max. 48 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRMS
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 32 5/8" and max. 62 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRMS
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 39" and max. 71 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRMS
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRMS
Size: 10 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 05-Nov-2014 **Renewed:** 05-Nov-2023 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRW1
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2019 **Renewed:** 16-Jan-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 31" and max. 47 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRW1
Size: 3 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2019 **Renewed:** 16-Jan-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 31 1/2" and max. 48 1/8"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRW1
Size: 4 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2019 **Renewed:** 16-Jan-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 32 5/8" and max. 62 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRW1
Size: 6 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 16-Jan-2019 **Renewed:** 16-Jan-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 39" and max. 71 1/4"

Type: RP **Manufacturer:** Wilkins **Model:** 375ASTRW1
Size: 8 **Orientation:** H **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Apr-2019 **Renewed:** 25-Apr-2025 **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ASTRW1
Size: 10 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 25-Apr-2019 | **Renewed:** 25-Apr-2025 | **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ASTW1
Size: 2 1/2 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 16-Jan-2019 | **Renewed:** 16-Jan-2025 | **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ASTW1
Size: 3 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 16-Jan-2019 | **Renewed:** 16-Jan-2025 | **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ASTW1
Size: 4 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 16-Jan-2019 | **Renewed:** 16-Jan-2025 | **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ASTW1
Size: 6 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 16-Jan-2019 | **Renewed:** 16-Jan-2025 | **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375ASTW1
Size: 8 | **Orientation:** H | **Meters:**
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 25-Apr-2019 | **Renewed:** 25-Apr-2025 | **Bypass:**
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 375ASTW1
Size: 10
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 25-Apr-2019
Renewed: 25-Apr-2025
Bypass:
Shutoffs: (yyy),ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP
Manufacturer: Wilkins
Model: 375AW1
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP
Manufacturer: Wilkins
Model: 375AW1
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP
Manufacturer: Wilkins
Model: 375AW1
Size: 4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP
Manufacturer: Wilkins
Model: 375AW1
Size: 6
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: RP | **Manufacturer:** Wilkins | **Model:** 375AW1
Size: 8 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 25-Apr-2019 | **Renewed:** 25-Apr-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375AW1
Size: 10 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 25-Apr-2019 | **Renewed:** 25-Apr-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375B
Size: 1/2 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 08-Nov-2012 | **Renewed:** 08-Nov-2024 | **Bypass:**
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375B
Size: 3/4 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 08-Nov-2012 | **Renewed:** 08-Nov-2024 | **Bypass:**
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375B
Size: 1 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 08-Nov-2012 | **Renewed:** 08-Nov-2024 | **Bypass:**
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP | **Manufacturer:** Wilkins | **Model:** 375B
Size: 1 1/4 | **Orientation:** H | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 08-Nov-2012 | **Renewed:** 08-Nov-2024 | **Bypass:**
Shutoffs: (int)

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 375B
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375B
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375MS
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Jul-2003
Renewed: 03-Jul-2024
Bypass:
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Up to serial number L61205

Type: RP
Manufacturer: Wilkins
Model: 375MS
Size: 2 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Serial number L61205 and higher

Type: RP
Manufacturer: Wilkins
Model: 375MS
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 03-Jul-2003
Renewed: 03-Jul-2024
Bypass:
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Up to serial number L61205

Type: RP
Manufacturer: Wilkins
Model: 375MS
Size: 3
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,zzz,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Serial number L61205 and higher

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 29-Mar-2005 **Renewed:** 29-Mar-2026 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,vvv,www,zzz,dddd,eeee,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Up to serial number L61205

Type: RP **Manufacturer:** Wilkins **Model:** 375MS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk
Notes: Serial number L61205 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 375ST
Size: 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-Feb-2011 **Renewed:** 22-Feb-2026 **Bypass:**
Shutoffs: (int)

Type: RP **Manufacturer:** Wilkins **Model:** 375ST
Size: 3/4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 22-Feb-2011 **Renewed:** 22-Feb-2026 **Bypass:**
Shutoffs: (int)

Type: RP **Manufacturer:** Wilkins **Model:** 375ST
Size: 1 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 31-Oct-2011 **Renewed:** 31-Oct-2023 **Bypass:**
Shutoffs: int

Type: RP **Manufacturer:** Wilkins **Model:** 375W1
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn

Type: RP **Manufacturer:** Wilkins **Model:** 375W1
Size: 3 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RP **Manufacturer:** Wilkins **Model:** 375W1
Size: 4 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RP **Manufacturer:** Wilkins **Model:** 375W1
Size: 6 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 12-Mar-2019 **Renewed:** 12-Mar-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RP **Manufacturer:** Wilkins **Model:** 375W1
Size: 8 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Apr-2019 **Renewed:** 25-Apr-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RP **Manufacturer:** Wilkins **Model:** 375W1
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 25-Apr-2019 **Renewed:** 25-Apr-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,vvv,www,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RP **Manufacturer:** Wilkins **Model:** 375XL
Size: 1/2 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 07-Apr-2009 **Renewed:** 07-Apr-2024 **Bypass:**
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 375XL
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Mar-2007
Renewed: 09-Mar-2025
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375XL
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Mar-2007
Renewed: 09-Mar-2025
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375XL
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Apr-2010
Renewed: 20-Apr-2025
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375XL
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Apr-2010
Renewed: 20-Apr-2025
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375XL
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Apr-2010
Renewed: 20-Apr-2025
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375XLB
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: RP
Manufacturer: Wilkins
Model: 375XLB
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375XLB
Size: 1
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 375XLB
Size: 1 1/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375XLB
Size: 1 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 375XLB
Size: 2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Nov-2012
Renewed: 08-Nov-2024
Bypass:
Shutoffs: (int)

Type: RP
Manufacturer: Wilkins
Model: 475
Size: 2 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Jan-2002
Renewed: 24-Jan-2026
Bypass:
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number Q05664

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 475
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 24-Jan-2002 **Renewed:** 24-Jan-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 27-Jul-2000 **Renewed:** 27-Jul-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP | **Manufacturer:** Wilkins | **Model:** 475
Size: 6 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 27-Jul-2000 | **Renewed:** 27-Jul-2024 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

Type: RP | **Manufacturer:** Wilkins | **Model:** 475
Size: 6 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 09-Sep-2010 | **Renewed:** 09-Sep-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP | **Manufacturer:** Wilkins | **Model:** 475
Size: 8 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 03-Jul-2003 | **Renewed:** 03-Jul-2024 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

Type: RP | **Manufacturer:** Wilkins | **Model:** 475
Size: 8 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 09-Sep-2010 | **Renewed:** 09-Sep-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP | **Manufacturer:** Wilkins | **Model:** 475
Size: 10 | **Orientation:** VUVD | **Meters:**
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 22-Nov-2004 | **Renewed:** 22-Nov-2025 | **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 475
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 2 1/2 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 3 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 29-Mar-2005 **Renewed:** 29-Mar-2026 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 475MS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475ST
Size: 10 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 4 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 6 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 8 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 10 **Orientation:** VUVD **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475STR
Size: 10 **Orientation:** VUVU **Meters:**
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:**
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 24-Jan-2002 **Renewed:** 24-Jan-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 24-Jan-2002 **Renewed:** 24-Jan-2026 **Bypass:**
Shutoffs:
(gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn,llllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,tttt,vvvv,wwww,yyyy,zzzz,kkkkk,gggggg,hhhhhh,jjjjjj,kkkkkk,mmmmmm,nnnnnn,llllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 09-Sep-2000 **Renewed:** 09-Sep-2024 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 31-May-2001 **Renewed:** 31-May-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 08-Jun-2004 **Renewed:** 08-Jun-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaakkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 10 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Nov-2004 **Renewed:** 22-Nov-2025 **Bypass:**
Shutoffs:
(ppp),qqq,sss,ttt,www,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475V
Size: 10 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 2 1/2 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,ll,mm,tt,uu,yy,zz,ppp,qqq,zzz,dddd,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 3 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (gg),hh,ppp,qqq,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 4 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 6 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 03-Jul-2003 **Renewed:** 03-Jul-2024 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 8 **Orientation:** VUVU **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 29-Mar-2005 **Renewed:** 29-Mar-2026 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Up to serial number Q05664

Type: RP **Manufacturer:** Wilkins **Model:** 475VMS
Size: 10 **Orientation:** H **Meters:**
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Sep-2010 **Renewed:** 09-Sep-2025 **Bypass:**
Shutoffs: (ppp),qqq,sss,ttt,www,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll
Notes: Serial number Q05664 and higher

Type: RP
Size: 3/4
Manual: 5
Approved: 28-Apr-1976
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 28-Apr-2024
Model: 575
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1
Manual: 5
Approved: 28-Apr-1976
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 28-Apr-2024
Model: 575
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 2 1/2
Manual: 7
Approved: 25-Sep-1986
Shutoffs: gg,ee,tt,yy
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 25-Sep-2025
Model: 575
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 3
Manual: 5
Approved: 20-Aug-1979
Shutoffs: gg,ee,tt,yy
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 20-Aug-2024
Model: 575
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 4
Manual: 5
Approved: 08-Jun-1980
Shutoffs: gg,ee,tt,yy
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 08-Jun-2025
Model: 575
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 6
Manual: 6
Approved: 06-Jul-1981
Shutoffs: gg,ee,tt,yy
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 06-Jul-2026
Model: 575
Meters:
Spare Parts Only: Yes
Bypass:

Type: RP
Size: 1 1/4
Manual: 5
Approved: 11-Oct-1976
Shutoffs: ii
Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 11-Oct-2024
Model: 575 (MOD-III)
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 575 (MOD-III)
Size: 1 1/2
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Oct-1976
Renewed: 11-Oct-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 575 (MOD-III)
Size: 2
Orientation: H
Meters:
Manual: 5
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Oct-1976
Renewed: 11-Oct-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 575A
Size: 3/4
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Apr-1987
Renewed: 17-Apr-2026
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 575A
Size: 1
Orientation: H
Meters:
Manual: 7
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Apr-1987
Renewed: 17-Apr-2026
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 575M10
Size: 10
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Jun-1983
Renewed: 01-Jun-2025
Bypass:
Shutoffs: gg,ee,tt,yy
Notes: 6"x6"x10" manifold, formerly MBC-10"

Type: RP
Manufacturer: Wilkins
Model: 575M8
Size: 8
Orientation: H
Meters:
Manual: 6
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Apr-1983
Renewed: 11-Apr-2025
Bypass:
Shutoffs: gg,ee,tt,yy
Notes: 4"x4"x8" manifold, formerly MBC-8"

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 26-Nov-1991
Renewed: 26-Nov-2024
Bypass:
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Nov-1991
Renewed: 08-Nov-2024
Bypass:
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Nov-1991
Renewed: 08-Nov-2024
Bypass:
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-Nov-1991
Renewed: 08-Nov-2024
Bypass:
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 8
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Feb-1995
Renewed: 06-Feb-2025
Bypass:
Shutoffs:
(ppp),qqq,sss,ttt,www,yyy,zzz,dddd,eeee,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,kkkkk,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,ooooo
o

Type: RP
Manufacturer: Wilkins
Model: 975
Size: 10
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 06-Feb-1995
Renewed: 06-Feb-2025
Bypass:
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975A
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975A
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975A
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975A
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975A
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Jul-1991
Renewed: 18-Jul-2024
Bypass:
Shutoffs: ii

Type: RP
Manufacturer: Wilkins
Model: 975BMS
Size: 2 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Jun-1997
Renewed: 17-Jun-2024
Bypass:
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975BMS
Size: 3
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Jun-1997
Renewed: 17-Jun-2024
Bypass:
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975BMS
Size: 4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Jun-1997
Renewed: 17-Jun-2024
Bypass:
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP
Manufacturer: Wilkins
Model: 975BMS
Size: 6
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 17-Jun-1997
Renewed: 17-Jun-2024
Bypass:
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

2026 © University of Southern California

Type: RP **Manufacturer:** Wilkins **Model:** 975BMS
Size: 8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 17-Jun-1997 **Renewed:** 17-Jun-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975BMS
Size: 10 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 17-Jun-1997 **Renewed:** 17-Jun-2024 **Bypass:**
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975MS
Size: 2 1/2 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-May-1995 **Renewed:** 05-May-2025 **Bypass:**
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975MS
Size: 3 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-May-1995 **Renewed:** 05-May-2025 **Bypass:**
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975MS
Size: 4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-May-1995 **Renewed:** 05-May-2025 **Bypass:**
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975MS
Size: 6 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-May-1995 **Renewed:** 05-May-2025 **Bypass:**
Shutoffs: gg,ee,ff,hh,tt,uu,yy,zz,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975MS
Size: 8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-Dec-1996 **Renewed:** 05-Dec-2023 **Bypass:**
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

Type: RP **Manufacturer:** Wilkins **Model:** 975MS
Size: 10 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** Yes
Approved: 05-Dec-1996 **Renewed:** 05-Dec-2023 **Bypass:**
Shutoffs: (gg),ee,ff,hh,tt,uu,yy,zz,ppp,ssss,tttt,vvvv,wwww,yyyy,zzzz

---

Type: RP **Manufacturer:** Wilkins **Model:** 975XL
Size: 1/4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Jul-1994 **Renewed:** 12-Jul-2024 **Bypass:**
Shutoffs: (ii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP **Manufacturer:** Wilkins **Model:** 975XL
Size: 3/8 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Jul-1994 **Renewed:** 12-Jul-2024 **Bypass:**
Shutoffs: (ii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP **Manufacturer:** Wilkins **Model:** 975XL
Size: 1/2 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 12-Jul-1994 **Renewed:** 12-Jul-2024 **Bypass:**
Shutoffs: (ii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP **Manufacturer:** Wilkins **Model:** 975XL
Size: 3/4 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-Nov-1992 **Renewed:** 02-Nov-2025 **Bypass:**
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP **Manufacturer:** Wilkins **Model:** 975XL
Size: 1 **Orientation:** H **Meters:**
Manual: 8 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 02-Nov-1992 **Renewed:** 02-Nov-2025 **Bypass:**
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),ooo,ggg

Type: RP
Manufacturer: Wilkins
Model: 975XL
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XL
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Nov-1992
Renewed: 02-Nov-2025
Bypass:
Shutoffs: (ii),bbb,ooo,bbbbb,ccccc,pppppp

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Oct-2009
Renewed: 01-Oct-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 3/8
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Oct-2009
Renewed: 01-Oct-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Oct-2009
Renewed: 01-Oct-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Jul-2009
Renewed: 29-Jul-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Jul-2009
Renewed: 29-Jul-2024
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Aug-2009
Renewed: 21-Aug-2024
Bypass:
Shutoffs: (iiii),pppppp

Type: RP
Manufacturer: Wilkins
Model: 975XL2BMS
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL2BMS
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2BMS
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2BMS
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2BMS
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2MS
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2MS
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: RP
Manufacturer: Wilkins
Model: 975XL2MS
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2MS
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2MS
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 1 1/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 1 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SE
Size: 2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Mar-2011
Renewed: 29-Mar-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Mar-2011
Renewed: 29-Mar-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Mar-2011
Renewed: 29-Mar-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-Mar-2011
Renewed: 29-Mar-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 1 1/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 1 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2SEU
Size: 2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2TCU
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: RP
Manufacturer: Wilkins
Model: 975XL2TCU
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2TCU
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2TCU
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2TCU
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2TCU
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 09-Sep-2010
Renewed: 09-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL2U
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL2U
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2U
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2U
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL2V
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2V
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL2V
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: RP
Manufacturer: Wilkins
Model: 975XL2V
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XL3
Size: 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3
Size: 1
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3
Size: 1 1/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL3
Size: 1 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL3
Size: 2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)

Type: RP
Manufacturer: Wilkins
Model: 975XL3BFSS
Size: 2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 23-May-2023
Renewed: 23-May-2026
Bypass:
Shutoffs: (pppppp)

Type: RP
Manufacturer: Wilkins
Model: 975XL3N
Size: 3/4
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL3N
Size: 1
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL3N
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL3N
Size: 2
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-May-2026
Renewed:
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL3SE
Size: 1/2
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SE
Size: 1/2
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SE
Size: 3/4
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SE
Size: 3/4
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SE
Size: 1
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XL3SE
Size: 1
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (iiii)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SEU
Size: 3/4
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SEU
Size: 3/4
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SEU
Size: 1
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3SEU
Size: 1
Orientation: VUVU
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3U
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3U
Size: 1
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)
Notes: Starting serial #: ALB26001 and higher, this assembly now contains an O-ring seal on the RV plunger rather than the lip seal previously used. Both the O-ring and lip seal on the RV plunger are approved.

Type: RP
Manufacturer: Wilkins
Model: 975XL3U
Size: 1 1/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL3U
Size: 1 1/2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XL3U
Size: 2
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 06-Sep-2022
Renewed: 06-Sep-2025
Bypass:
Shutoffs: (mmmmm)

Type: RP
Manufacturer: Wilkins
Model: 975XLBF
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Feb-2011
Renewed: 22-Feb-2026
Bypass:
Shutoffs: (bbbbb),pppppp

2026 © University of Southern California

Type: RP
Size: 2
Manual: 8
Approved: 22-Feb-2011
Shutoffs: (ccccc),pppppp

Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 22-Feb-2026

Model: 975XLBFSS
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 3/4
Manual: 8
Approved: 09-May-1997
Shutoffs: (ii),ooo

Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 09-May-2024

Model: 975XLBMS
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1
Manual: 8
Approved: 09-May-1997
Shutoffs: (ii),ooo

Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 09-May-2024

Model: 975XLBMS
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/4
Manual: 8
Approved: 09-May-1997
Shutoffs: (ii),ooo

Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 09-May-2024

Model: 975XLBMS
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 1 1/2
Manual: 8
Approved: 09-May-1997
Shutoffs: (ii),ooo

Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 09-May-2024

Model: 975XLBMS
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Size: 2
Manual: 8
Approved: 09-May-1997
Shutoffs: (ii),ooo

Manufacturer: Wilkins
Orientation: H
0.25% Pb: No
Renewed: 09-May-2024

Model: 975XLBMS
Meters:
Spare Parts Only: No
Bypass:

Type: RP
Manufacturer: Wilkins
Model: 975XLD
Size: 3/4
Orientation: H
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 08-Oct-2002
Renewed: 08-Oct-2023
Bypass:
Shutoffs: (ii),ooo, iiii, mmmmm
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLD
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Jul-2013
Renewed: 03-Jul-2025
Bypass:
Shutoffs: (iiii), mmmmm
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLDTCU
Size: 3/4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass:
Shutoffs: (iiii), mmmmm
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLMS
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-1994
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLMS
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-1994
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLMS
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-1994
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (ii),ooo

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XLMS
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-1994
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLMS
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 30-Aug-1994
Renewed: 30-Aug-2024
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Nov-1999
Renewed: 04-Nov-2023
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 1 1/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Nov-1999
Renewed: 04-Nov-2023
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Nov-1999
Renewed: 04-Nov-2023
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 1 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Nov-1999
Renewed: 04-Nov-2023
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Nov-1999
Renewed: 04-Nov-2023
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLSE
Size: 2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 04-Nov-1999
Renewed: 04-Nov-2023
Bypass:
Shutoffs: (ii).ooo

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Oct-2000
Renewed: 16-Oct-2024
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 1 1/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 1 1/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 1 1/2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 1 1/2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 2
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLSEU
Size: 2
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 27-Mar-2000
Renewed: 27-Mar-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLST
Size: 3/8
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 19-Nov-2002
Renewed: 19-Nov-2023
Bypass:
Shutoffs: (ggggg)

Type: RP
Manufacturer: Wilkins
Model: 975XLST
Size: 1/2
Orientation: H
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 19-Nov-2002
Renewed: 19-Nov-2023
Bypass:
Shutoffs: (ggggg)

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XLTCU
Size: 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Apr-2007
Renewed: 05-Apr-2025
Bypass:
Shutoffs: (ii),ooo
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLTCU
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jun-2006
Renewed: 27-Jun-2024
Bypass:
Shutoffs: (ii),ooo,xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLTCU
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jun-2006
Renewed: 27-Jun-2024
Bypass:
Shutoffs: (ii),ooo,xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLTCU
Size: 1 1/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jun-2006
Renewed: 27-Jun-2024
Bypass:
Shutoffs: (ii),ooo,xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLTCU
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jun-2006
Renewed: 27-Jun-2024
Bypass:
Shutoffs: (ii),ooo,xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLTCU
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Jun-2006
Renewed: 27-Jun-2024
Bypass:
Shutoffs: (ii),ooo,xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLU
Size: 3/4
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Sep-1993
Renewed: 02-Sep-2026
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLU
Size: 1
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Sep-1993
Renewed: 02-Sep-2026
Bypass:
Shutoffs: (ggg),xxx
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: RP
Manufacturer: Wilkins
Model: 975XLU
Size: 1 1/2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Sep-1993
Renewed: 02-Sep-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLU
Size: 2
Orientation: H
Meters:
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 02-Sep-1993
Renewed: 02-Sep-2026
Bypass:
Shutoffs: (ggg),xxx

Type: RP
Manufacturer: Wilkins
Model: 975XLV
Size: 3/4
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Jan-2001
Renewed: 07-Jan-2025
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLV
Size: 3/4
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Jan-2001
Renewed: 07-Jan-2025
Bypass:
Shutoffs: (ii),ooo

2026 © University of Southern California

Type: RP
Manufacturer: Wilkins
Model: 975XLV
Size: 1
Orientation: VUVD
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Jan-2001
Renewed: 07-Jan-2025
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: 975XLV
Size: 1
Orientation: VUVU
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Jan-2001
Renewed: 07-Jan-2025
Bypass:
Shutoffs: (ii),ooo

Type: RP
Manufacturer: Wilkins
Model: MBC-10"
Size: 10
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: 6"x6"x10" manifold, Model designation changed to 575M10

Type: RP
Manufacturer: Wilkins
Model: MBC-8"
Size: 8
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: 4"x4"x8" manifold,Model designation changed to 575M8

Type: RPDA
Manufacturer: Ames
Model: 5000
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 28-Dec-1989
Renewed: 28-Dec-2025
Bypass: Conbraco 4020402 3/4 (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: RPDA
Manufacturer: Ames
Model: 5000
Size: 6
Orientation: H
Meters: (K),A,B,C,D,E,F,G,H,I,J,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 28-Dec-1989
Renewed: 28-Dec-2025
Bypass: Conbraco 4020402 3/4 (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: RPDA
Manufacturer: Ames
Model: 5000
Size: 8
Orientation: H
Meters: (K),A,B,C,D,E,F,G,H,I,J,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Jul-1989
Renewed: 01-Jul-2025
Bypass: Conbraco 4020402 3/4 (H)
Shutoffs: (uu),ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: RPDA
Manufacturer: Ames
Model: 5000
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 19-Mar-1990
Renewed: 19-Mar-2026
Bypass: Conbraco 4020402 3/4 (H)
Shutoffs: uu,ee,ff,gg,hh,ll,mm,oo,pp,tt,ccc,ddd,ffff,gggg

Type: RPDA
Manufacturer: Ames
Model: 5000CIV
Size: 2 1/2
Orientation: H
Meters: (H),C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu

Type: RPDA
Manufacturer: Ames
Model: 5000CIV
Size: 3
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,eee

Type: RPDA
Manufacturer: Ames
Model: 5000CIV
Size: 4
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,eee

Type: RPDA
Manufacturer: Ames
Model: 5000CIV
Size: 6
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,eee

2026 © University of Southern California

Type: RPDA
Manufacturer: Ames
Model: 5000CIV
Size: 8
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,eee

Type: RPDA
Manufacturer: Ames
Model: 5000CIV
Size: 10
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 07-Jul-2000
Renewed: 07-Jul-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,eee

Type: RPDA
Manufacturer: Ames
Model: Colt 500-GV
Size: 2 1/2
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Colt 500-GV
Size: 3
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Colt 500-GV
Size: 4
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Colt 500-GV
Size: 6
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Size: 8
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 15-Nov-2025

Model: Colt 500-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 10
Manual: 9
Approved: 27-Sep-2010
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2025

Model: Colt 500-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 28-May-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2024

Model: Colt 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 28-May-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2024

Model: Colt 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: Colt 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

2026 © University of Southern California

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 28-May-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 28-May-2024

Model: Colt 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Colt 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Nov-2025

Model: Colt 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: Colt 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 14-Jun-2025

Model: Colt 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500ZGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500ZGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Colt 500ZGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

2026 © University of Southern California

Type: RPDA
Manufacturer: Ames
Model: Colt 500ZGV
Size: 8
Orientation: VUVU
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 8
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Aug-2015
Renewed: 13-Aug-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500GV
Size: 10
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Oct-2015
Renewed: 12-Oct-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500NBF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: RPDA
Manufacturer: Ames
Model: LFColt 500NBF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500NBF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500NGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500NGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500NGV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500ZBF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: RPDA
Manufacturer: Ames
Model: LFColt 500ZBF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500ZBF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500ZGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500ZGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFColt 500ZGV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500GV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500GV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500GV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500GV
Size: 6
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Aug-2015
Renewed: 13-Aug-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500GV
Size: 8
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Oct-2015
Renewed: 12-Oct-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500GV
Size: 10
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Oct-2015
Renewed: 12-Oct-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500NBF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500NBF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500NGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500NGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500ZBF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500ZBF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500ZGV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

2026 © University of Southern California

Type: RPDA
Manufacturer: Ames
Model: LFMaxim 500ZGV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Ames
Model: Maxim 500-GV
Size: 2 1/2
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Maxim 500-GV
Size: 3
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Maxim 500-GV
Size: 4
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Jun-2006
Renewed: 20-Jun-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Maxim 500-GV
Size: 6
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Nov-2010
Renewed: 15-Nov-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Maxim 500-GV
Size: 8
Orientation: H
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 27-Sep-2010
Renewed: 27-Sep-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Size: 10
Manual: 9
Approved: 27-Sep-2010
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2025

Model: Maxim 500-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Maxim 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Maxim 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Nov-2025

Model: Maxim 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: Maxim 500NBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Maxim 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

2026 © University of Southern California

Type: RPDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: Maxim 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Nov-2025

Model: Maxim 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (zzz),ssssss

Manufacturer: Ames
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: Maxim 500NGV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Maxim 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: Maxim 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Ames
Orientation: VUVU
0.25% Pb: No
Renewed: 14-Jun-2025

Model: Maxim 500ZBF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Manufacturer: Ames
Model: Maxim 500ZGV
Size: 2 1/2
Orientation: VUVU
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Jun-2013
Renewed: 24-Jun-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Maxim 500ZGV
Size: 3
Orientation: VUVU
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Jun-2013
Renewed: 24-Jun-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Ames
Model: Maxim 500ZGV
Size: 6
Orientation: VUVU
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Jun-2013
Renewed: 14-Jun-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (zzz),ssssss

Type: RPDA
Manufacturer: Apollo/Conbraco
Model: RPDALF4A
Size: 2 1/2
Orientation: H
Meters: (P),O
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 10-Jun-2014
Renewed: 10-Jun-2026
Bypass: Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA
Manufacturer: Apollo/Conbraco
Model: RPDALF4A
Size: 3
Orientation: H
Meters: (P),O
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 10-Jun-2014
Renewed: 10-Jun-2026
Bypass: Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA
Manufacturer: Apollo/Conbraco
Model: RPDALF4A
Size: 4
Orientation: H
Meters: (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 24-Jun-2013
Renewed: 24-Jun-2025
Bypass: Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

2026 © University of Southern California

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4A
Size: 6 | **Orientation:** H | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 24-Jun-2013 | **Renewed:** 24-Jun-2025 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4A
Size: 8 | **Orientation:** H | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 22-Feb-2018 | **Renewed:** 22-Feb-2024 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 2 1/2 | **Orientation:** VUVD | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 12-May-2016 | **Renewed:** 12-May-2025 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 2 1/2 | **Orientation:** VUVU | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 12-May-2016 | **Renewed:** 12-May-2025 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 3 | **Orientation:** VUVD | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 12-May-2016 | **Renewed:** 12-May-2025 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 3 | **Orientation:** VUVU | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 12-May-2016 | **Renewed:** 12-May-2025 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 4 | **Orientation:** VUVD | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 10-Jun-2014 | **Renewed:** 10-Jun-2026 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 4 | **Orientation:** VUVU | **Meters:** (P),G,H,I,J,K,L,M,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 11-Jun-2014 | **Renewed:** 11-Jun-2026 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 6 | **Orientation:** VUVD | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 12-May-2015 | **Renewed:** 12-May-2024 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 6 | **Orientation:** VUVU | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 12-May-2015 | **Renewed:** 12-May-2024 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 8 | **Orientation:** VUVD | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 22-Feb-2018 | **Renewed:** 22-Feb-2024 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AN
Size: 8 | **Orientation:** VUVU | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 22-Feb-2018 | **Renewed:** 22-Feb-2024 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (yyy), cccc, dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa, xxxxxx

---

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AR
Size: 2 1/2 | **Orientation:** H | **Meters:** (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:** Apollo RPLF4A 1/2"
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

2026 © University of Southern California

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AR
Size: 3 | **Orientation:** H | **Meters:** (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:** Apollo RPLF4A 1/2"
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AR
Size: 4 | **Orientation:** H | **Meters:** (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:** Apollo RPLF4A 1/2"
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AR
Size: 6 | **Orientation:** H | **Meters:** (M),G,H,I,J,K,L,N,O,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 21-Dec-2015 | **Renewed:** 21-Dec-2024 | **Bypass:** Apollo RPLF4A 1/2"
Shutoffs: (cccc), dddd, mmmm, nnnn, xxxxx, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: RPDA | **Manufacturer:** Apollo/Conbraco | **Model:** RPDALF4AR
Size: 8 | **Orientation:** H | **Meters:** (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** Yes
Approved: 22-Feb-2018 | **Renewed:** 22-Feb-2024 | **Bypass:** Apollo RPLF4A 1/2" (H)
Shutoffs: (xxxxx), cccc, dddd, mmmm, nnnn, yyyyy, zzzzz, aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: RPDA | **Manufacturer:** Cla-Val | **Model:** 18-4
Size: 10 | **Orientation:** H | **Meters:** (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8 | **0.25% Pb:** No | **Spare Parts Only:** Yes
Approved: 23-Aug-1990 | **Renewed:** 23-Aug-2026 | **Bypass:** Cla-Val RP2 3/4 (H)
Shutoffs: hh,gg,qq,rr

Type: RPDA | **Manufacturer:** Conbraco | **Model:**
Size: | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: See Apollo/Conbraco

Type: RPDA | **Manufacturer:** Febco | **Model:** 826 Type YD
Size: 2 1/2 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 826YD

Type: RPDA | **Manufacturer:** Febco | **Model:** 826 Type YD
Size: 3 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 826YD

Type: RPDA | **Manufacturer:** Febco | **Model:** 826 Type YD
Size: 4 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 826YD

Type: RPDA | **Manufacturer:** Febco | **Model:** 826 Type YD
Size: 6 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 826YD

Type: RPDA | **Manufacturer:** Febco | **Model:** 826 Type YD
Size: 8 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 826YD

Type: RPDA | **Manufacturer:** Febco | **Model:** 826 Type YD
Size: 10 | **Orientation:** | **Meters:**
Manual: | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: | **Renewed:** | **Bypass:**
Notes: model designation changed to 826YD

2026 © University of Southern California

Type: RPDA
Manufacturer: Febco
Model: 826YD
Size: 2 1/2
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Nov-1988
Renewed: 11-Nov-2024
Bypass: Febco 825Y 3/4 (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 826 Type YD

Type: RPDA
Manufacturer: Febco
Model: 826YD
Size: 3
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 11-Nov-1988
Renewed: 11-Nov-2024
Bypass: Febco 825Y 3/4 (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 826 Type YD

Type: RPDA
Manufacturer: Febco
Model: 826YD
Size: 4
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Oct-1988
Renewed: 14-Oct-2024
Bypass: Febco 825Y 3/4 (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 826 Type YD

Type: RPDA
Manufacturer: Febco
Model: 826YD
Size: 6
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Mar-1990
Renewed: 01-Mar-2026
Bypass: Febco 825Y 3/4 (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 826 Type YD

Type: RPDA
Manufacturer: Febco
Model: 826YD
Size: 8
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 22-Jun-1990
Renewed: 22-Jun-2026
Bypass: Febco 825Y 3/4 (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 826 Type YD

Type: RPDA
Manufacturer: Febco
Model: 826YD
Size: 10
Orientation: H
Meters: (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 22-Jun-1990
Renewed: 22-Jun-2026
Bypass: Febco 825Y 3/4 (H)
Shutoffs: (ff),mm,oo,pp,uu,zzz,ffff,gggg
Notes: formerly 826 Type YD

Type: RPDA
Manufacturer: Neptune
Model:
Size:
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: See Wilkins

Type: RPDA
Manufacturer: Watts
Model: 909DDC
Size: 6
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909RPDA

Type: RPDA
Manufacturer: Watts
Model: 909DDCM2
Size: 3
Orientation:
Meters:
Manual:
0.25% Pb: No
Spare Parts Only: No
Approved:
Renewed:
Bypass:
Notes: model designation changed to 909RPDA

Type: RPDA
Manufacturer: Watts
Model: 909RPDA
Size: 2 1/2
Orientation: H
Meters: (H),C,D,E,F,G,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 16-Jun-1999
Renewed: 16-Jun-2026
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,zz,ffff,gggg,aaaaaaa

Type: RPDA
Manufacturer: Watts
Model: 909RPDA
Size: 3
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Oct-1988
Renewed: 05-Oct-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa
Notes: formerly 909DDCM2

2026 © University of Southern California

Type: RPDA
Manufacturer: Watts
Model: 909RPDA
Size: 4
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 09-Feb-1988
Renewed: 09-Feb-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Type: RPDA
Manufacturer: Watts
Model: 909RPDA
Size: 6
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 05-Oct-1988
Renewed: 05-Oct-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa
Notes: formerly 909DDC

Type: RPDA
Manufacturer: Watts
Model: 909RPDA
Size: 8
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 14-Feb-1988
Renewed: 14-Feb-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Type: RPDA
Manufacturer: Watts
Model: 909RPDA
Size: 10
Orientation: H
Meters: (N),B,C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T,U
Manual: 8
0.25% Pb: No
Spare Parts Only: No
Approved: 15-Feb-1988
Renewed: 15-Feb-2024
Bypass: Watts 909QT 3/4 (H)
Shutoffs: (pp),hh,mm,uu,zz,eee,ffff,gggg,aaaaaaa

Type: RPDA
Manufacturer: Watts
Model: 957NRPDA-BF
Size: 2 1/2
Orientation: VUVD
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 24-Jun-2013
Renewed: 24-Jun-2025
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (yyy)

Type: RPDA
Manufacturer: Watts
Model: 957NRPDA-BF
Size: 3
Orientation: VUVD
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 07-Apr-2009
Renewed: 07-Apr-2024
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)
Shutoffs: (yyy)

Type: RPDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 957NRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: 957NRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 957NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 957NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 957NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Nov-2025

Model: 957NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

2026 © University of Southern California

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025
Model: 957NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024
Model: 957RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024
Model: 957RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024
Model: 957RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024
Model: 957RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Nov-2025
Model: 957RPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 10
Manual: 9
Approved: 27-Sep-2010
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2025
Model: 957RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025
Model: 957ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025
Model: 957ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025
Model: 957ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 14-Jun-2025
Model: 957ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz)
Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025
Model: 957ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

2026 © University of Southern California

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 957ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 957ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 14-Jun-2025

Model: 957ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 967NRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 967NRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Nov-2025

Model: 967NRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: 967NRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 967NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 07-Apr-2009
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 07-Apr-2024

Model: 967NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 15-Nov-2025

Model: 967NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVD
0.25% Pb: No
Renewed: 14-Jun-2025

Model: 967NRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 967RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

2026 © University of Southern California

Type: RPDA
Size: 3
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 967RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 9
Approved: 20-Jun-2006
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 20-Jun-2024

Model: 967RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 15-Nov-2010
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 15-Nov-2025

Model: 967RPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 8
Manual: 9
Approved: 27-Sep-2010
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2025

Model: 967RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 10
Manual: 9
Approved: 27-Sep-2010
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 27-Sep-2025

Model: 967RPDA-GV
Meters: (N), H, I J, K L, M, N, O, P, Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 967ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 967ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (yyy)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 14-Jun-2025

Model: 967ZRPDA-BF
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 2 1/2
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 967ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 3
Manual: 9
Approved: 24-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 24-Jun-2025

Model: 967ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 6
Manual: 9
Approved: 14-Jun-2013
Shutoffs: (zzz)

Manufacturer: Watts
Orientation: VUVU
0.25% Pb: No
Renewed: 14-Jun-2025

Model: 967ZRPDA-GV
Meters: (N),H,I,J,K,L,M,N,O,P,Q
Spare Parts Only: No
Bypass: Watts 919QT 3/4" (H), Watts LF919QT 3/4" (H)

Type: RPDA
Size: 4
Manual: 8
Approved: 01-Nov-1992
Shutoffs: pp,hh,mm,uu,zz

Manufacturer: Watts
Orientation: H
0.25% Pb: No
Renewed: 01-Nov-2025

Model: 990RPDA
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Spare Parts Only: Yes
Bypass: Watts 009QT 3/4 (H)

2026 © University of Southern California

Type: RPDA
Manufacturer: Watts
Model: 990RPDA
Size: 8
Orientation: H
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass: Watts 009QT 3/4 (H)
Shutoffs: oo,gg,hh,ll,mm,pp,tt,uu

Type: RPDA
Manufacturer: Watts
Model: 992RPDA
Size: 4
Orientation: H
Meters: (H),A,B,C,D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Nov-1992
Renewed: 01-Nov-2025
Bypass: Watts 009QT 3/4 (H)
Shutoffs: oo

Type: RPDA
Manufacturer: Watts
Model: 992RPDA
Size: 10
Orientation: H
Meters: (H),D,E,F,G,I,J,K,L,M,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 13-Jan-1993
Renewed: 13-Jan-2026
Bypass: Watts 009QT 3/4 (H)
Shutoffs: oo

Type: RPDA
Manufacturer: Watts
Model: LF957NRPDA-BF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957NRPDA-BF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957NRPDA-BF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: RPDA
Manufacturer: Watts
Model: LF957NRPDA-GV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957NRPDA-GV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957NRPDA-GV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957RPDA-GV
Size: 2 1/2
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2014
Renewed: 15-May-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Water meter identified with NSF61 mark

Type: RPDA
Manufacturer: Watts
Model: LF957RPDA-GV
Size: 3
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2014
Renewed: 15-May-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Water meter identified with NSF61 mark

Type: RPDA
Manufacturer: Watts
Model: LF957RPDA-GV
Size: 4
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2014
Renewed: 15-May-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Water meter identified with NSF61 mark

2026 © University of Southern California

Type: RPDA
Manufacturer: Watts
Model: LF957RPDA-GV
Size: 6
Orientation: H
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2014
Renewed: 15-May-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Water meter identified with NSF61 mark

Type: RPDA
Manufacturer: Watts
Model: LF957RPDAGV
Size: 8
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Aug-2015
Renewed: 13-Aug-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Water meter identified with NSF61 mark

Type: RPDA
Manufacturer: Watts
Model: LF957RPDAGV
Size: 10
Orientation: H
Meters: (M)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Sep-2015
Renewed: 21-Sep-2024
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957ZRPDA-BF
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957ZRPDA-BF
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957ZRPDA-BF
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (yyy)
Notes: Lead free compliant version identified with NSF61 mark on meter

Type: RPDA
Manufacturer: Watts
Model: LF957ZRPDA-GV
Size: 2 1/2
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957ZRPDA-GV
Size: 3
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Watts
Model: LF957ZRPDA-GV
Size: 4
Orientation: VUVD
Meters: (O)
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 08-Jan-2014
Renewed: 08-Jan-2026
Bypass: Watts LF919QT 3/4" (H)
Shutoffs: (zzz)
Notes: Lead free compliant version identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Wilkins
Model: 375ADA
Size: 2 1/2
Orientation: H
Meters: (M),H,I,J,K,L,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Oct-2008
Renewed: 20-Oct-2023
Bypass: Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA
Manufacturer: Wilkins
Model: 375ADA
Size: 2 1/2
Orientation: H
Meters: (O), M
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Feb-2014
Renewed: 18-Feb-2026
Bypass: Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # Y09616; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA
Manufacturer: Wilkins
Model: 375ADA
Size: 3
Orientation: H
Meters: (M),H,I,J,K,L,N,O,P,Q
Manual: 9
0.25% Pb: No
Spare Parts Only: No
Approved: 20-Oct-2008
Renewed: 20-Oct-2023
Bypass: Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

2026 © University of Southern California

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADA
Size: 3 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # Y09616; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADA
Size: 4 | **Orientation:** H | **Meters:** (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 02-Jun-2004 | **Renewed:** 02-Jun-2025 | **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADA
Size: 4 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # Y09616; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADA
Size: 6 | **Orientation:** H | **Meters:** (M),C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 25-Nov-2003 | **Renewed:** 25-Nov-2024 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADA
Size: 6 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # Y09616; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ADA
Size: 8 **Orientation:** H **Meters:** (N),G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 15-Jun-2004 **Renewed:** 15-Jun-2025 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ADA
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # Y09616; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ADA
Size: 10 **Orientation:** H **Meters:** (N),H,I,J,K,L,M,N,O,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 11-Mar-2009 **Renewed:** 11-Mar-2024 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ADA
Size: 10 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Lead free compliant version: Starting Serial # Y09616; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ADAR
Size: 2 1/2 **Orientation:** H **Meters:** (M),H,I,J,K,L,N,O,P,Q
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 16-Jun-2010 **Renewed:** 16-Jun-2025 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8"

2026 © University of Southern California

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR
Size: 2 1/2 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 1/4" and max. 47 1/8" and Lead free compliant version: Starting Serial # T00466; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR
Size: 3 | **Orientation:** H | **Meters:** (M),H,I,J,K,L,N,O,P,Q
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 16-Jun-2010 | **Renewed:** 16-Jun-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8"

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR
Size: 3 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 34 3/4" and max. 48 1/8" and Lead free compliant version: Starting Serial # T00466; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR
Size: 4 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4"

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR
Size: 4 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 35 3/4" and max. 62 1/4" and Lead free compliant version: Starting Serial # T00466; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR

Size: 6 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4"

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR

Size: 6 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 42 1/2" and max. 71 1/4" and Lead free compliant version: Starting Serial # T00466; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR

Size: 8 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 57 7/8" and max. 86"

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR

Size: 8 | **Orientation:** H | **Meters:** (O), M

Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No

Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)

Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,lllll,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 57 7/8" and max. 86" and Lead free compliant version: Starting Serial # T00466; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR

Size: 10 | **Orientation:** H | **Meters:** (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T

Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No

Approved: 25-Mar-2010 | **Renewed:** 25-Mar-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)

Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 61 3/8" and max. 100 5/8"

2026 © University of Southern California

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ADAR
Size: 10 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,xxxx,yyyy,kkkkk,llllll,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 61 3/8" and max. 100 5/8" and Lead free compliant version: Starting Serial # T00466; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ASTDA
Size: 2 1/2 | **Orientation:** H | **Meters:** (M),H,I,J,K,L,N,O,P,Q
Manual: 10 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 14-Jun-2013 | **Renewed:** 14-Jun-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (yyy),qqq,ttt,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ASTDA
Size: 2 1/2 | **Orientation:** H | **Meters:** (O), M
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 20-Feb-2014 | **Renewed:** 20-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (yyy),qqq,ttt,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ASTDA
Size: 3 | **Orientation:** H | **Meters:** (M),H,I,J,K,L,N,O,P,Q
Manual: 10 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 14-Jun-2013 | **Renewed:** 14-Jun-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (yyy),qqq,ttt,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ASTDA
Size: 3 | **Orientation:** H | **Meters:** (O), M
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 20-Feb-2014 | **Renewed:** 20-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (yyy),qqq,ttt,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375ASTDA
Size: 4 | **Orientation:** H | **Meters:** (M),H,I,J,K,L,N,O,P,Q
Manual: 10 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 14-Jun-2013 | **Renewed:** 14-Jun-2025 | **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyy),qqq,ttt,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDA
Size: 4 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 20-Feb-2014 **Renewed:** 20-Feb-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyy),qqq,ttt,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Lead free compliant version: By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDA
Size: 6 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDA
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDA
Size: 10 **Orientation:** H **Meters:** (O)
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDAR
Size: 2 1/2 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 31" and max. 47 1/8"

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDAR
Size: 3 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 31 1/2" and max. 48 1/8"

2026 © University of Southern California

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDAR
Size: 4 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 09-Oct-2014 **Renewed:** 09-Oct-2023 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 32 5/8" and max. 62 1/4"

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDAR
Size: 6 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 39" and max. 71 1/4"

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDAR
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 48 3/4" and max. 86"

Type: RPDA **Manufacturer:** Wilkins **Model:** 375ASTDAR
Size: 10 **Orientation:** H **Meters:** (O)
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Sep-2014 **Renewed:** 18-Sep-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (yyyy),ttt,www,yyy,uuuu,vvvv,xxxx,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm
Notes: Integral grooved spool between the #2 ck and #2 SOV - assembly length: min. 52 5/8" and max. 100 5/8"

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 2 1/2 **Orientation:** H **Meters:** (M),C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 08-Oct-2002 **Renewed:** 08-Oct-2023 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 2 1/2 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # M08452; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375DA
Size: 3 | **Orientation:** H | **Meters:** (M),C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 08-Oct-2002 | **Renewed:** 08-Oct-2023 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375DA
Size: 3 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # M08452; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375DA
Size: 4 | **Orientation:** H | **Meters:** (M),C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 13-Dec-2000 | **Renewed:** 13-Dec-2024 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www.zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375DA
Size: 4 | **Orientation:** H | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # M08452; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 375DA
Size: 6 | **Orientation:** H | **Meters:** (N),C,D,E,F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 31-May-2001 | **Renewed:** 31-May-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www.zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

2026 © University of Southern California

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 6 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # M08452; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 8 **Orientation:** H **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 15-Jun-2004 **Renewed:** 15-Jun-2025 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www.zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 8 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # M08452; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 10 **Orientation:** H **Meters:** (N),G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 22-Nov-2004 **Renewed:** 22-Nov-2025 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (hh),ff,mm,uu,zz,qqq,vvv,www.zzz,eeee,vvvv,wwww,yyyy,zzzz,kkkkk,jjjjjj,kkkkkk,mmmmmm,nnnnnn

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 375DA
Size: 10 **Orientation:** H **Meters:** (O), M
Manual: 9 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Feb-2014 **Renewed:** 18-Feb-2026 **Bypass:** Wilkins 975XLD 3/4" (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # M08452; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475DA
Size: 4 **Orientation:** VUVD **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 **0.25% Pb:** No **Spare Parts Only:** No
Approved: 20-Mar-2001 **Renewed:** 20-Mar-2025 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DA
Size: 4 | **Orientation:** VUVD | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # R04847; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DA
Size: 6 | **Orientation:** VUVD | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 31-May-2001 | **Renewed:** 31-May-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DA
Size: 6 | **Orientation:** VUVD | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # R04847; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DA
Size: 8 | **Orientation:** VUVD | **Meters:** (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 11-Aug-2004 | **Renewed:** 11-Aug-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DA
Size: 8 | **Orientation:** VUVD | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # R04847; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DAV
Size: 4 | **Orientation:** VUVU | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 20-Mar-2001 | **Renewed:** 20-Mar-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),mm,ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,lllll,iiiiii,jjjjjj,llllll,mmmmmm

2026 © University of Southern California

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DAV
Size: 4 | **Orientation:** VUVU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # R04847; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DAV
Size: 6 | **Orientation:** VUVU | **Meters:** (N),F,G,H,I,J,K,L,M,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 20-Jul-2004 | **Renewed:** 20-Jul-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),mm,ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DAV
Size: 6 | **Orientation:** VUVU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,kkkkk,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # R04847; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DAV
Size: 8 | **Orientation:** VUVU | **Meters:** (M),B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 9 | **0.25% Pb:** No | **Spare Parts Only:** No
Approved: 24-Apr-2004 | **Renewed:** 24-Apr-2025 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (qqq),mm,ttt,www,yyy,zzz,eeee,uuuu,vvvv,xxxx,yyyy,kkkkk,llllll,iiiiii,jjjjjj,llllll,mmmmmm

---

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475DAV
Size: 8 | **Orientation:** VUVU | **Meters:** (O), M
Manual: 9 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Feb-2014 | **Renewed:** 18-Feb-2026 | **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (hh),qqq,vvv,www,yyyy,zzzz,mmmmmm,nnnnnn
Notes: Lead free compliant version: Starting Serial # R04847; By-pass Assembly Starting Serial # 3863325 and identified with NSF61 mark on meter

Type: RPDA | **Manufacturer:** Wilkins | **Model:** 475STDA
Size: 4 | **Orientation:** VUVD | **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 | **0.25% Pb:** Yes | **Spare Parts Only:** No
Approved: 18-Dec-2018 | **Renewed:** 18-Dec-2024 | **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,llllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 4 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 6 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 6 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 8 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 8 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 10 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDA
Size: 10 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLDTCU 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

2026 © University of Southern California

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 4 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 4 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 6 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 6 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 8 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 8 **Orientation:** VUVU **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA **Manufacturer:** Wilkins **Model:** 475STDAR
Size: 10 **Orientation:** VUVD **Meters:** (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10 **0.25% Pb:** Yes **Spare Parts Only:** No
Approved: 18-Dec-2018 **Renewed:** 18-Dec-2024 **Bypass:** Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,lllll,ggggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

Type: RPDA
Manufacturer: Wilkins
Model: 475STDAR
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 18-Dec-2018
Renewed: 18-Dec-2024
Bypass: Wilkins 975XLD 3/4 (H)
Shutoffs: (kkkkk),yyy,ssss,uuuu,vvvv,xxxx,yyyy,aaaaa,llllll,gggggg,iiiiii,jjjjjj,llllll,mmmmmm,oooooo

---

Type: RPDA
Manufacturer: Wilkins
Model: 975DA
Size: 2 1/2
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-1994
Renewed: 01-Feb-2024
Bypass: Wilkins 975 3/4 (H)
Shutoffs: (hh),ff,uu,zz,vvvv,wwww,yyyy,zzzz

Type: RPDA
Manufacturer: Wilkins
Model: 975DA
Size: 3
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Feb-1994
Renewed: 01-Feb-2024
Bypass: Wilkins 975 3/4 (H)
Shutoffs: (hh),ff,uu,zz,vvvv,wwww,yyyy,zzzz

Type: RPDA
Manufacturer: Wilkins
Model: 975DA
Size: 4
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 01-Nov-1993
Renewed: 01-Nov-2023
Bypass: Wilkins 975 3/4 (H)
Shutoffs: hh,ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: RPDA
Manufacturer: Wilkins
Model: 975DA
Size: 6
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 14-Mar-1994
Renewed: 14-Mar-2024
Bypass: Wilkins 975 3/4 (H)
Shutoffs: hh,ff,mm,uu,zz,vvvv,wwww,yyyy,zzzz

Type: RPDA
Manufacturer: Wilkins
Model: 975DA
Size: 8
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass: Wilkins 975 3/4 (H)
Shutoffs: (hh),ff,uu,zz,vvvv,wwww,yyyy.zzzz

2026 © University of Southern California

Type: RPDA
Manufacturer: Wilkins
Model: 975DA
Size: 10
Orientation: H
Meters: (M),A,B,C,D,E,F,G,H,I,J,K,L,N,O,P,Q,T
Manual: 8
0.25% Pb: No
Spare Parts Only: Yes
Approved: 05-Dec-1996
Renewed: 05-Dec-2023
Bypass: Wilkins 975 3/4 (H)
Shutoffs: (hh),ff,uu,zz,vvvv,wwww,yyyy.zzzz

Type: RPDA-II
Manufacturer: Ames
Model: Deringer 50
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Manufacturer: Ames
Model: Deringer 50
Size: 3
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Manufacturer: Ames
Model: Deringer 50
Size: 4
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Manufacturer: Ames
Model: Deringer 50
Size: 6
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Aug-2022
Renewed: 03-Aug-2025
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Manufacturer: Ames
Model: Deringer 50
Size: 8
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Size: 2 1/2
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 3
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 4
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 6
Manual: 10
Approved: 01-Oct-2024
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed:

Model: Deringer 50G
Meters:
Spare Parts Only: No
Bypass:

Type: RPDA-II
Size: 8
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 4
Manual: 10
Approved: 01-Oct-2024
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed:

Model: Deringer 50GX
Meters:
Spare Parts Only: No
Bypass:

Type: RPDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (ssssss), tttttt

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 50GX
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

2026 © University of Southern California

Type: RPDA-II
Size: 4
Manual: 10
Approved: 03-Aug-2022
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2025

Model: Deringer 50X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 6
Manual: 10
Approved: 26-Mar-2020
Shutoffs: (int)

Manufacturer: Ames
Orientation: H
0.25% Pb: Yes
Renewed: 26-Mar-2026

Model: Deringer 50X
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 1 1/2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (dddddd)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: RPDA24A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVA4A (HVD)

Type: RPDA-II
Size: 2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (dddddd)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: RPDA24A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVA4A (HVD)

Type: RPDA-II
Size: 1 1/2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (eeeeee)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: RPDA2LF4A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVALF4A (HVD)

Type: RPDA-II
Size: 2
Manual: 10
Approved: 31-Oct-2016
Shutoffs: (eeeeee)

Manufacturer: Apollo/Conbraco
Orientation: H
0.25% Pb: No
Renewed: 31-Oct-2025

Model: RPDA2LF4A
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Spare Parts Only: No
Bypass: Apollo 1/2" Model CVALF4A (HVD)

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 2 1/2
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 3
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 4
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 6
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 8
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-Dec-2017
Renewed: 15-Dec-2023
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),yyy,yyyyy,zzzzz,aaaaaa,xxxxxx

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 10
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

2026 © University of Southern California

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4A
Size: 12
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AN
Size: 10
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2022
Renewed: 12-Apr-2025
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (zzzzz), yyy,zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa

---

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AN
Size: 12
Orientation: VUVD
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Apr-2022
Renewed: 12-Apr-2025
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (bbbbbb), ll,mm,cccccc

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AR
Size: 2 1/2
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 34" and max. 47 1/8"

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AR
Size: 3
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 35" and max. 48 1/8"

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AR
Size: 4
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 37 3/8" and max. 62 1/4"

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AR
Size: 6
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 46" and max. 71 1/4"

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AR
Size: 8
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 27-Mar-2018
Renewed: 27-Mar-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (xxxxx),zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,yyyyy,zzzzz,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 55 3/4" and max. 86"

Type: RPDA-II
Manufacturer: Apollo/Conbraco
Model: RPDA2LF4AR
Size: 10
Orientation: H
Meters: (M),G,H,I,J,K,L,N,O,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: Yes
Approved: 05-Nov-2021
Renewed: 05-Nov-2024
Bypass: Apollo 1/2" Model CVALF4A (HVD)
Shutoffs: (zzzzz), zzz,cccc,dddd,kkkk,llll,mmmm,nnnn,xxxxx, yyyyy,aaaaaa
Notes: Integral Stainless Steel grooved spool between the #2 ck and #2 SOV - assembly length: min. 65 3/4" and max. 100 5/8"

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Jan-2017
Renewed: 20-Jan-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

2026 © University of Southern California

Type: RPDA-II
Size: 3
Manual: 10
Approved: 20-Jan-2017
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 20-Jan-2026
Model: Deringer 50
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 4
Manual: 10
Approved: 20-Jan-2017
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 20-Jan-2026
Model: Deringer 50
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 6
Manual: 10
Approved: 03-Aug-2022
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 03-Aug-2025
Model: Deringer 50
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 8
Manual: 10
Approved: 27-Jun-2017
Shutoffs: (int)
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 27-Jun-2026
Model: Deringer 50
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 2 1/2
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024
Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 3
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024
Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Size: 4
Manual: 10
Approved: 24-Oct-2018
Shutoffs: (ssssss), tttttt
Manufacturer: Backflow Direct
Orientation: H
0.25% Pb: Yes
Renewed: 24-Oct-2024
Model: Deringer 50G
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Spare Parts Only: No
Bypass: Backflow Direct 1/2" CV(HVD)

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50G
Size: 6
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Oct-2024
Renewed:
Bypass:
Shutoffs: (ssssss), tttttt

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50G
Size: 8
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (ssssss), tttttt

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50GX
Size: 4
Orientation: H
Meters:
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 01-Oct-2024
Renewed:
Bypass:
Shutoffs: (ssssss), tttttt

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50GX
Size: 6
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 12-Mar-2019
Renewed: 12-Mar-2025
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (ssssss), tttttt

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50X
Size: 4
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 03-Aug-2022
Renewed: 03-Aug-2025
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Manufacturer: Backflow Direct
Model: Deringer 50X
Size: 6
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 27-Jun-2017
Renewed: 27-Jun-2026
Bypass: Backflow Direct 1/2" CV(HVD)
Shutoffs: (int)

Type: RPDA-II
Manufacturer: Febco
Model: LF866
Size: 2 1/2
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

2026 © University of Southern California

Type: RPDA-II
Manufacturer: Febco
Model: LF866
Size: 3
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF866
Size: 4
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF866
Size: 6
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 13-Mar-2015
Renewed: 13-Mar-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF866
Size: 8
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF866
Size: 10
Orientation: H
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (H)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 2 1/2
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 2 1/2
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 3
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 3
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 20-Mar-2015
Renewed: 20-Mar-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 4
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 4
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 6
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 6
Orientation: VUVU
Meters: (O),J,K,L,M,N,P,Q
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Jan-2015
Renewed: 26-Jan-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

2026 © University of Southern California

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 8
Orientation: VUVU
Meters: (O)
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 07-Jul-2015
Renewed: 07-Jul-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 10
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-May-2018
Renewed: 29-May-2024
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886V
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 29-May-2018
Renewed: 29-May-2024
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 4
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 4
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 6
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 6
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 8
Orientation: VUVU
Meters: (O)
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 10
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886W
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 4
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 4
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 6
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

2026 © University of Southern California

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 6
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 26-Mar-2020
Renewed: 26-Mar-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 8
Orientation: VUVD
Meters: (O)
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 8
Orientation: VUVU
Meters: (O)
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 10
Orientation: VUVD
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVU)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: RPDA-II
Manufacturer: Febco
Model: LF886WZ
Size: 10
Orientation: VUVU
Meters: (O),G,H,I,J,K,L,M,N,P,Q,T
Manual: 10
0.25% Pb: Yes
Spare Parts Only: No
Approved: 15-May-2020
Renewed: 15-May-2026
Bypass: Watts 3/4" LF619 (HVD)
Shutoffs: (mm), ll,oo,pp,zzz,cccc,dddd,eeee,ffff,gggg,nnnnn,aaaaaaa

---

Type: SVB
Manufacturer: Watts
Model: 008PCQT
Size: 3/8
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Nov-1998
Renewed: 18-Nov-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp

Type: SVB
Manufacturer: Watts
Model: 008PCQT
Size: 1/2
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 18-Nov-1998
Renewed: 18-Nov-2025
Bypass:
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Type: SVB
Size: 3/4
Manual: 9
Approved: 19-Jun-2000
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 19-Jun-2024

Model: 008PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: SVB
Size: 1
Manual: 9
Approved: 19-Jun-2000
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: No
Renewed: 19-Jun-2024

Model: 008PCQT
Meters:
Spare Parts Only: Yes
Bypass:

Type: SVB
Size: 3/8
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (vv),xx,ooo,hhhh,pppp

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF008PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: SVB
Size: 1/2
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF008PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: SVB
Size: 3/4
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF008PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: SVB
Size: 1
Manual: 9
Approved: 13-Mar-2015
Shutoffs: (vv),xx,ooo,hhhh,pppp,rrrrr

Manufacturer: Watts
Orientation: VUH
0.25% Pb: Yes
Renewed: 13-Mar-2024

Model: LF008PCQT
Meters:
Spare Parts Only: No
Bypass:

Type: SVB
Size: 3/8
Manual: 9
Approved: 09-Mar-2007
Shutoffs: (ooo),ii

Manufacturer: Wilkins
Orientation: VUH
0.25% Pb: No
Renewed: 09-Mar-2025

Model: 460
Meters:
Spare Parts Only: Yes
Bypass:

2026 © University of Southern California

Type: SVB
Manufacturer: Wilkins
Model: 460
Size: 1/2
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 09-Mar-2007
Renewed: 09-Mar-2025
Bypass:
Shutoffs: (ooo),ii

Type: SVB
Manufacturer: Wilkins
Model: 460
Size: 3/4
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-May-2008
Renewed: 08-May-2026
Bypass:
Shutoffs: (ooo),ii

Type: SVB
Manufacturer: Wilkins
Model: 460
Size: 1
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: No
Spare Parts Only: Yes
Approved: 08-May-2008
Renewed: 08-May-2026
Bypass:
Shutoffs: (ooo),ii

Type: SVB
Manufacturer: Wilkins
Model: 460XL
Size: 3/8
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: SVB
Manufacturer: Wilkins
Model: 460XL
Size: 1/2
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

---

Type: SVB
Manufacturer: Wilkins
Model: 460XL
Size: 3/4
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

Type: SVB
Manufacturer: Wilkins
Model: 460XL
Size: 1
Orientation: VUH
Meters:
Manual: 9
0.25% Pb: Yes
Spare Parts Only: No
Approved: 21-Mar-2011
Renewed: 21-Mar-2026
Bypass:
Shutoffs: (iiii)
Notes: Testcocks: Female Threaded End or 45 degree male SAE flare

2026 © University of Southern California

Manufacturers of Approved Backflow Prevention Assemblies

Ames Fire & Waterworks - A Watts Water Technologies Company
http://www.amesfirewater.com
815 Chestnut Street
North Andover, MA 01845
(978) 688-1811

Apollo/Conbraco Industries, Inc.
http://www.apollovalves.com
P. O. Box 247
Matthews, NC 28105
(704) 847-9191

AQUESTIA (A.R.I) DIRECTING THE FLOW
http://www.arivalves.com
Kibbutz Kfar Charuv
M.P. South Golan
ISRAEL, 12932
972-4-6761800 or 972-4-6761988

Backflow Direct - A Watts Water Technologies Company
www.backflowdirect.com
815 Chestnut Street
North Andover, MA 01845
(978) 688-1811

BEECO - Distributed by Mifab
www.beecobackflow.com
1321 West 119th St
Chicago, IL 60643-5109
(800) 465-2736

Cla-Val Company
http://www.cla-val.com
P. O. Box 1325
Newport Beach, CA 92659-0325
(949) 722-4800

FEBCO - A Watts Water Technologies Company
http://www.febcoonline.com
815 Chestnut Street
North Andover, MA 01845
(978) 688-1811

MGI Controls - An Acorn Engineering Company
http://www.mgicontrols.com
15125 Proctor Ave.
City of Industry, CA 91746
(626) 336-4561

Watts - A Watts Water Technologies Company
http://www.wattsreg.com
815 Chestnut Street
North Andover, MA 01845
(978) 688-1811

Wilkins Regulator Company
http://www.zurn.com
1747 Commerce Way
Paso Robles, CA 93446
(800) 817-8177